

A. BALANCE OUTSIDE AIR CONNECTION TO ALL FAN COILS AT 50 CFM.

B. PROVIDE CEILING RADIATION DAMPERS WHERE PENETRATING FIRE RATED ASSEMBLY.



DESIGNED BY:	CJE
DRAWN BY:	CJE
CHECKED BY:	RSA
SCALE:	AS NOTED
NOTES:	

SECOND FLOOR DUCTWORK PLAN

**HARRIS A. SANDELS
ARCHITECTS, P.C.**
252 WASHINGTON AVENUE, ALBANY, NEW YORK 12210

ELDOR ADULT CARE FACILITY
156 WEST CLARKSTOWN ROAD
NEW CITY N.Y. 10956



IT NO:

M103

BID SET 9-18-20	OF:
-----------------	-----

