

PANEL RP2																				
VOLTAGE:		120/208				AMP:		150												
PHASE:		3				MAIN:		MCB												
DESCRIPTION	KW	BKR	CK	PH	CK	BKR	KW	DESCRIPTION												
REC ELEC RM	0.18	20/1	7	A	2	20/1	0.36	GF REC RESTRMS												
SCRUBBER	0.36	20/1	8	B	4	20/1	1	HAND DRYER												
DOOR BELL	0.36	20/1	5	C	6	20/1	1	HAND DRYER												
MGR OFF REC	1.08	20/1	7	A	8	20/1	0.18	BRK RM MV												
ASST MGR OFF REC	1.08	20/1	8	B	10	20/1	0.18	BRK RM GF REC												
CASH RM REC	1.08	20/1	11	C	12	20/1	0.6	BRK RM REC												
SPARE	1.08	20/1	12	A	14	20/1	1	VENDING												
OFFICE TV MONITORS	0.72	20/1	15	B	16	20/1	1	VENDING												
TIMELOCK	0.36	20/1	17	C	18	20/1	1	REFRIG												
WATER COOLER	0.5	20/1	19	A	20	20/1	0.72	QUAD REC RACKS												
ICE BIN	0.5	20/1	21	B	22	20/1	0.72	QUAD REC RACKS												
REC MONITOR	0.5	20/1	23	C	24	20/1	0.36	QUAD SW WARE MGR												
COPPER	0.5	20/1	25	A	26	20/1	0.72	FLR MGR REC												
COFFEE	0.18	20/1	27	B	28	20/1	0.36	REC OUTSIDE												
COFFEE	0.18	20/1	29	C	30	20/1	0.36	REC PRINT END MGR												
CUST SERV REC	0.72	20/1	31	A	32	20/1	0.18	CORD REEL REC												
EF-1	0.34	20/1	33	B	34	20/1	0.18	CORD REEL REC												
EF-2	0.34	20/1	35	C	36	20/1	0.18	LCP-ELSB												
EF-3	0.2	20/1	37	A	38	20/1	0.18	CONDENS PUMP												
BMS LTG CONTACTR	0.18	20/1	39	B	40	25/2	1.9	AHU-2 CU-2												
BMS LTG CONTACTR	0.18	20/1	41	C	42	—	1.9	—												
A TOTAL	7.6		VLL		PH															
B TOTAL	9.7		208		3															
C TOTAL	8.3																			
CONN. kVA	24.6																			
CONN. amps	68.4																			

PANEL RP2												
VOLTAGE:			120/208			AMP:			225			
PHASE:			3			MAIN:			MLO			
DESCRIPTION	KW	BKR	CK	PH	CK	BKR	KW	DESCRIPTION				
FIRE ALARM PNL	0.18	20/1	43	A	44	50/2	4	SPIDER BOX				
BLDG MTD SIGN	0.5	20/1	45	B	46	—	4	—				
LTS SMALLWARES	0.7	20/1	47	C	48	50/2	4	SPIDER BOX				
LTS SMALLWARES	1	20/1	49	A	50	—	4	—				
LCP-LP2	0.18	20/1	51	B	52	20/1	0.2	CFA				
RCP-1	0.4	20/1	53	C	54	20/1	—	SHUNT TRIP				
BLDG MTD SIGN	0.5	20/1	55	A	56	20/1	0.36	PROD MGR REC				
BLDG MTD SIGN	0.5	20/1	57	B	58	20/1	—	SPARE				
LCP-RP2	0.18	20/1	59	C	60	20/1	—	SPARE				
LTS LIGHTBOX	0.2	20/1	61	A	62	—	—	SPARE				
SPACE	—	—	63	B	64	—	—	SPACE				
SPACE	—	—	65	C	66	—	—	SPACE				
SPACE	—	—	67	A	68	—	—	SPACE				
SPACE	—	—	69	B	70	—	—	SPACE				
SPACE	—	—	71	C	72	—	—	SPACE				
SPACE	—	—	73	A	74	—	—	SPACE				
SPACE	—	—	75	B	76	—	—	SPACE				
SPACE	—	—	77	C	78	—	—	SPACE				
SPACE	—	—	79	A	80	—	—	SPACE				
SPACE	—	—	81	B	82	—	—	SPACE				
SPACE	—	—	83	C	84	—	—	SPACE				
A TOTAL	10.24		VLL		PH							
B TOTAL	5.38		208		3							
C TOTAL	5.28											
CONN. kVA	20.9											
CONN. amps	58.1											

PANEL REH																				
VOLTAGE:			277/480			AMP:			800											
PHASE:			3			MAIN:			MLQ											
DESCRIPTION	KW	BKR	OK	PH	CK	BKR	KW	DESCRIPTION												
A-12A (FANS)	0.6	20/3	7	A	2	20/2	1.2	A-8B (FANS)												
	0.6	—	8	B	4	—	—	—												
	0.6	—	9	C	6	20/2	1.2	A-7B (FANS)												
A-12B (FANS)	0.6	20/3	7	A	8	—	1.2	—												
	0.6	—	9	B	10	20/2	1.2	A-8A (FANS)												
	0.6	—	11	C	12	—	—	—												
SPARE	—	20/2	13	A	14	20/2	1.2	A-7A (FANS)												
	—	—	15	B	16	—	1.2	—												
A-11B (FANS)	1.2	20/2	17	C	18	20/2	1.2	A-6B (FANS)												
	1.2	—	19	A	20	—	1.2	—												
A-11A (FANS)	1.2	20/2	21	C	22	20/2	1.2	A-5B (FANS)												
	1.2	—	23	A	24	—	1.2	—												
A-10B (FANS)	1.2	20/2	25	A	26	20/2	1.2	A-6A (FANS)												
	1.2	—	27	B	28	—	1.2	—												
A-9B (FANS)	1.2	20/2	29	C	30	20/2	1.2	A-5A (FANS)												
	1.2	—	31	A	32	—	1.2	—												
A-10A (FANS)	1.2	20/2	33	B	34	20/2	1.2	A-4B (FANS)												
	1.2	—	35	C	36	—	1.2	—												
A-9A (FANS)	1.2	20/2	37	A	38	20/2	1.2	A-3B (FANS)												
	1.2	—	39	B	40	—	1.2	—												
SPACE	—	—	41	C	42	—	—	SPACE												
A TOTAL	14.4		VLL		PH															
B TOTAL	14.4		480		3															
C TOTAL	13.2																			
CONN. kVA	42																			
CONN. amps	50.6																			

PANEL REH									
2ND SECTION									
DESCRIPTION	KW	BKR	CK	PH	CK	BKR	KW	DESCRIPTION	
A-4A (FANS)	1.2	20/1	43	A	44	30/3	5.8	B-2A (DEFROST)	
—	1.2	—	45	B	46	—	5.8	—	
A-3A (FANS)	1.2	20/2	47	C	48	—	5.8	—	
—	1.2	—	49	A	50	20/3	0.6	B-2A (FANS)	
A-2B (FANS)	1.2	20/2	51	B	52	—	0.6	—	
—	1.2	—	53	C	54	—	0.6	—	
A-2A (FANS)	1.2	20/2	55	A	56	30/3	5.8	B-1B (DEFROST)	
—	1.2	—	57	B	58	—	5.8	—	
A-1B (FANS)	1.2	20/2	59	C	60	—	5.8	—	
—	1.2	—	61	A	62	20/3	0.6	B-1B (FANS)	
A-1A (FANS)	1.2	20/2	63	B	64	—	0.6	—	
—	1.2	—	65	C	66	0.6	0.6	—	
B-1A (FANS)	0.6	30/3	67	A	68	30/3	5.8	B-3A (DEFROST)	
—	0.6	—	69	B	70	—	5.8	—	
—	0.6	—	71	C	72	—	5.8	—	
B-1A (DEFROST)	5.8	30/3	73	A	74	20/3	0.6	B-3A (FANS)	
—	5.8	—	75	B	76	—	0.6	—	
—	5.8	—	77	C	78	—	0.6	—	
B-2B (DEFROST)	5.8	30/3	79	A	80	20/3	0.6	B-2B (FANS)	
—	5.8	—	81	B	82	—	0.6	—	
—	5.8	—	83	C	84	—	0.6	—	
A TOTAL		36.8		VLL		PH			
B TOTAL		36.8		480		S			
C TOTAL		36.8							
CONN. kVA		110.4							
CONN. amps		132.9							