

SECTION 213113 - ELECTRIC-DRIVE, CENTRIFUGAL FIRE PUMPS

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
 - 1. Horizontally mounted, single-stage, split-case fire pumps.
 - 2. Horizontally mounted, multistage, split-case fire pumps.
 - 3. Vertically mounted, single-stage, split-case fire pumps.
 - 4. Fire-pump accessories and specialties.
 - 5. Flowmeter systems.

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product. Include rated capacities, operating characteristics, performance curves, electrical characteristics, and furnished specialties and accessories.
- B. Shop Drawings: For fire pumps, motor drivers, and fire-pump accessories and specialties.
 - 1. Include plans, elevations, sections, and mounting and attachment details.
 - 2. Include details of equipment assemblies. Indicate dimensions, weights, loads, required clearances, method of field assembly, components, and location and size of each field connection.
 - 3. Include diagrams for power, signal, and control wiring.

1.4 INFORMATIONAL SUBMITTALS

- A. Product Certificates: For each type of fire pump, from manufacturer.
- B. Source quality-control reports.
- C. Field quality-control reports.

1.5 CLOSEOUT SUBMITTALS

- A. Operation and Maintenance Data: For fire pumps to include in operation and maintenance manuals.

PART 2 - PRODUCTS

2.1 PERFORMANCE REQUIREMENTS

- A. NFPA Compliance: Comply with NFPA 20.
- B. Pump Equipment, Accessory, and Specialty Pressure Rating: 175 psig (1200 kPa) minimum unless higher pressure rating is indicated.
- C. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.

2.2 GENERAL REQUIREMENTS FOR CENTRIFUGAL FIRE PUMPS

- A. Description: Factory-assembled and -tested fire-pump and driver unit.
- B. Finish: Red paint applied to factory-assembled and -tested unit before shipping.

2.3 HORIZONTALLY MOUNTED, SINGLE-STAGE, SPLIT-CASE FIRE PUMPS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - 1. A-C Fire Pump; a Xylem brand.
 - 2. Patterson Pump Company; a Gorman-Rupp company.
 - 3. Peerless Pump Company.
- B. Pump:
 - 1. Standard: UL 448, for split-case pumps for fire service.
 - 2. Casing: Axially split case, cast iron, with ASME B16.1 pipe-flange connections.
 - 3. Impeller: Double suction, cast bronze, statically and dynamically balanced, and keyed to shaft.
 - 4. Wear Rings: Replaceable bronze.
 - 5. Shaft and Sleeve: Alloy steel shaft with bronze sleeve.
 - a. Shaft Bearings: Grease-lubricated ball bearings in cast-iron housing.
 - b. Seals: Stuffing box with minimum of four rings of graphite-impregnated braided yarn and bronze packing gland.
 - 6. Mounting: Pump and driver shafts are horizontal, with pump and driver on same base.

- C. Coupling: Flexible and capable of absorbing torsional vibration and shaft misalignment. Include metal coupling guard.
- D. Driver:
 - 1. Standard: UL 1004A.
 - 2. Type: Electric motor; NEMA MG 1, polyphase Design B.

2.4 HORIZONTALLY MOUNTED, MULTISTAGE, SPLIT-CASE FIRE PUMPS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - 1. A-C Fire Pump; a Xylem brand.
 - 2. Patterson Pump Company; a Gorman-Rupp company.
 - 3. Peerless Pump Company.
- B. Pump:
 - 1. Standard: UL 448, for split-case pumps for fire service.
 - 2. Number of Stages: Two.
 - 3. Casing: Axially split case, cast iron with ASME B16.1 pipe-flange connections.
 - 4. Impeller: Single suction, cast bronze, statically and dynamically balanced, and keyed to shaft.
 - 5. Wear Rings: Replaceable bronze.
 - 6. Shaft and Sleeve: Alloy steel shaft with bronze sleeve.
 - a. Shaft Bearings: Grease-lubricated ball bearings in cast-iron housing.
 - b. Seals: Stuffing box with minimum of four rings of graphite-impregnated braided yarn and bronze packing gland.
 - 7. Mounting: Pump and driver shafts are horizontal, with pump and driver on same base.
- C. Coupling: Flexible and capable of absorbing torsional vibration and shaft misalignment. Include metal coupling guard.
- D. Driver:
 - 1. Standard: UL 1004A.
 - 2. Type: Electric motor; NEMA MG 1, polyphase Design B.

2.5 VERTICALLY MOUNTED, SINGLE-STAGE, SPLIT-CASE FIRE PUMPS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - 1. A-C Fire Pump; a Xylem brand.
 - 2. Peerless Pump Company.
 - 3. Pentair Pump Group.

- B. Pump:
 - 1. Standard: UL 448, for split-case pumps for fire service.
 - 2. Casing: Axially split case, cast iron, with ASME B16.1 pipe-flange connections.
 - 3. Impeller: Double suction, cast bronze, statically and dynamically balanced, and keyed to shaft.
 - 4. Wear Rings: Replaceable bronze.
 - 5. Shaft and Sleeve: Alloy steel shaft with bronze sleeve.
 - a. Shaft Bearings: Grease-lubricated ball bearings in cast-iron housing.
 - b. Seals: Stuffing box with minimum of four rings of graphite-impregnated braided yarn and bronze packing gland.
 - 6. Mounting: Pump and driver shafts are vertical, with motor above pump and pump on base.
- C. Coupling: Flexible and capable of absorbing torsional vibration and shaft misalignment. Include metal coupling guard.
- D. Driver:
 - 1. Standard: UL 1004A.
 - 2. Type: Electric motor; NEMA MG 1, polyphase Design B.

2.6 FIRE-PUMP ACCESSORIES AND SPECIALTIES

- A. Automatic Air-Release Valves: Comply with NFPA 20 for installation in fire-pump casing.
- B. Circulation Relief Valves: UL 1478, brass, spring loaded; for installation in pump discharge piping.
- C. Relief Valves:
 - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. CLA-VAL Automatic Control Valves.
 - b. Kunkle Valve.
 - 2. Description: UL 1478, bronze or cast iron, spring loaded; for installation in fire-suppression water-supply piping.
- D. Inlet Fitting: Eccentric tapered reducer at pump suction inlet.
- E. Outlet Fitting: Concentric tapered reducer at pump discharge outlet.
- F. Discharge Cone: Closed or open type.
- G. Hose Valve Manifold Assembly:

1. Standard: Comply with requirements in NFPA 20.
2. Header Pipe: ASTM A 53/A 53M, Schedule 40, galvanized steel, with ends threaded according to ASME B1.20.1.
3. Header Pipe Fittings: ASME B16.4, galvanized cast-iron threaded fittings.
4. Automatic Drain Valve: UL 1726.
5. Manifold:
 - a. Test Connections: Comply with UL 405; however, provide outlets without clappers instead of inlets.
 - b. Body: Flush type, brass or ductile iron, with number of outlets required by NFPA 20.
 - c. Nipples: ASTM A 53/A 53M, Schedule 40, galvanized-steel pipe, with ends threaded according to ASME B1.20.1.
 - d. Adapters and Caps with Chain: Brass or bronze, with outlet threaded according to NFPA 1963 and matching local fire-department threads.
 - e. Escutcheon Plate: Brass or bronze; rectangular.
 - f. Hose Valves: UL 668, bronze, with outlet threaded according to NFPA 1963 and matching local fire-department threads.
 - g. Exposed Parts Finish: Rough brass.
 - h. Escutcheon Plate Marking: Equivalent to "FIRE PUMP TEST."

2.7 FLOWMETER SYSTEMS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 1. Emerson Process Management; Rosemount Division.
 2. Hyspan Precision Products, Inc.
 3. Reddy-Buffaloes Pump Company.
- B. Description: UL-listed or FM-Approved, fire-pump flowmeter system able to indicate flow to not less than 175 percent of fire-pump rated capacity.
- C. Pressure Rating: 175 psig (1200 kPa) minimum.
- D. Sensor: Annubar probe, orifice plate, or venturi unless otherwise indicated. Sensor size shall match pipe, tubing, flowmeter, and fittings.
- E. Permanently Mounted Flowmeter: Compatible with flow sensor; with dial not less than 4-1/2 inches (115 mm) in diameter. Include bracket or device for wall mounting.
 1. Tubing Package: NPS 1/8 or NPS 1/4 (DN 6 or DN 10) soft copper tubing with copper or brass fittings and valves.
- F. Portable Flowmeter: Compatible with flow sensor; with dial not less than 4-1/2 inches (115 mm) in diameter and with two 12-foot- (3.7-m-) long hoses in carrying case.

2.8 GROUT

- A. Standard: ASTM C 1107, Grade B, post-hardening and volume-adjusting, dry, hydraulic-cement grout.
- B. Characteristics: Nonshrink and recommended for interior and exterior applications.
- C. Design Mix: 5000-psi (34-MPa), 28-day compressive strength.
- D. Packaging: Premixed and factory packaged.

2.9 SOURCE QUALITY CONTROL

- A. Testing: Test and inspect fire pumps according to UL 448 requirements for "Operation Test" and "Manufacturing and Production Tests."
 - 1. Verification of Performance: Rate fire pumps according to UL 448.
- B. Fire pumps will be considered defective if they do not pass tests and inspections.
- C. Prepare test and inspection reports.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine equipment bases and anchorage provisions, with Installer present, for compliance with requirements for installation tolerances, and other conditions affecting performance of fire pumps.
- B. Examine roughing-in for fire-suppression piping systems to verify actual locations of piping connections before fire-pump installation.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 INSTALLATION

- A. Fire-Pump Installation Standard: Comply with NFPA 20 for installation of fire pumps, relief valves, and related components.
- B. Equipment Mounting:
 - 1. Install fire pumps on cast-in-place concrete equipment bases.
 - 2. Comply with requirements for vibration isolation devices specified in Section 21 05 48.13 "Vibration Controls for Fire-Suppression Piping and Equipment."

- C. Install fire-pump suction and discharge piping equal to or larger than sizes required by NFPA 20.
- D. Support piping and pumps separately, so weight of piping does not rest on pumps.
- E. Install valves that are same size as connecting piping. Comply with requirements for fire-protection valves specified in Section 21 13 13 "Wet-Pipe Sprinkler Systems."
- F. Install pressure gages on fire-pump suction and discharge flange pressure-gage tappings. Comply with requirements for pressure gages specified in Section 21 13 13 "Wet-Pipe Sprinkler Systems."
- G. Install piping hangers and supports, anchors, valves, gages, and equipment supports according to NFPA 20.
- H. Install flowmeters and sensors. Install flowmeter-system components and make connections according to NFPA 20 and manufacturer's written instructions.
- I. Electrical Wiring: Install electrical devices furnished by equipment manufacturers but not factory mounted. Furnish copies of manufacturers' wiring diagram submittals to electrical Installer.
- J. Wiring Method: Conceal conductors and cables in accessible ceilings, walls, and floors where possible.

3.3 ALIGNMENT

- A. Align split-case pump and driver shafts after complete unit has been leveled on concrete base, grout has set, and anchor bolts have been tightened.
- B. After alignment is correct, tighten anchor bolts evenly. Fill baseplate completely with grout, with metal blocks and shims or wedges in place. Tighten anchor bolts after grout has hardened. Check alignment and make required corrections.
- C. Align piping connections.
- D. Align pump and driver shafts for angular and parallel alignment according to HI 1.4 and to tolerances specified by manufacturer.

3.4 CONNECTIONS

- A. Comply with requirements for piping and valves specified in Section 21 13 13 "Wet-Pipe Sprinkler Systems." Drawings indicate general arrangement of piping, fittings, and specialties.
- B. Install piping adjacent to pumps and equipment to allow service and maintenance.
- C. Connect relief-valve discharge to drainage piping or point of discharge.
- D. Connect flowmeter-system meters, sensors, and valves to tubing.

- E. Connect fire pumps to their controllers.

3.5 IDENTIFICATION

- A. Identify system components. Comply with requirements for fire-pump marking according to NFPA 20.

3.6 FIELD QUALITY CONTROL

- A. Test each fire pump with its controller as a unit. Comply with requirements for electric-motor-driver fire-pump controllers specified in Section 26 29 33 "Controllers for Fire-Pump Drivers."
- B. Manufacturer's Field Service: Engage a factory-authorized service representative to inspect, test, and adjust components, assemblies, and equipment installations, including connections.
- C. Perform the following tests and inspections.
 - 1. After installing components, assemblies, and equipment, including controller, test for compliance with requirements.
 - 2. Test according to NFPA 20 for acceptance and performance testing.
 - 3. Leak Test: After installation, charge system and test for leaks. Repair leaks and retest until no leaks exist.
 - 4. Operational Test: After electrical circuitry has been energized, start units to confirm proper motor rotation and unit operation.
 - 5. Test and adjust controls and safeties. Replace damaged and malfunctioning controls and equipment.
- D. Components, assemblies, and equipment will be considered defective if they do not pass tests and inspections.
- E. Prepare test and inspection reports.
- F. Furnish fire hoses in number, size, and length required to reach storm drain or other acceptable location to dispose of fire-pump test water. Hoses are for tests only and do not convey to Owner.

3.7 DEMONSTRATION

- A. Train Owner's maintenance personnel to adjust, operate, and maintain fire pumps.

END OF SECTION 21 31 13