

PLUMBING FIXTURE SCHEDULE											
CODE	FIXTURE	MANUFACTURER / MODEL NO.	FAUCET/FLUSH VALVE	CW CONN.	HW CONN.	SAN CONN.	IW CONN.	VENT CONN.	ST CONN.	ACCESSORIES / COMMENTS	
WC-1	WATER CLOSET FLOOR MOUNTED	KOHLER / K-5310-0 "CIMARRON"	FLUSH TANK INCLUDED 1.28 GPF	1"	-	4"	-	2"	-	SEAT: ANGLE SUPPLY W/ STOP: TRIP LEVER:	KOHLER / K-4008-0 KOHLER / K-7637 KOHLER / K-9466-X-2BZ
WC-2	WATER CLOSET WALL MOUNTED	TOTO / CT708UVG	TOTO / TET3LA31#SS 1.28 GPF	1"	-	4"		2"		SEAT: SEE SPECIFICATIONS FOR ACCESSORIES	TOTO / SC534
LAV-1	LAVATORY UNDERMOUNTED	KOHLER / K-2882 "VERTICYL"	WATERMARK DESIGNS / Z3-2-17-L8 1.2 GPM W/ MPU5PL DRAIN, MPT1 P-TRAP	1/2"	1/2"	1-1/2"	-	1-1/2"	-	TMV	
LAV-2	LAVATORY UNDERMOUNTED	KOHLER/ K-5400 "IRON PLAINS"	SPLASH LAB / TSL R.020 (HARDWIRE) 0.50 GPM	1/2"	1/2"	1-1/2"	-	1-1/2"	-	TMV	
LAV-3	LAVATORY WALL MOUNTED	AMERICAN STANDARD / 355.012 "LUCERNE"	TOTO / TEL103 ECOPOWER 0.35 GPM	1/2"	1/2"	1-1/2"		1-1/2"	-	TMV	
DF-1	SINGLE BOWL DRINKING FOUNTAIN W/ BOTTLE FILL STATION	ELKAY / LZWS - EDFPBM114K	N/A	1/2"	-	1-1/2"	-	1-1/2"	-	SEE SPECIFICATIONS FOR ACCESSORIES	
DF-2	DOUBLE BOWL DRINKING FOUNTAIN W/ BOTTLE FILL STATION	ELKAY / LZWS-EDFPBM117K	N/A	1/2"	-	1-1/2"	-	1-1/2"	-	SEE SPECIFICATIONS FOR ACCESSORIES	
BF	BOTTLE FILL STATION	ELKAY / LZWSMDK	N/A	1/2"	-	1-1/2"	-	1-1/2"	-	SEE SPECIFICATIONS FOR ACCESSORIES	
SH-1	SHOWER	WATERMARK DESIGNS / Z3-HAF	N/A	1/2"	1/2"	2"	-	2"	-	PRESSURE BALANCE TRIM: PRESSURE BALANCE VALVE: DRAIN: DRAIN PLATE:	WATERMARK DESIGNS / Z3-P80-L9 WATERMARK DESIGNS / SS-PB75 WATERMARK DESIGNS / LDRK WATERMARK DESIGNS / LD6-XX
SH-2	SHOWER ADA	WATERMARK DESIGNS / Z3-HAF	WATERMARK DESIGNS / Z3-HSHK3 (2.0 GPM)	1/2"	1/2"	2"	-	2"	-	PRESSURE BALANCE TRIM: PRESSURE BALANCE VALVE: DRAIN: DRAIN PLATE: DIVERTER VALVE: DIVERTER VALVE TRIM KIT:	WATERMARK DESIGNS / Z3-P80-L8 WATERMARK DESIGNS / SS-PB75 WATERMARK DESIGNS / LDRK WATERMARK DESIGNS / LD6-XX WATERMARK DESIGNS / SS-WD2 WATERMARK DESIGNS / Z3-WTR-L8
BATH-1	BATH TUB ADA	WET STYLE / BC 14XX-#MA	WATERMARK DESIGNS / Z3-WBS WATERMARK DESIGNS / Z3-HSHK3 (2.0 GPM)	1/2"	1/2"	3"	-	2"	-	PRESSURE BALANCE TRIM: PRESSURE BALANCE VALVE: DIVERTER VALVE TRIM KIT:	WATERMARK DESIGNS / Z3-P80-L8 WATERMARK DESIGNS / SS-PB75 WATERMARK DESIGNS / Z3-WTR-L8
BATH-2	BATH TUB FREE STANDING	WET STYLE / BLB 01XX-#MA	WATERMARK DESIGNS / Z3-8.26-3-L8	1/2"	1/2"	3"	-	2"	-		
SK-1	SINK	ELKAY / LRAD222255	SPEAKMAN / SC-3004-LD-E 0.5 GPM	1/2"	1/2"	1-1/2"	-	1-1/2"	-	TMV	
SK-2	SINK	KOHLER / K-3894-4-NA	KOHLER / K-7505 1.5 GPM	1/2"	1/2"	1-1/2"	-	1-1/2"	-	TMV DRAIN:	KOHLER / K-8801 "DUOSTRAINER"
JSK-1	JANITOR'S SINK	FIAT / MSB-2424100 "MODESTO"	FIAT / 830AA	1/2"	1/2"	3"	-	2"	-	VB	
JSK-2	JANITOR'S SINK LAUNDRY TUB	FIAT / L-1 "SERV-A-SINK"	FIAT / A1000	1/2"	1/2"	2"		1-1/2"	-	VB	
EYE	EMERGENCY EYE WASH STATION	SPEAKMAN / SE-582	AS PROVIDED WITH FIXTURE 3.2 GPM	1/2"	1/2"	1-1/2"	-	1-1/2"	-	TMV	
FD-A	FLOOR DRAIN	ZURN / Z-505	N/A	-	-	SEE PLANS	-	2"	-	TP	
FD-B	FLOOR DRAIN	ZURN / ZN-415-B	N/A	-	-	SEE PLANS	-	2"	-	TP	
FD-C	FLOOR DRAIN	ZURN / Z-520	N/A	-	-	SEE PLANS	-	2"	-	TP	
FS	FLOOR SINK	ZURN / Z-1900-4	N/A	-	-	SEE PLANS	-	2"	-		
TD-1	TRENCH DRAIN, 12" WIDE	ZURN / Z882	N/A	-	-	SEE PLANS	-	2"	-	TP	
TD-2	TRENCH DRAIN, 6" WIDE	ZURN / Z886	N/A	-	-	SEE PLANS	-	2"	-	TP	
HB	HOSE BIBB	ZURN / Z1333XL	N/A	3/4"	-	-	-	-	-		
WH	WALL HYDRANT	ZURN / Z1330XL	N/A	3/4"	-	-	-	-	-		
FPWH	FREEZE PROOF WALL HYDRANT	ZURN / Z1320XL	N/A	3/4"	-	-	-	-	-		
FPRH	FREEZE PROOF ROOF HYDRANT	ZURN / Z1388XL	N/A	3/4"	-	-	-		-	VB	
AD	AREA DRAIN	ZURN / Z-550	N/A	-	-	-	-	-	SEE PLANS		
RD-A	ROOF DRAIN	ZURN / Z-100-ERC	N/A	-	-	-	-	-	SEE PLANS		
RD-B	GUTTER DRAIN	ZURN/ Z180 CORNICE DRAIN	N/A	-	-	-	-	-	2"		
RD-C	CANOPY DRAIN	ZURN/ Z180 CORNICE DRAIN	N/A	-	-	-	-	-	2"		
OD-A	OVERFLOW ROOF DRAIN	ZURN / Z-100-ERC-W4	N/A	-	-	-	-	-	SEE PLANS		
GENERAL NOTES											
1. PLUMBING DESIGN AND SIZES ARE BASED ON THE 2015 NYS PLUMBING CODE.											
2. ALL EXPOSED PIPING SERVING PLUMBING FIXTURES THAT MAY BE USED FOR ADA PURPOSES SHALL TRAPS AND SUPPLIES INSULATED PER ADA REQUIREMENTS.											
3. FINISH AND TYPE OF ALL FIXTURES AND FAUCETS ARE SUBJECT TO ARCHITECT APPROVAL. REFER TO ARCHITECTURAL SCHEDULE.											
4. EACH PLUMBING FIXTURE SHALL BE PROVIDED WITH A P-TRAP, EXCEPT THOSE WITH INTEGRAL TRAPS.											
5. EXTEND INDIRECT WASTE FULL SIZE TO NEAREST FLOOR DRAIN OR FLOOR SINK, UNLESS OTHERWISE NOTED ON PLANS.											
6. FAUCET SHALL BE LEAD FREE AS PER COMPLIANCE WITH NSF 61.											
7. EXTEND DOMESTIC HOT WATER RECIRCULATION LINE AS REQUIRED TO ALLOW FOR HOT WATER TO BE RECIRCULATED WITHIN 24" OF LAVATORY VALVE STOPS.											
ACCESSORY CODES											
TP = TRAP PRIMER											
VB = VACUUM BREAKER											
FLTR = FILTER											
TMV = POINT-OF-USE THERMOSTATIC MIXING VALVE, ASSE 1070 COMPLIANT											