

LONGO ARCHITECTS
& ASSOCIATES LLC

WILLIAM R. RYAN AIA
VINCENT F. WOLK AIA

ASSOCIATE
MITCHELL C. BOBYACK RA

September 10, 2021

ADDENDUM #1
TO CONTRACT DOCUMENTS
FOR WELLS FARGO
NEW BRANCH INTERIOR FIT-OUT
1130 EAST BOSTON POST ROAD, MAMARONECK, NY 10543

All bidders are advised that this Addendum and its contents are to be added to the original Specifications for the project and may alter, amend or clarify the original Specifications and Drawings for the project, taking precedence where in conflict.

Clarifications/Updates:

1. Address Correction: 1130 East Boston Post Road, Mamaroneck NY 10543
2. Please provide LVT in the restrooms. Ignore note for FF7 on Drawing A-103
3. Please provide ½” glass for all sidelight glass. Disregard any other dimensions shown on the drawings.
4. Please provide ½” tempered glass at Door 104.
5. Previously mentioned but worth mentioning again:
 - a. Exclude furnishing & installation of AP-1 and AP-2 from your bid. That is furnished & installed by QSP. Any wall prep in those areas are still the responsibility of the GC.
 - b. Below is the spec for light fixture Type C – the Acoustic Square light found in the Conference Room: **“LightART” Acoustic Box**

ACC - SHPE - BOX
Size: 32 in SQ
Height: 12 in H
Felt Color: Nickel
Suspension: 24in – 96in
LED CRI / CCT: 80 CRI / 3000K
Canopy Color: White
Power Cord: White

- c. GC is responsible to maintain labor harmony throughout the duration of the project (this is also mentioned in the invitation to bid)

September 10, 2021

Wells Fargo – Mamaroneck NY

Addendum #1

Submitted By:

A handwritten signature in black ink that reads "Vincent F. Wolk". The signature is written in a cursive style with a large, prominent "V" at the beginning.

Vincent F. Wolk, AIA, NCARB
VFW/mlw