

PLUMBING FIXTURE SCHEDULE

TAG	SYMBOLS		FIXTURES	PLUMBING CONNECTIONS				DESCRIPTION
	PLAN	ELEVATION		WASTE	VENT	COLD WATER	HOT WATER	
P-1			WATER CLOSET WALL HUNG	4"	2"	1 1/2"	-	TOILET; MAKE: AMERICAN STANDARD MODEL: 3351.101AF WALL MILLENIUM FLOWISE 1.28 GPF FLUSHOMETER TOILET SYSTEM 1.28 GPF WALL-MOUNT ELONGATED FLUSHOMETER VALVE TOILET, ADA COMPLIANT, 1 1/2" INLET SPUD, FULLY GLAZED 2 1/2" TRAPWAY. AMERICAN STANDARD FLUSHOMETER SELECTRONIC FLOWISE MODEL 6065.122 1.28 GALLONS PER FLUSH, ELECTRONIC FLUSH VALVE, HARD-WIRED, FULLY MECHANICAL MANUAL OVERRIDE BUTTON, AUTOMATIC FLUSH AFTER 24 HOURS OF NON-USE, 3-SECOND FLUSH DELAY, 1" IPS SCREWDRIVER BAK-CHECK ANGLE STOP, VANDAL RESISTANT STOP CAP, ADJUSTABLE TAILPIECE, INTEGRAL VACUUM BREAKER AND 1 1/2" SPUD COUPLING PROVIDE WALL CARRIER SIMILAR TO WATTS ISCA-101-R & ISCA-131 FOR BACK TO BACK INSTALLATION & ROUTING OF WASTE HORIZONTAL WITHIN CHASE.
P-2			URINAL	2"	2"	1"	-	URINAL; MAKE: AMERICAN STANDARD MODEL: DECORUM FLOWISE 0.5 GPF HIGH EFFICIENCY URINAL 0.5 GPF VITREOUS CHINA URINAL, ADA COMPLIANT, 3/4" INLET SPUD, OUTLET CONNECTION THREADED 2" INSIDE, PROVIDE WALL CARRIER. AMERICAN STANDARD FLUSHOMETER SELECTRONIC FLOWISE MODEL 6062.002 0.125 GALLONS PER FLUSH, ELECTRONIC FLUSH VALVE, HARD-WIRED, FULLY MECHANICAL MANUAL OVERRIDE BUTTON, AUTOMATIC FLUSH AFTER 24 HOURS OF NON-USE, 3-SECOND FLUSH DELAY, 1" IPS SCREWDRIVER BAK-CHECK ANGLE STOP, VANDAL RESISTANT STOP CAP, ADJUSTABLE TAILPIECE, INTEGRAL VACUUM BREAKER AND 1 1/2" SPUD COUPLING. SEE ARCHITECTS DRAWINGS FOR MOUNTING HEIGHTS.
P-3			COUNTERTOP LAVATORY	2"	2"	1/2"	1/2"	LAVATORY; MAKE: KOHLER MODEL: K-2189-1 LADENA 20 7/8"x14 3/8"x8 3/8" DROP-IN MOUNT BATHROOM SINK, RECTANGULAR BASIN WITH CURVED BOTTOM, NO FAUCET HOLES; REQUIRES WALL OR COUNTER MOUNT FAUCET. FAUCET; MAKE: AMERICAN STANDARD MODEL: 2064.195 SENSOR OPERATED PROXIMITY LAVATORY FAUCET, HARD-WIRED AC, 0.5 GPM PCA, VR MULTI-LAMINAR SPRAY. PROVIDE THERMOSTATIC MIXING VALVE 605XTMV10701.
P-4			SHOWER	2"	1-1/2"	1/2"	1/2"	SHOWER; MAKE: AMERICAN STANDARD MODEL: T675.507.002 COLONY SOFT COLLECTION COLONY SOFT FLOWISE SHOWER TRIM KIT. POLISHED CHROME FINISH, METAL LEVER HANDLES, 1.5 GPM MAX FLOW. SHOWER PAN; MAKE: ZORO MODEL: G 2245680, 36"x36" TERRAZZO SHOWER PAN FOR TILED WALL APPLICATION.
NFHB			HOSE BIB	-	-	-	-	IN UNFINISHED SPACES, WASHDOWN FAUCET SHALL BE POLISHED CHROME-PLATED WALL FAUCET WITH 1/2" MALE INLET AND 3/4" HOSE THREAD OUTLET: CHICAGO #5 WITH #E27 VACUUM BREAKER OR ACCEPTABLE EQUIVALENT.
FD-1			FLOOR DRAIN	3"	2"	-	-	FOR TRAFFIC AREA OF GOLF CART STORAGE & MAINT. GARAGE: WADE #W-1210-27 WITH CAST IRON BODY, CAST IRON DRAINAGE FLANGE, SEDIMENT BUCKET, FLASHING COLLAR, 12" ROUND HEAVY DUTY CAST IRON GRATE. PROVIDE PROSET TRAP GUARD.
FD-2			FLOOR DRAIN	3"	2"	-	-	FOR MECHANICAL AREA: WADE #W-1100-STD5-1-27 WITH 5" ROUND ADJUSTABLE NICKEL-BRASS STRAINER, CAST IRON BODY, CAST IRON DRAINAGE FLANGE, FLASHING CLAMP, AND SEDIMENT BUCKET. PROVIDE PROSET TRAP GUARD.
FD-3			FLOOR DRAIN	3"	2"	-	-	FOR BATHROOMS: WADE #W-1100-STD5-1-27 WITH 5" ROUND ADJUSTABLE NICKEL-BRASS STAINER, CAST IRON BODY, CAST IRON DRAINAGE FLANGE, FLASHING CLAMP, AND SEDIMENT BUCKET.

NOTES:
1.) REFER TO ARCHITECTURAL DRAWINGS FOR FIXTURE, QUANTITY, LOCATIONS, & MOUNTING HEIGHTS.

IN CHARGE OF JW
CHECKED BY RG
MADE BY AMB

IT IS A VIOLATION OF NYS LAW FOR ANY PERSON TO ALTER THIS DOCUMENT IN ANY WAY, UNLESS ACTING UNDER THE DIRECTION OF A LICENSED PROFESSIONAL ENGINEER. IF A DOCUMENT BEARING THE SEAL OF AN ENGINEER IS ALTERED, THE ALTERING ENGINEER SHALL AFFIX TO THE DOCUMENT THEIR SEAL AND THE NOTATION "ALTERED BY" FOLLOWED BY THEIR SIGNATURE AND THE DATE OF SUCH ALTERATION, AND A SPECIFIC DESCRIPTION OF THE ALTERATION.

 OLA Consulting Engineers 60 Broadway, Hawthorne, New York 10632 914.747.2600 8 West 38th Street, Suite 601 New York, NY 10018 646.849.4110 ola.com				
			DBA0006.00	
REVISION NUMBER	DATE	MADE BY	APP'D BY	REVISION
RECORD DRAWING CERTIFICATION				
<input type="checkbox"/> AS BUILT - CHANGES AS NOTED <input type="checkbox"/> AS BUILT - NO CHANGES				
CONTRACTOR		PROJECT COORDINATOR		
NAME	DATE	NAME	DATE	
SIGNATURE		SIGNATURE		
TITLE		TITLE		
WESTCHESTER COUNTY, NEW YORK		CONTRACT NUMBER	SHEET NUMBER	
DEPARTMENT OF PUBLIC WORKS		17-539	P-601	
DIVISION OF ENGINEERING		SHEET NO. 34 OF 59		
NEW GOLF CART STORAGE FACILITY AND CLUBHOUSE UPGRADES		SCALE: NONE	DATE: 6/4/21	
MOHANSIC GOLF COURSE, YORKYOWN, NEW YORK		DPW FILE NO.	REV. NO.	
PLUMBING SCHEDULES		10-02-P-67-0	0	