



City of Yonkers/Yonkers Public Schools
One Larkin Center – 3rd Floor
Yonkers, New York 10701
(914) 377-6036
Fax: (914) 377-6032
Email: kimberly.sansevere@yonkersny.gov

CITY OF YONKERS/YONKERS PUBLIC SCHOOLS
Purchasing

Mike Spano, Mayor
Tom Collich, Director

2 Pages

January 15, 2021

TO: PROSPECTIVE BIDDERS
FROM: KIM SANSEVERE, PRINCIPAL BUYER
Re: IFB-6570 –HVAC UPGRADES AT SAUNDERS TRADES & TECHNICAL HIGH SCHOOL

ADDENDUM NO. 1

The contents of this addendum alter and amend the original bid requirements and take precedence over the related items therein. This addendum forms a part of the contract documents. Bidders must acknowledge receipt of all addenda when submitting their bids. Failure to acknowledge receipt may render your bid as non-responsive and ineligible for award. Vendors are responsible for ensuring that they receive all addenda.

The following changes are made to the issued bid drawings:

- **FA-001: Fire Alarm Notes, Note 1 is revised to state:**
“ELECTRICAL CONTRACTOR SHALL INCLUDE IN HIS BASE BID ALL FIRE ALARM RELATED WORK TO BE PERFORMED BY FIRE ALARM SUB-CONTRACTOR PER THE SCOPE OF WORK CONTAINED ON THESE DRAWINGS IN CONNECTION WITH THE FIRE ALARM SYSTEM. THESE DRAWINGS ARE PROVIDED FOR BID PURPOSES ONLY AND TO ILLUSTRATE THE SCOPE OF WORK INTENT OF THIS PROJECT. PRIOR TO SUBMISSION OF THE BID, THE CONTRACTOR IS RESPONSIBLE TO REVIEW ALL DRAWINGS (I.E., MECHANICAL/HVAC, ELECTRICAL, PLUMBING, FIRE SPRINKLER, AND ARCHITECTURAL). UPON SUBMISSION OF THE BID, THE ELECTRICAL CONTRACTOR CERTIFIES THAT ALL DRAWINGS HAVE BEEN REVIEWED, THE SITE HAS BEEN VISITED/INSPECTED (IF APPLICABLE), AND THAT ALL LOCAL FIRE MARSHALL REQUIRED ITEMS ARE FULLY UNDERSTOOD AND INCLUDED IN THE BID PRICE (NO CHANGE ORDERS ALLOWED).”

FA-001: Fire Alarm Notes, Note 3 is revised to state:
“ELECTRICAL CONTRACTOR MUST SUBMIT TO THE ENGINEER & OWNER FINAL (AS APPROVED BY THE LOCAL BLDG. DEPT. & FIRE MARSHALL) SIGNED AND SEALED (BY ANY LICENSED PE) DESIGN/BUILD DRAWINGS INCLUDING: FIRE ALARM RISER DIAGRAM, LAYOUT, EQUIPMENT LIST & SPECIFICATIONS PRIOR TO START OF INSTALLATION. THE COST OF THE ENGINEERING FEE, PROGRAMMING CHARGE, NEW EQUIPMENT, CONNECTION & TESTING, TROUBLE SHOOTING OF SYSTEM, ATTENDANCE AT THE FIRE ALARM INSPECTION, ETC. ARE TO BE PART OF THE BASE BID. INSTALLATION OF THE NEW FIRE ALARM SYSTEM CAN BEGIN UPON WRITTEN APPROVAL FROM THE ENGINEER.”

S-001: Structural Steel Notes: Note 10 is clarified to state:
“ENDS OF BEAMS AND WEBS SHALL BE REINFORCED WHERE CUTS OR COPIES REDUCE STRENGTH BELOW REQUIRED VALUES.”

S-001: Concrete Notes: Note 10 is clarified to state:

“COLD WEATHER CONCRETING SHALL BE IN ACCORDANCE WITH ACI-306. UNLESS TEMPERATURE IS AT LEAST 40°F (4.4°C) AND RISING, WATER AND/OR AGGREGATE SHOULD BE HEATED SO THAT THE TEMPERATURE OF THE CONCRETE, WHEN PLACED, IS NOT LESS THAN 55°F (13°C). PROVISION SHOULD BE MADE FOR MAINTAINING THE CONCRETE MOIST AND AT A MINIMUM TEMPERATURE OF NOT LESS THAN 50°F (10°C) FOR A PERIOD OF AT LEAST 7 DAYS.”

The bid due date remains 2:00 pm on February 4, 2021

**** End of Addendum ****

IFB-6570 - ADDENDUM NO. 1 – ACKNOWLEDGEMENT

(Please submit acknowledgement with your bid)

Legal Name of Bidding Firm: _____

Address: _____

Bidder's Representative: _____ **Title:** _____

E-mail: _____ **Fax:** _____ **Date:** _____

Signature: _____ **Telephone:** _____



City of Yonkers/Yonkers Public Schools
One Larkin Center – 3rd Floor
Yonkers, New York 10701
(914) 377-6036
Fax: (914) 377-6032
Email: kimberly.sansevere@yonkersny.gov

CITY OF YONKERS/YONKERS PUBLIC SCHOOLS
Purchasing

Mike Spano, Mayor
Tom Collich, Director

2 Pages

January 15, 2021

TO: PROSPECTIVE BIDDERS
FROM: KIM SANSEVERE, PRINCIPAL BUYER
Re: IFB-6570 –HVAC UPGRADES AT SAUNDERS TRADES & TECHNICAL HIGH SCHOOL

ADDENDUM NO. 1

The contents of this addendum alter and amend the original bid requirements and take precedence over the related items therein. This addendum forms a part of the contract documents. Bidders must acknowledge receipt of all addenda when submitting their bids. Failure to acknowledge receipt may render your bid as non-responsive and ineligible for award. Vendors are responsible for ensuring that they receive all addenda.

The following changes are made to the issued bid drawings:

- **FA-001: Fire Alarm Notes, Note 1 is revised to state:**
“ELECTRICAL CONTRACTOR SHALL INCLUDE IN HIS BASE BID ALL FIRE ALARM RELATED WORK TO BE PERFORMED BY FIRE ALARM SUB-CONTRACTOR PER THE SCOPE OF WORK CONTAINED ON THESE DRAWINGS IN CONNECTION WITH THE FIRE ALARM SYSTEM. THESE DRAWINGS ARE PROVIDED FOR BID PURPOSES ONLY AND TO ILLUSTRATE THE SCOPE OF WORK INTENT OF THIS PROJECT. PRIOR TO SUBMISSION OF THE BID, THE CONTRACTOR IS RESPONSIBLE TO REVIEW ALL DRAWINGS (I.E., MECHANICAL/HVAC, ELECTRICAL, PLUMBING, FIRE SPRINKLER, AND ARCHITECTURAL). UPON SUBMISSION OF THE BID, THE ELECTRICAL CONTRACTOR CERTIFIES THAT ALL DRAWINGS HAVE BEEN REVIEWED, THE SITE HAS BEEN VISITED/INSPECTED (IF APPLICABLE), AND THAT ALL LOCAL FIRE MARSHALL REQUIRED ITEMS ARE FULLY UNDERSTOOD AND INCLUDED IN THE BID PRICE (NO CHANGE ORDERS ALLOWED).”

FA-001: Fire Alarm Notes, Note 3 is revised to state:
“ELECTRICAL CONTRACTOR MUST SUBMIT TO THE ENGINEER & OWNER FINAL (AS APPROVED BY THE LOCAL BLDG. DEPT. & FIRE MARSHALL) SIGNED AND SEALED (BY ANY LICENSED PE) DESIGN/BUILD DRAWINGS INCLUDING: FIRE ALARM RISER DIAGRAM, LAYOUT, EQUIPMENT LIST & SPECIFICATIONS PRIOR TO START OF INSTALLATION. THE COST OF THE ENGINEERING FEE, PROGRAMMING CHARGE, NEW EQUIPMENT, CONNECTION & TESTING, TROUBLE SHOOTING OF SYSTEM, ATTENDANCE AT THE FIRE ALARM INSPECTION, ETC. ARE TO BE PART OF THE BASE BID. INSTALLATION OF THE NEW FIRE ALARM SYSTEM CAN BEGIN UPON WRITTEN APPROVAL FROM THE ENGINEER.”

S-001: Structural Steel Notes: Note 10 is clarified to state:
“ENDS OF BEAMS AND WEBS SHALL BE REINFORCED WHERE CUTS OR COPIES REDUCE STRENGTH BELOW REQUIRED VALUES.”

S-001: Concrete Notes: Note 10 is clarified to state:

“COLD WEATHER CONCRETING SHALL BE IN ACCORDANCE WITH ACI-306. UNLESS TEMPERATURE IS AT LEAST 40°F (4.4°C) AND RISING, WATER AND/OR AGGREGATE SHOULD BE HEATED SO THAT THE TEMPERATURE OF THE CONCRETE, WHEN PLACED, IS NOT LESS THAN 55°F (13°C). PROVISION SHOULD BE MADE FOR MAINTAINING THE CONCRETE MOIST AND AT A MINIMUM TEMPERATURE OF NOT LESS THAN 50°F (10°C) FOR A PERIOD OF AT LEAST 7 DAYS.”

The bid due date remains 2:00 pm on February 4, 2021

**** End of Addendum ****

IFB-6570 - ADDENDUM NO. 1 – ACKNOWLEDGEMENT

(Please submit acknowledgement with your bid)

Legal Name of Bidding Firm: _____

Address: _____

Bidder's Representative: _____ **Title:** _____

E-mail: _____ **Fax:** _____ **Date:** _____

Signature: _____ **Telephone:** _____



City of Yonkers/Yonkers Public Schools
One Larkin Center – 3rd Floor
Yonkers, New York 10701
(914) 377-6036
Fax: (914) 377-6032
Email: kimberly.sansevere@yonkersny.gov

CITY OF YONKERS/YONKERS PUBLIC SCHOOLS
Purchasing

Mike Spano, Mayor
Tom Collich, Director

2 Pages

January 15, 2021

TO: PROSPECTIVE BIDDERS
FROM: KIM SANSEVERE, PRINCIPAL BUYER
Re: IFB-6570 –HVAC UPGRADES AT SAUNDERS TRADES & TECHNICAL HIGH SCHOOL

ADDENDUM NO. 1

The contents of this addendum alter and amend the original bid requirements and take precedence over the related items therein. This addendum forms a part of the contract documents. Bidders must acknowledge receipt of all addenda when submitting their bids. Failure to acknowledge receipt may render your bid as non-responsive and ineligible for award. Vendors are responsible for ensuring that they receive all addenda.

The following changes are made to the issued bid drawings:

- **FA-001: Fire Alarm Notes, Note 1 is revised to state:**
“ELECTRICAL CONTRACTOR SHALL INCLUDE IN HIS BASE BID ALL FIRE ALARM RELATED WORK TO BE PERFORMED BY FIRE ALARM SUB-CONTRACTOR PER THE SCOPE OF WORK CONTAINED ON THESE DRAWINGS IN CONNECTION WITH THE FIRE ALARM SYSTEM. THESE DRAWINGS ARE PROVIDED FOR BID PURPOSES ONLY AND TO ILLUSTRATE THE SCOPE OF WORK INTENT OF THIS PROJECT. PRIOR TO SUBMISSION OF THE BID, THE CONTRACTOR IS RESPONSIBLE TO REVIEW ALL DRAWINGS (I.E., MECHANICAL/HVAC, ELECTRICAL, PLUMBING, FIRE SPRINKLER, AND ARCHITECTURAL). UPON SUBMISSION OF THE BID, THE ELECTRICAL CONTRACTOR CERTIFIES THAT ALL DRAWINGS HAVE BEEN REVIEWED, THE SITE HAS BEEN VISITED/INSPECTED (IF APPLICABLE), AND THAT ALL LOCAL FIRE MARSHALL REQUIRED ITEMS ARE FULLY UNDERSTOOD AND INCLUDED IN THE BID PRICE (NO CHANGE ORDERS ALLOWED).”

- FA-001: Fire Alarm Notes, Note 3 is revised to state:**
“ELECTRICAL CONTRACTOR MUST SUBMIT TO THE ENGINEER & OWNER FINAL (AS APPROVED BY THE LOCAL BLDG. DEPT. & FIRE MARSHALL) SIGNED AND SEALED (BY ANY LICENSED PE) DESIGN/BUILD DRAWINGS INCLUDING: FIRE ALARM RISER DIAGRAM, LAYOUT, EQUIPMENT LIST & SPECIFICATIONS PRIOR TO START OF INSTALLATION. THE COST OF THE ENGINEERING FEE, PROGRAMMING CHARGE, NEW EQUIPMENT, CONNECTION & TESTING, TROUBLE SHOOTING OF SYSTEM, ATTENDANCE AT THE FIRE ALARM INSPECTION, ETC. ARE TO BE PART OF THE BASE BID. INSTALLATION OF THE NEW FIRE ALARM SYSTEM CAN BEGIN UPON WRITTEN APPROVAL FROM THE ENGINEER.”

- S-001: Structural Steel Notes: Note 10 is clarified to state:**
“ENDS OF BEAMS AND WEBS SHALL BE REINFORCED WHERE CUTS OR COPIES REDUCE STRENGTH BELOW REQUIRED VALUES.”

S-001: Concrete Notes: Note 10 is clarified to state:

“COLD WEATHER CONCRETING SHALL BE IN ACCORDANCE WITH ACI-306. UNLESS TEMPERATURE IS AT LEAST 40°F (4.4°C) AND RISING, WATER AND/OR AGGREGATE SHOULD BE HEATED SO THAT THE TEMPERATURE OF THE CONCRETE, WHEN PLACED, IS NOT LESS THAN 55°F (13°C). PROVISION SHOULD BE MADE FOR MAINTAINING THE CONCRETE MOIST AND AT A MINIMUM TEMPERATURE OF NOT LESS THAN 50°F (10°C) FOR A PERIOD OF AT LEAST 7 DAYS.”

The bid due date remains 2:00 pm on February 4, 2021

**** End of Addendum ****

IFB-6570 - ADDENDUM NO. 1 – ACKNOWLEDGEMENT

(Please submit acknowledgement with your bid)

Legal Name of Bidding Firm: _____

Address: _____

Bidder's Representative: _____ **Title:** _____

E-mail: _____ **Fax:** _____ **Date:** _____

Signature: _____ **Telephone:** _____



City of Yonkers/Yonkers Public Schools
One Larkin Center – 3rd Floor
Yonkers, New York 10701
(914) 377-6036
Fax: (914) 377-6032
Email: kimberly.sansevere@yonkersny.gov

CITY OF YONKERS/YONKERS PUBLIC SCHOOLS
Purchasing

Mike Spano, Mayor
Tom Collich, Director

2 Pages

January 15, 2021

TO: PROSPECTIVE BIDDERS
FROM: KIM SANSEVERE, PRINCIPAL BUYER
Re: IFB-6570 –HVAC UPGRADES AT SAUNDERS TRADES & TECHNICAL HIGH SCHOOL

ADDENDUM NO. 1

The contents of this addendum alter and amend the original bid requirements and take precedence over the related items therein. This addendum forms a part of the contract documents. Bidders must acknowledge receipt of all addenda when submitting their bids. Failure to acknowledge receipt may render your bid as non-responsive and ineligible for award. Vendors are responsible for ensuring that they receive all addenda.

The following changes are made to the issued bid drawings:

- **FA-001: Fire Alarm Notes, Note 1 is revised to state:**
“ELECTRICAL CONTRACTOR SHALL INCLUDE IN HIS BASE BID ALL FIRE ALARM RELATED WORK TO BE PERFORMED BY FIRE ALARM SUB-CONTRACTOR PER THE SCOPE OF WORK CONTAINED ON THESE DRAWINGS IN CONNECTION WITH THE FIRE ALARM SYSTEM. THESE DRAWINGS ARE PROVIDED FOR BID PURPOSES ONLY AND TO ILLUSTRATE THE SCOPE OF WORK INTENT OF THIS PROJECT. PRIOR TO SUBMISSION OF THE BID, THE CONTRACTOR IS RESPONSIBLE TO REVIEW ALL DRAWINGS (I.E., MECHANICAL/HVAC, ELECTRICAL, PLUMBING, FIRE SPRINKLER, AND ARCHITECTURAL). UPON SUBMISSION OF THE BID, THE ELECTRICAL CONTRACTOR CERTIFIES THAT ALL DRAWINGS HAVE BEEN REVIEWED, THE SITE HAS BEEN VISITED/INSPECTED (IF APPLICABLE), AND THAT ALL LOCAL FIRE MARSHALL REQUIRED ITEMS ARE FULLY UNDERSTOOD AND INCLUDED IN THE BID PRICE (NO CHANGE ORDERS ALLOWED).”

- FA-001: Fire Alarm Notes, Note 3 is revised to state:**
“ELECTRICAL CONTRACTOR MUST SUBMIT TO THE ENGINEER & OWNER FINAL (AS APPROVED BY THE LOCAL BLDG. DEPT. & FIRE MARSHALL) SIGNED AND SEALED (BY ANY LICENSED PE) DESIGN/BUILD DRAWINGS INCLUDING: FIRE ALARM RISER DIAGRAM, LAYOUT, EQUIPMENT LIST & SPECIFICATIONS PRIOR TO START OF INSTALLATION. THE COST OF THE ENGINEERING FEE, PROGRAMMING CHARGE, NEW EQUIPMENT, CONNECTION & TESTING, TROUBLE SHOOTING OF SYSTEM, ATTENDANCE AT THE FIRE ALARM INSPECTION, ETC. ARE TO BE PART OF THE BASE BID. INSTALLATION OF THE NEW FIRE ALARM SYSTEM CAN BEGIN UPON WRITTEN APPROVAL FROM THE ENGINEER.”

- S-001: Structural Steel Notes: Note 10 is clarified to state:**
“ENDS OF BEAMS AND WEBS SHALL BE REINFORCED WHERE CUTS OR COPIES REDUCE STRENGTH BELOW REQUIRED VALUES.”

S-001: Concrete Notes: Note 10 is clarified to state:

“COLD WEATHER CONCRETING SHALL BE IN ACCORDANCE WITH ACI-306. UNLESS TEMPERATURE IS AT LEAST 40°F (4.4°C) AND RISING, WATER AND/OR AGGREGATE SHOULD BE HEATED SO THAT THE TEMPERATURE OF THE CONCRETE, WHEN PLACED, IS NOT LESS THAN 55°F (13°C). PROVISION SHOULD BE MADE FOR MAINTAINING THE CONCRETE MOIST AND AT A MINIMUM TEMPERATURE OF NOT LESS THAN 50°F (10°C) FOR A PERIOD OF AT LEAST 7 DAYS.”

The bid due date remains 2:00 pm on February 4, 2021

**** End of Addendum ****

IFB-6570 - ADDENDUM NO. 1 – ACKNOWLEDGEMENT

(Please submit acknowledgement with your bid)

Legal Name of Bidding Firm: _____

Address: _____

Bidder's Representative: _____ **Title:** _____

E-mail: _____ **Fax:** _____ **Date:** _____

Signature: _____ **Telephone:** _____



City of Yonkers/Yonkers Public Schools
One Larkin Center – 3rd Floor
Yonkers, New York 10701
(914) 377-6036
Fax: (914) 377-6032
Email: kimberly.sansevere@yonkersny.gov

CITY OF YONKERS/YONKERS PUBLIC SCHOOLS
Purchasing

Mike Spano, Mayor
Tom Collich, Director

2 Pages

January 15, 2021

TO: PROSPECTIVE BIDDERS
FROM: KIM SANSEVERE, PRINCIPAL BUYER
Re: IFB-6570 –HVAC UPGRADES AT SAUNDERS TRADES & TECHNICAL HIGH SCHOOL

ADDENDUM NO. 1

The contents of this addendum alter and amend the original bid requirements and take precedence over the related items therein. This addendum forms a part of the contract documents. Bidders must acknowledge receipt of all addenda when submitting their bids. Failure to acknowledge receipt may render your bid as non-responsive and ineligible for award. Vendors are responsible for ensuring that they receive all addenda.

The following changes are made to the issued bid drawings:

- **FA-001: Fire Alarm Notes, Note 1 is revised to state:**
“ELECTRICAL CONTRACTOR SHALL INCLUDE IN HIS BASE BID ALL FIRE ALARM RELATED WORK TO BE PERFORMED BY FIRE ALARM SUB-CONTRACTOR PER THE SCOPE OF WORK CONTAINED ON THESE DRAWINGS IN CONNECTION WITH THE FIRE ALARM SYSTEM. THESE DRAWINGS ARE PROVIDED FOR BID PURPOSES ONLY AND TO ILLUSTRATE THE SCOPE OF WORK INTENT OF THIS PROJECT. PRIOR TO SUBMISSION OF THE BID, THE CONTRACTOR IS RESPONSIBLE TO REVIEW ALL DRAWINGS (I.E., MECHANICAL/HVAC, ELECTRICAL, PLUMBING, FIRE SPRINKLER, AND ARCHITECTURAL). UPON SUBMISSION OF THE BID, THE ELECTRICAL CONTRACTOR CERTIFIES THAT ALL DRAWINGS HAVE BEEN REVIEWED, THE SITE HAS BEEN VISITED/INSPECTED (IF APPLICABLE), AND THAT ALL LOCAL FIRE MARSHALL REQUIRED ITEMS ARE FULLY UNDERSTOOD AND INCLUDED IN THE BID PRICE (NO CHANGE ORDERS ALLOWED).”

- FA-001: Fire Alarm Notes, Note 3 is revised to state:**
“ELECTRICAL CONTRACTOR MUST SUBMIT TO THE ENGINEER & OWNER FINAL (AS APPROVED BY THE LOCAL BLDG. DEPT. & FIRE MARSHALL) SIGNED AND SEALED (BY ANY LICENSED PE) DESIGN/BUILD DRAWINGS INCLUDING: FIRE ALARM RISER DIAGRAM, LAYOUT, EQUIPMENT LIST & SPECIFICATIONS PRIOR TO START OF INSTALLATION. THE COST OF THE ENGINEERING FEE, PROGRAMMING CHARGE, NEW EQUIPMENT, CONNECTION & TESTING, TROUBLE SHOOTING OF SYSTEM, ATTENDANCE AT THE FIRE ALARM INSPECTION, ETC. ARE TO BE PART OF THE BASE BID. INSTALLATION OF THE NEW FIRE ALARM SYSTEM CAN BEGIN UPON WRITTEN APPROVAL FROM THE ENGINEER.”

- S-001: Structural Steel Notes: Note 10 is clarified to state:**
“ENDS OF BEAMS AND WEBS SHALL BE REINFORCED WHERE CUTS OR COPIES REDUCE STRENGTH BELOW REQUIRED VALUES.”

S-001: Concrete Notes: Note 10 is clarified to state:

“COLD WEATHER CONCRETING SHALL BE IN ACCORDANCE WITH ACI-306. UNLESS TEMPERATURE IS AT LEAST 40°F (4.4°C) AND RISING, WATER AND/OR AGGREGATE SHOULD BE HEATED SO THAT THE TEMPERATURE OF THE CONCRETE, WHEN PLACED, IS NOT LESS THAN 55°F (13°C). PROVISION SHOULD BE MADE FOR MAINTAINING THE CONCRETE MOIST AND AT A MINIMUM TEMPERATURE OF NOT LESS THAN 50°F (10°C) FOR A PERIOD OF AT LEAST 7 DAYS.”

The bid due date remains 2:00 pm on February 4, 2021

**** End of Addendum ****

IFB-6570 - ADDENDUM NO. 1 – ACKNOWLEDGEMENT

(Please submit acknowledgement with your bid)

Legal Name of Bidding Firm: _____

Address: _____

Bidder's Representative: _____ **Title:** _____

E-mail: _____ **Fax:** _____ **Date:** _____

Signature: _____ **Telephone:** _____



City of Yonkers/Yonkers Public Schools
One Larkin Center – 3rd Floor
Yonkers, New York 10701
(914) 377-6036
Fax: (914) 377-6032
Email: kimberly.sansevere@yonkersny.gov

CITY OF YONKERS/YONKERS PUBLIC SCHOOLS
Purchasing

Mike Spano, Mayor
Tom Collich, Director

2 Pages

January 15, 2021

TO: PROSPECTIVE BIDDERS
FROM: KIM SANSEVERE, PRINCIPAL BUYER
Re: IFB-6570 –HVAC UPGRADES AT SAUNDERS TRADES & TECHNICAL HIGH SCHOOL

ADDENDUM NO. 1

The contents of this addendum alter and amend the original bid requirements and take precedence over the related items therein. This addendum forms a part of the contract documents. Bidders must acknowledge receipt of all addenda when submitting their bids. Failure to acknowledge receipt may render your bid as non-responsive and ineligible for award. Vendors are responsible for ensuring that they receive all addenda.

The following changes are made to the issued bid drawings:

- **FA-001: Fire Alarm Notes, Note 1 is revised to state:**
“ELECTRICAL CONTRACTOR SHALL INCLUDE IN HIS BASE BID ALL FIRE ALARM RELATED WORK TO BE PERFORMED BY FIRE ALARM SUB-CONTRACTOR PER THE SCOPE OF WORK CONTAINED ON THESE DRAWINGS IN CONNECTION WITH THE FIRE ALARM SYSTEM. THESE DRAWINGS ARE PROVIDED FOR BID PURPOSES ONLY AND TO ILLUSTRATE THE SCOPE OF WORK INTENT OF THIS PROJECT. PRIOR TO SUBMISSION OF THE BID, THE CONTRACTOR IS RESPONSIBLE TO REVIEW ALL DRAWINGS (I.E., MECHANICAL/HVAC, ELECTRICAL, PLUMBING, FIRE SPRINKLER, AND ARCHITECTURAL). UPON SUBMISSION OF THE BID, THE ELECTRICAL CONTRACTOR CERTIFIES THAT ALL DRAWINGS HAVE BEEN REVIEWED, THE SITE HAS BEEN VISITED/INSPECTED (IF APPLICABLE), AND THAT ALL LOCAL FIRE MARSHALL REQUIRED ITEMS ARE FULLY UNDERSTOOD AND INCLUDED IN THE BID PRICE (NO CHANGE ORDERS ALLOWED).”

- FA-001: Fire Alarm Notes, Note 3 is revised to state:**
“ELECTRICAL CONTRACTOR MUST SUBMIT TO THE ENGINEER & OWNER FINAL (AS APPROVED BY THE LOCAL BLDG. DEPT. & FIRE MARSHALL) SIGNED AND SEALED (BY ANY LICENSED PE) DESIGN/BUILD DRAWINGS INCLUDING: FIRE ALARM RISER DIAGRAM, LAYOUT, EQUIPMENT LIST & SPECIFICATIONS PRIOR TO START OF INSTALLATION. THE COST OF THE ENGINEERING FEE, PROGRAMMING CHARGE, NEW EQUIPMENT, CONNECTION & TESTING, TROUBLE SHOOTING OF SYSTEM, ATTENDANCE AT THE FIRE ALARM INSPECTION, ETC. ARE TO BE PART OF THE BASE BID. INSTALLATION OF THE NEW FIRE ALARM SYSTEM CAN BEGIN UPON WRITTEN APPROVAL FROM THE ENGINEER.”

- S-001: Structural Steel Notes: Note 10 is clarified to state:**
“ENDS OF BEAMS AND WEBS SHALL BE REINFORCED WHERE CUTS OR COPIES REDUCE STRENGTH BELOW REQUIRED VALUES.”

S-001: Concrete Notes: Note 10 is clarified to state:

“COLD WEATHER CONCRETING SHALL BE IN ACCORDANCE WITH ACI-306. UNLESS TEMPERATURE IS AT LEAST 40°F (4.4°C) AND RISING, WATER AND/OR AGGREGATE SHOULD BE HEATED SO THAT THE TEMPERATURE OF THE CONCRETE, WHEN PLACED, IS NOT LESS THAN 55°F (13°C). PROVISION SHOULD BE MADE FOR MAINTAINING THE CONCRETE MOIST AND AT A MINIMUM TEMPERATURE OF NOT LESS THAN 50°F (10°C) FOR A PERIOD OF AT LEAST 7 DAYS.”

The bid due date remains 2:00 pm on February 4, 2021

**** End of Addendum ****

IFB-6570 - ADDENDUM NO. 1 – ACKNOWLEDGEMENT

(Please submit acknowledgement with your bid)

Legal Name of Bidding Firm: _____

Address: _____

Bidder's Representative: _____ **Title:** _____

E-mail: _____ **Fax:** _____ **Date:** _____

Signature: _____ **Telephone:** _____