



CITY OF YONKERS

Purchasing

1 Larkin Center, 3rd Floor
Yonkers, New York 10701
(914) 377-6036

Fax: (914) 377-6032
kimberly.sansevere@YonkersNY.gov

Mike Spano, Mayor

Thomas E. Collich, Director

March 25, 2021

TO: PROSPECTIVE BIDDERS
FROM: KIM SANSEVERE, PRINCIPAL BUYER

**Re: IFB-6594: AUDITORIUM UPGRADES AND EXTERIOR BLEACHER REPLACEMENT
AT LINCOLN HIGH SCHOOL**

ADDENDUM NO. 2

The contents of this addendum alter and amend the original bid requirements and take precedence over the related items therein. This addendum forms a part of the contract documents. Bidders must acknowledge receipt of all addenda when submitting their bids. Failure to acknowledge receipt may render your bid as non-responsive and ineligible for award. Vendors are responsible for ensuring that they receive all addenda.

ADDITIONS/CLARIFICATIONS TO THE BID DOCUMENT:

DRAWING E601 – ELECTRICAL SCHEDULES

Lighting Fixture Schedule **ADD** Fixture Type 'L' Luminaire LED APX13-15W-3500K-120/277-DIM-FL-WHT-DIM-EMB310.

CITY RESPONDS TO VENDOR QUESTIONS:

1. Drawing E201 provide Light Fixture information for Type 'L' EM located at exit doors both sides of auditorium.

Answer: Fixture Type 'L' Luminaire LED APX13-15W-3500K-120/277-DIM-FL-WHT-DIM-EMB310

2. Will Contract #2 General Construction be responsible for providing scaffolding within the Auditorium seating areas for all trades to access ceiling?

Answer: No, each contractor responsible for their own access to the ceiling

3. Is all work involved in Building Automation system (BAS), is a part of HVAC work / HVAC bid ?

Answer: Yes

If so, please confirm whether we are integrating all new HVAC controls to the existing BMS system in the school.

Answer: Yes

4. Projector Screen and controls are furnished and installed under which Contract?

Answer: Projector screen and all associated items are provided and installed by General Construction Contract (see WS20). Wiring by E-contract.

5. Confirm the Auditorium Sound System is existing to remain and that new microphones are terminated to existing Auditorium System equipment.

Answer: Yes

6. Project Mount Detail #9 Drawing A501 steel support is furnished and installed under which Contract?

Answer: General Construction.

NO FURTHER QUESTIONS WILL BE ACCEPTED

The bid due date remains to 2:00 pm on April 2, 2021

IFB-6594 ADDENDUM 2 ACKNOWLEDGEMENT

Acknowledgements must be submitted with your bid

Bidding Firm: _____

Address: _____

Bidder's Representative: _____ Title: _____

Signature: _____ Date: _____

Email: _____ Phone: _____