

ADDENDUM 04

BID ADDENDUM NUMBER | 04

PROJECT NUMBER | 1910404.00

Date | 11/23/2021

OFFICE ADDRESS | KSQ DESIGN

PROJECT | Yorktown Central School District
District Wide Improvements 2020 Phase II

215 W 40th Street, 15th Floor
New York, NY 10018
914.682.3700

NOTICE TO CONTRACTORS |

This Addendum issued prior to receipt of Bid shall and does hereby become a part of the Construction Documents for the above project.

All principal Contractors shall be responsible for seeing that their Subcontractors are properly apprised of the Contents of this Addendum.

All information contained in this Addendum shall supersede and shall take precedence over any conflicting information in the original Bidding Documents dated 10/25/2021 and all pervious addenda.

All Contractors shall acknowledge receipt of this Addendum in the space provided in the Proposal Form. Failure to do so may subject Bidder to disqualification.

A. CHANGES TO SPECIFICATIONS

NONE

B. CHANGES TO DRAWINGS

Drawing YHS-E104:

- a. Revise drawing to DELETE Keyed Note '1'. Breaker is existing.

C. CLARIFICATIONS:

1. RFI Question: In reviewing Addendum No. 3 Clarification response #1 stated that Panel PP-HSAC is an existing panel which has an existing 250 amp, 3 pole spare circuit breaker to be utilized for new RTU-3 in the cafeteria. With this in mind I assume on attached Drawing No. YHS-E104 Key Note #1 should be removed as it is existing.
 - a. **Note #1 is an oversight. The panel is existing, and all notes pertaining to the installation of the panel shall be removed.**

D. ENCLOSURES:

NONE

END OF ADDENDA 04