



Corporate Office

1063 Route 22 East
Mountainside, NJ 07092
tel: 908.873.0022
fax: 908.873.0023

Atlanta Office

1200 Abbey Court
Alpharetta, GA 30004
tel: 706.216.5267
fax: 770.674.5763
license: GCC0004211

Charlotte Office

13504-J South Point Blvd
Charlotte, NC 28273
tel: 704.504.0200
fax: 704.504.0079
license: 72447

DC Metro Office

1655 North Fort Myer Drive
Suite 702
Arlington, VA 22209
tel: 908.873.0022
fax: 908.873.0023

Orlando Office

1401 Sligh Boulevard
Orlando, FL 32806
tel: 407.286.2428
fax: 407.930.5793
license: CGC1521021

South Florida Office

6555 Powerline Road
Suite 108
Fort Lauderdale, FL 33309
tel: 954.533.0895
fax: 954.533.5227
license: CGC1521021

FIDELITY INVESTMENTS - NANUET RFI RESPONSES

- Door Schedule:

- Confirm opening 136B is a pair of FR1 doors

Yes, that is correct

- Office 134 has a door tag of 180, not shown on schedule

Match door 105

- Transaction office 102 has a door tag of FR3, but only (1) sidelight is pictured

It should have (2) sidelights

- Door 137 shows hardware set 4, set 4 not listed in schedule.

It should be 03