

BID
ADDENDUM NO. 5
TO
CONTRACT DOCUMENTS
AND
TECHNICAL SPECIFICATIONS
FOR
2019 BOND REFERENDUM
CAPITAL IMPROVEMENTS
AT
MAMARONECK HIGH SCHOOL
PHASE 2
NYSED #66-07-01-03-0-001-039
BID # 20/21 – MUFSD-00

Mamaroneck Union Free School District
1000 West Boston Post Road
Mamaroneck, NY 10543

Telephone No. 914-220-3040

Contact: Ms. Sylvia Wallach
Assistant Superintendent for Business

LAN Job #4.1092.72.06
January 17, 2022

Michael J. McGovern, RA
NYS #022257

1.0 General: The original contract documents dated **November 22, 2021**, issued to the New York State Education Department (NYSED) for this project, are hereby amended as noted in this NYSED addendum which shall become part of said contract documents, as if originally included therein. Bidders must acknowledge receipt of this NYSED addendum and all other addenda on the proposal form when submitting proposals. In case any bidder fails to acknowledge receipt of addenda, his proposal will nevertheless be construed as though it has been received, acknowledged, and the submission of his proposal shall constitute acknowledgment by the bidder of the receipt of same.

This is to advise all prospective bidders that this addendum has been issued to all bidders and that it contains a change in the contract documents.

Sealed bid proposals shall be received by **2:00 p.m. prevailing time on Wednesday, January 19, 2022**, by mail or in person at the Boston Post Road main entrance, at the Mamaroneck Union Free School District Office, 1000 West Boston Post Road, NY 10543. All bids must be received by 2:00 p.m. prevailing time at which time they shall be publicly opened and read aloud at 3:00 p.m. prevailing time. **Staff will be available to accept hand delivered bids between the hours of 8:00 a.m. and 2:00 p.m. on January 19, 2022. Please be advised that masks are mandatory, and all attendees will be required to socially distance during the bid opening.**

2.0 Amendments to Specifications:

Section No.	Page No.	Addendum Requirements
01 12 00		<p>Milestone schedule for the Chiller Replacement Scope of work has been revised due to chiller availability and the need of the existing chillers for the Summer 2022 cooling season.</p> <p>[01 12 00 Pg. 5 of 28 – IV. Construction Milestones KEY MILESTONE DATES:</p> <p>CHILLER REPLACEMENTS (Post Building)</p> <ul style="list-style-type: none"> • Chillers must remain in operation up to 10/1/22 • Completion: No later than 10/31/22 <p>[01 12 00 Pg. 5 of 28 – IV. Construction Milestones “Mamaroneck High School”] PH-2 MHS Capital Improvement Bond Project Bid Schedule. This schedule issued as part of Addendum #1 shall be updated. Activity ID’s associated with the chiller work shall be adjusted per the new milestone dates above.</p>

3.0 Amendments to Drawings:

Drawing No.	Addendum Requirements
M1.81	<p>Add note to drawing as follows: MC TO TEMPORARILY SUPPORT ALL EXISTING CONDUIT ATTACHED TO THE EXISTING BREECHING TO BE REMOVED UNTIL THE EC CAN PERMANENTLY SUPPORT.</p> <p>This drawing is not being reissued.</p>

3.0 Amendments to Drawings: (Cont.)

Drawing
No.

Addendum Requirements

E2.80

Add note to drawing as follows:

EC TO PERMANENTLY SUPPORT EXISTING CONDUIT
PREVIOUSLY SUPPORTED BY THE BREECHING THAT WAS
REMOVED BY THE MC. EXTEND SUPPORTS TO CONCRETE
DECK ABOVE (APPROX. 6-7 FEET TO DECK FROM BOTTOM
OF EXISTING BREECHING).

This drawing is not being reissued.

4.0 Requests for Information (RFIs):

No. Question / Response

N/A

5.0 Clarifications:

No.

N/A

6.0 Substitution Requests:

Specification
Section No.

N/A

END OF ADDENDUM NO. 5