

RFI



482 Norristown Road, Suite 200
Blue Bell, PA 19422
610.834.7805
Kimmel-Bogrette.com

Project Name: MSMC – Guzman Hall

RFI #: 2

Date: 9.23.2021

Company: Mid Hudson Construction Management

Name: Kyle Cuomo

Question:

Please confirm the floor finish for the new stair treads. 1/A7.1 calls for “tile.” Is that ceramic tile or resilient tile?

Answer:

CT-1 is the tile, see finish schedule.

Answered by:

Laura Gamble, AIA of Kimmel-Bogrette