

- 233 East Main Street
Middletown, NY 10940
Phone: (845) 344-5863
Fax: (845) 956-5865
- 19 Waywayup Lane
Port Jervis, NY 12771
Phone: (845) 956-5866

ADDENDUM NO. 2
ADA BATHROOM – ITB-OCCC-2022-14
Our File No. OCCC-161
Orange County Community College
Middletown, New York

Bid date: April 14, 2022

Bid time: 2:00 P.M.

This addendum is made part of the referenced plans and specifications.

Please sign to acknowledge receipt of this addendum and fax or email it back to this office (845) 956-5865, jmh@fuscoengineering.com receipt of this addendum must be acknowledged on the Bid Document.

Note: Failure to acknowledge receipt of addendum may result in disqualification of the bid.

The enclosed material represents Addendum #2 for the ADA Bathroom Project at SUNY Orange - Orange County Community College.

CLARIFICATION:

1. Question: We have a question on the tile work. All bathroom floors are to have new tiles and all bathroom walls are to receive tiles from floor to ceiling, correct?

Answer: In the George Shepard Building there are three (3) bathrooms that will receive new tile on the floors and on the walls eight (8) feet from the finished floor to the new ceiling grid.

In the Bio-Tech Building the bathroom on the first floor and the bathroom on the third floor will receive new tile on the floors and on the walls eight (8) feet from the finished floor to the new ceiling grid.

Receipt of Addendum No.2 for the ADA Bathroom project acknowledged:

PRINT COMPANY NAME

DATE

SIGNATURE