| | MECHANICAL SYMBOLS - GENERAL | | |
|-------------|---|--|--|
| | NEW PIPING, DUCTWORK, OR EQUIPMENT | | |
| | NEW EQUIPMENT | | |
| | CONTINUATION FOR DUCTWORK OR PIPING | | |
| AHU 3-2 | TYPE OF EQUIPMENT (AIR HANDLING UNIT) -UNIT NUMBER (2ND AIR HANDLER ON THE 3RD FLOOR) | | |
| # > | DRAWING NOTE TAG | | |
| \triangle | REVISION SYMBOL | | |
| T | THERMOSTAT OR TEMPERATURE SENSOR TO BE WALL OR DUCT MOUNTED. REFER TO PLANS FOR LOCATION. | | |
| | THERMOSTAT/SENSOR WIRING FROM SENSING DEVICE TO CONTROLLED DEVICE | | |
| | | | |

| MECHANICAL SYMBOLS - DUCTWORK | | | |
|--|----------|--|--|
| 18X12 | 18X12 | DUCT SIZE (FIRST FIGURE INDICATES HORIZONTAL SIZE) | |
| , 18ø | 7 180 7 | ROUND DUCT DIAMETER | |
| | | SUPPLY DUCT UP | |
| × | × | SUPPLY DUCT DOWN | |
| | | RETURN OR EXHAUST DUCT UP | |
| | | RETURN OR EXHAUST DUCT DOWN | |
| <u> </u> | <u> </u> | ACOUSTICAL LINING IN DUCT | |
| → | | TRANSITION FROM RECTANGULAR TO ROUND OR OVAL DUCT | |
| Ş—AD | E2 4 | ACCESS DOOR IN DUCT | |
| <u> </u> | | MITERED ELBOW WITH TURNING VANES | |
| | A | RADIUS ELBOW (INNER RADIUS = WIDTH) | |
| \\ | | DUCT SPLIT | |
| <u> </u> | | 90° BRANCH TAP (USE 45° BOOT, OR CONICAL TAP FOR BRANCH SERVING A SINGLE DIFFUSER/REGISTER ONLY) | |
| \(\) | | 45° BRANCH TAP | |
| <u> </u> | | SPLIT (SUPPLY) OR CONVERGENCE (RETURN/EXHAUST) RADIUS ELBOW TYPE | |
| <u> </u> | | SPLIT (SUPPLY) OR CONVERGENCE (RETURN/EXHAUST) MITERED ELBOW TYPE WITH TURNING VANES | |
| ├ | | SPLIT (SUPPLY) OR CONVERGENCE (RETURN/EXHAUST) BULLHEAD TYPE | |
| 5 | | OFFSET (WITH RADIUS ELBOWS) | |
| ├ | — | SUPPLY REGISTER | |
| ├ | 1 | RETURN OR EXHAUST REGISTER | |
| Ş L _{VD} | I VD | VOLUME DAMPER | |
| \ | FD | FIRE DAMPER W/DUCT ACCESS DOOR (FD/AD) | |
| Ş → M | M | MOTORIZED DAMPER W/DUCT ACCESS DOOR | |
| | VD | BRANCH TAKEOFF TO CEILING DIFFUSER/REGISTER | |

| MECHAI | NICAL SYMBOLS - DUCTWORK (CONTINUED) |
|------------------------|---|
| | SUPPLY CEILING DIFFUSER (4-WAY BLOW) |
| - ∑ - | SUPPLY CEILING DIFFUSER (3-WAY BLOW) |
| — | SUPPLY CEILING DIFFUSER (2-WAY BLOW) |
| ¥ | SUPPLY CEILING DIFFUSER (1-WAY BLOW) |
| CD-B(500) | DIFFUSER TYPE AND CFM (CUBIC FEET PER MINUTE). REFER TO SCHEDULE. |
| | RETURN CEILING GRILLE OR REGISTER |
| H C | COIL HC=HEATING COIL CC=COOLING COIL COIL PHC=PREHEAT COIL |
| SQ.FT. | TRANSFER GRILLES ON BOTH SIDES OF WALL/PARTITION AND SQ. FT. OPENING SIZE |
| ▼ SQ.FT. | TRANSFER OPENING IN WALL/PARTITION AND SQ. FT. OPENING SIZE |
| | FAN (RISER) |
| | CEILING MOUNTED INLINE EXHAUST FAN (WITH FLEX CONNECTION AT INLET & OUTLET) |

NEW YORK STATE CODES & STANDARDS

- 2020 BUILDING CODE OF NEW YORK STATE
 2018 INTERNATIONAL BUILDING CODE WITH AMENDMENTS
 3018 INTERNATIONAL BUILDING CODE WITH AMENDMENTS
- 2018 INTERNATIONAL PLUMBING CODE WITH AMENDMENTS
 2018 INTERNATIONAL MECHANICAL CODE WITH AMENDMENTS
 2018 INTERNATIONAL FUEL GAS CODE WITH AMENDMENTS
 2018 INTERNATIONAL FIRE CODE WITH AMENDMENTS
- 2017 NATIONAL ELECTRICAL CODE (NFPA-70)
 LOCAL FIRE DEPARTMENT/FIRE MARSHAL
 ALL OTHER LOCAL AUTHORITIES HAVING JURISDICTION

NEW YORK STATE ENERGY CODES

• 2018 INTERNATIONAL ENERGY CONSERVATION CODE WITH AMENDMENTS

REFERENCE STANDARDS

APPLICABLE REFERENCE STANDARDS SHALL BE AS REFERENCED BY ALL STATE AND LOCAL CODES. THE LIST BELOW IS FOR QUICK REFERENCE AND DOES NOT INCLUDE ALL APPLICABLE REFERENCE STANDARDS.


- 2016 NFPA 13 STANDARD FOR THE INSTALLATION OF SPRINKLER SYSTEMS
 2016 NFPA 14 STANDARD FOR THE INSTALLATION OF STANDPIPE AND HOSE SYSTEMS
- 2016 NFPA 14 STANDARD FOR THE INSTALLATION OF STANDPIPE AND HOSE SYSTEMS
 2016 NFPA 20 STANDARD FOR THE INSTALLATION OF STATIONARY PUMPS FOR FIRE PROTECTION
- 2017 NFPA 70 NATIONAL ELECTRICAL CODE
 2016 NFPA 72 NATIONAL FIRE ALARM AND SIGNALING CODE
- 2018 NFPA 101- LIFE SAFETY CODE
 2018 NFPA 30A- CODE FOR MOTOR FUEL DISPENSING FACILITIES AND REPAIR GARAGES

| | MECHANICAL | DRAWING | LIST |
|-------|------------|---------|------|
| SHFFT | TITI F | | |

| SHEET NUMBER | SHEET TITLE |
|--------------|---|
| M-001 | COVER PAGE |
| M-002 | GENERAL NOTES |
| MD-100 | TRAVERSE AVENUE BOILER ROOM DEMOLITION PLAN |
| M-100 | TRAVERSE AVENUE BOILER ROOM PLAN |
| M-201 | DETAILS |
| M-301 | SPECIFICATIONS |

| ├ | > | DIRECTION OF FLOW IN PIPE |
|-------------------------|------------------------|---|
| — | § 3 | PITCH PIPE DOWN IN DIRECTION OF ARROW |
| ├ | | ELBOW TURNED UP |
| ←→ | | ELBOW TURNED DOWN |
| $\overline{\downarrow}$ | | BOTTOM PIPE CONNECTION |
| ≥ — | | TOP PIPE CONNECTION |
| ├ | | FLEXIBLE CONNECTION |
| ⊱—— } | | BALL VALVE |
| ├ | | GATE VALVE |
| ≥ | | GLOBE VALVE |
| ├ | | CHECK VALVE (ARROW INDICATES FLOW DIRECTION) |
| | | AUTOMATIC THREE-WAY CONTROL VALVE |
| ├ | | AUTOMATIC TWO-WAY CONTROL VALVE |
| ├ | | PRESSURE REDUCING VALVE |
| . | EXT | PLUG VALVE |
| | | SOLENOID VALVE |
| ·\[\ | | BUTTERFLY VALVE (MANUAL) |
| ₹ | | BUTTERFLY VALVE (MOTORIZED) |
| ├ | E[\(\)[] | CIRCUIT SETTER/BALANCING VALVE |
| ├ | £ | PIPE GUIDE |
| ├ | | EXPANSION JOINT |
| \ | | CONCENTRIC REDUCER (ARROW INDICATES FLOW DIRECTION) |
| — | | ECCENTRIC REDUCER (ARROW INDICATES FLOW DIRECTION) |
| · | | UNION |
| ├ | | CAPPED PIPE |
| ├ | | VALVED AND CAPPED CONNECTION (GATE) |
| ├ | | VALVED AND CAPPED CONNECTION (BALL) |
| \ | | "Y" TYPE STRAINER WITH BLOW DOWN VALVE |
| ├ | | BASKET TYPE STRAINER |
| ≥181 | 181 3 | DUPLEX STRAINER |
| <u></u> —— —— | | PIPE SLEEVE |
| '€> | VALVE IN VERTICAL PIPE | |

| ACU | AIR CONDITIONING UNIT |
|-----------|---|
| AD | ACCESS DOOR |
| AHU | AIR HANDLING UNIT |
| ATC | AUTOMATIC TEMPERATURE CONTROL |
| B(500) | DIFFUSER TYPE - REFER TO SCHEDULE |
| BMS | BUILDING MANAGEMENT SYSTEM |
| BTU | BRITISH THERMAL UNIT |
| CC | COOLING COIL |
| CFM | CUBIC FEET PER MINUTE |
| CG | CEILING GRILLE |
| CHWP | CHILLED WATER PUMP |
| CP | CONDENSATE PUMP |
| CR | CEILING REGISTER |
| CUH | CABINET UNIT HEATER |
| CV | CONSTANT VOLUME |
| CWP | CONDENSER WATER PUMP |
| DC DX | DRY COOLER DIRECT EXPANSION |
| | |
| E EAT | EXISTING ENTERING AIR TEMPERATURE |
| EF EF | EXHAUST FAN |
| EG | EXHAUST FAIN EXHAUST GRILLE |
| ER | EXISTING EQUIPMENT TO REMOVED |
| ERR | EXISTING EQUIPMENT TO REMOVED AND RELOCATED |
| EWT | ENTER WATER TEMPERATURE |
| FXC | FLEXIBLE CONNECTION |
| FC | FAN COIL |
| FD | FIRE DAMPER WITH ACCESS DOOR |
| FLA | FULL LOAD AMPS |
| FPI | FIN PER INCH |
| FTR | FIN TUBE RADIATION |
| GPM | GALLONS PER MINUTE |
| GX | GENERAL EXHAUST |
| HWP | HOT WATER PUMP |
| HX | HEAT EXCHANGER |
| HZ | HERTZ |
| IU | INDUCTION UNIT |
| KW | KILOWATT |
| KX | KITCHEN EXHAUST |
| LAT | LEAVING AIR TEMPERATURE |
| МВН | THOUSAND BTU PER HOUR |
| MCA | MINIMUM CIRCUIT AMPS |
| MD | MOTORIZED DAMPER |
| NC | NORMALLY CLOSED |
| NIC | NOT IN CONTRACT |
| NK | NECK SIZE |
| NO NTS | NORMALLY OPEN NOT TO SCALE |
| OAI | OUTSIDE AIR INTAKE |
| OED | OPEN END DUCT |
| PPH | POUNDS PER HOUR |
| PH | PHASE |
| PSI | POUND PER SQUARE INCH |
| PSIA | POUNDS PER SQUARE INCH ABSOLUTE |
| PSIG | POUNDS PER SQUARE INCH GAUGE |
| RE | RELOCATED POSITION OF EXISTING EQUIPMENT |
| RF | RETURN FAN |
| SD | SMOKE DETECTOR |
| TD | TRANSFER DUCT |
| TAO | TRANSFER AIR OPENING |
| TR | TOP REGISTER |
| TX | TOILET EXHAUST |
| TYP | TYPICAL |
| VN | VENT |
| V | VOLTS |
| VAV | VARIABLE AIR VOLUME |
| VD | VOLUME DAMPER |
| VFD | VARIABLE FREQUENCY DRIVE |
| WMS | WIRE MESH SCREEN |



ARCHITECTURE FACILITY PLANNING INTERIORS

ARCHITECTURE FACILITY PLANNING INTERIORS

THIS DRAWING IS THE PROPERTY OF THE ENGINEER. IT HAS BEEN SPECIFICALLY PREPARED FOR THE OWNER FOR THIS SITE AND IS NOT TO BE USED FOR ANY OTHER PURPOSE, LOCATION OR OWNER WITHOUT WRITTEN CONSENT OF THE ENGINEER.



PORT CHESTER HOUSING AUTHORITY BOILER REPLACEMENT
45 TRAVERSE AVENUE, PORT CHESTER,

Job Number:

Job Start Date: 6/13/22

| Issue: | Date: |
|----------------|---------|
| REVIEW | 6/16/22 |
| PERMIT | 7/15/22 |
| ISSUED FOR BID | 9/1/22 |
| | |
| | |

Drawn By: Checked By D.M.D. J.E.Q.

Sheet Title:

COVER PAGE

Scale:

Sheet Number: M-001