

MECHANICAL GENERAL NOTES

1. THESE DRAWINGS ARE GENERALLY DIAGRAMMATIC AND ARE INTENDED TO CONVEY THE SCOPE OF WORK AS WELL AS INDICATE GENERAL ARRANGEMENT OF EQUIPMENT, DUCTWORK AND PIPING. THE CONTRACTOR SHALL ADHERE TO THESE DRAWINGS AS CLOSELY AS POSSIBLE. HOWEVER, THE RIGHT IS RESERVED TO VARY THE RUNS OF DUCTWORK AND PIPING AND TO MAKE OFFSETS, WHERE NECESSARY, TO ACCOMMODATE CONDITIONS ARISING AT THE JOB SITE. THE CONTRACTOR SHALL PREPARE SHOP DRAWINGS TO BE SUBMITTED TO THE ENGINEER FOR APPROVAL. NO WORK SHALL BE PERFORMED PRIOR TO RECEIPT OF EQUIPMENT, DUCTWORK, AND PIPING FABRICATION SHOP DRAWING APPROVAL.
2. THE DRAWINGS AND SPECIFICATIONS SHALL BE INTERPRETED SO AS TO REQUIRE THE MOST SUBSTANTIAL AND COMPREHENSIVE PERFORMANCE OF THE WORK, CONSISTENT WITH THE INTENT AND REQUIREMENTS OF THE CONTRACT DOCUMENTS, AND SUCH WORK SHALL BE PERFORMED BY THE CONTRACTOR WITHOUT EXTRA COST TO THE OWNER. IN THE CASE OF A DISCREPANCY WITHIN THE CONTRACT DOCUMENTS, THE WORST CASE OR HIGHEST COST SHALL APPLY FOR BIDDING PURPOSES. THE CONTRACTOR SHALL NOTIFY THE ENGINEER OF ANY DISCREPANCY VIA RFI PRIOR TO PERFORMING THE ASSOCIATED WORK.
3. ANY MATERIAL, WORK, OR INCIDENTAL ACCESSORIES OR MINOR DETAILS NOT SHOWN BUT NECESSARY TO MAKE THE WORK COMPLETE IN ALL RESPECTS AND READY FOR OPERATION, EVEN IF NOT PARTICULARLY SHOWN ON THE DRAWINGS, SHALL BE PROVIDED BY THE CONTRACTOR WITHOUT ADDITIONAL EXPENSE TO THE OWNER.
4. DUCT SIZES SHOWN ON DRAWINGS ARE CLEAR INSIDE DIMENSIONS. WHERE ACOUSTICALLY LINED DUCT IS SPECIFIED, OUTER DUCT DIMENSIONS SHALL BE INCREASED TO ACCOMMODATE LINING.
5. WHERE WORK IS INDICATED TO BE BY OTHER CONTRACTORS, FOR EXAMPLE: "BY GENERAL CONSTRUCTION CONTRACTOR", THIS WORK IS NOT IN THE HVAC/MECHANICAL CONTRACT. EACH CONTRACTOR WILL BE RESPONSIBLE FOR CLOSE COORDINATION WITH OTHER CONTRACTORS' WORK.
6. REFER TO APPROPRIATE SPECIFICATION SECTION FOR EQUIPMENT SELECTION PARAMETERS WHERE DRAWINGS DO NOT CONTAIN EQUIPMENT SCHEDULES.
7. FOR AIR SYSTEMS, THE MECHANICAL CONTRACTOR SHALL INCLUDE IN BID PRICING SUPPLYING AND INSTALLING BRANCH VOLUME DAMPERS FOR ALL SUPPLY, RETURN, AND EXHAUST BRANCH DUCTWORK, REGARDLESS IF VOLUME DAMPERS ARE NOT SHOWN IN CONTRACT DOCUMENTS. ALL VOLUME DAMPERS SHALL BE ADJUSTABLE HANDLE TYPE FOR LAY-IN ACCESSIBLE CEILING OR CABLE OPERATED FOR CONCEALED TYPE OF CEILING. ALL BRANCH DUCT VOLUME DAMPERS SERVING DIFFUSERS IN GYPSUM BOARD CEILINGS (OR OTHERWISE INACCESSIBLE) SHALL BE REMOTELY (CORD OR CABLE) OPERABLE THROUGH THE FACE OF THE DIFFUSER.
8. INSTALL THERMOSTATS, FAN SPEED CONTROLLERS, AND OTHER ROOM OCCUPANT ADJUSTABLE CONTROL DEVICES 4'-0" ABOVE FINISHED FLOOR OR AS DIRECTED OTHERWISE BY ARCHITECT. COORDINATE EXACT LOCATIONS WITH THE ARCHITECTURAL PLANS. DEVICE COLORS TO BE SELECTED BY THE ARCHITECT. MANUFACTURER'S LOGO SHALL NOT BE EXPOSED.
9. AC UNITS SHOWN ON DRAWINGS ARE SCHEMATIC. SEE AC UNIT DETAIL ON DETAIL SHEET FOR ACTUAL TYPICAL ARRANGEMENT REQUIRED.
10. WHERE PIPING CONNECTIONS FOR EQUIPMENT SUCH AS PUMPS, AC UNITS, COILS, ETC. DIFFER FROM THE LINE SIZE PIPING, IT SHALL BE THE RESPONSIBILITY OF THE MECHANICAL CONTRACTOR TO FURNISH AND INSTALL THE NECESSARY REDUCER/EXPANDER FITTINGS TO ENABLE CONNECTION BETWEEN THE PIPING SYSTEM AND THE EQUIPMENT.
11. SOME PRESSURE AND TEMPERATURE GAUGES ARE SCHEMATICALLY SHOWN ON THE PLANS AND DETAILS. REFER TO THE SPECIFICATIONS FOR EXACT TYPES AND LOCATIONS.
12. PROVIDE UL LISTED AND LABELED FIRE DAMPERS AT ALL DUCT PENETRATIONS THROUGH FIRE RATED WALLS AND FLOORS, REGARDLESS IF FIRE DAMPERS ARE NOT SHOWN IN CONTRACT DOCUMENTS. PROVIDE 1-1/2 HOUR RATED FIRE DAMPERS AT WALLS/FLOORS WITH 2 HOUR OR LESS RATING. PROVIDE 3 HOUR RATED FIRE DAMPERS AT WALLS/FLOORS WITH 3 HOUR OR MORE RATING. ALL FIRE DAMPERS SHALL BE TYPE "B" WITH SHUTTER OUT OF AIRSTREAM, AND SHALL BE RATED FOR DYNAMIC AIRFLOW CONDITIONS 2,000 FT/MIN AND 4.0 IN-WC. PROVIDE ACCESS DOORS IN DUCTWORK, 18"x18" UNLESS OTHERWISE NOTED. COORDINATE WITH GENERAL CONTRACTOR FOR LOCATIONS AND SIZES OF ACCESS DOORS IN GENERAL CONSTRUCTION.
13. PROVIDE UL LISTED AND LABELED COMBINATION FIRE/SMOKE DAMPERS AT ALL DUCT PENETRATIONS THROUGH FIRE AND SMOKE RATED WALLS AND FLOORS, REGARDLESS IF FIRE DAMPERS ARE NOT SHOWN IN CONTRACT DOCUMENTS. ALL COMBINATION FIRE/SMOKE DAMPERS SHALL BE PROVIDED WITH AN END SWITCH FOR STATUS SIGNAL TO THE BMS AND FIRE SMOKE CONTROL PANEL. ALL COMBINATION FIRE/SMOKE DAMPERS SHALL BE RATED FOR DYNAMIC AIRFLOW CONDITIONS 2,000 FT/MIN AND 4.0 IN-WC. PROVIDE ACCESS DOORS IN DUCTWORK, 18"x18" UNLESS OTHERWISE NOTED. COORDINATE WITH GENERAL CONTRACTOR FOR LOCATIONS AND SIZES OF ACCESS DOORS IN GENERAL CONSTRUCTION.
14. PROVIDE FIRESTOPPING FOR ALL DUCT AND PIPE PENETRATIONS THROUGH FIRE RATED PARTITIONS.
15. THE MECHANICAL CONTRACTOR SHALL INCLUDE IN BID PRICING SUPPLYING AND INSTALLING THERMOSTATS FOR ANY EQUIPMENT THAT REQUIRES CONTROL, SUCH AS VAV BOXES, FCU, FANS, HEATERS, FINNED TUBE RADIATION, RTU'S, ETC., REGARDLESS IF THERMOSTATS ARE NOT SHOWN IN CONTRACT DOCUMENTS. ALL THERMOSTATS SHALL BE DIRECT DIGITAL PROGRAMMABLE TYPE, UNLESS OTHERWISE NOTED. PROVIDE ONE THERMOSTAT FOR EACH FAN COIL UNIT, FAN UNIT, VAV, FPB, ENTRANCE HEATER, BASEBOARD RADIATION, ETC. THERMOSTAT LOCATIONS SHALL BE AS SHOWN ON PLANS AND/OR WHERE DIRECTED AND APPROVED BY THE ARCHITECT AND ENGINEER.
16. ALL DUCTWORK AND PIPING REQUIRING FIRE RATING AND WHERE SHOWN ON PLANS SHALL BE PROVIDED WITH A 2-HOUR FIRE RATED ENCLOSURE (PROVIDED UNDER ANOTHER SECTION OF THE SPECIFICATIONS).
17. ALL LINEAR DIFFUSERS ARE TO BE COORDINATED WITH ARCHITECTURAL PLANS. FOR EXACT LENGTHS AND LOCATIONS. ACTIVE PLENUM SECTIONS SHALL BE OF THE SIZES AS SHOWN ON PLANS. EACH BRANCH TAP SERVING THE LINEAR DIFFUSER SHALL BE PROVIDED WITH A VOLUME DAMPER WHICH SHALL BE OPERABLE THROUGH THE DIFFUSER FACE. ACTIVE SUPPLY SECTION OF LINEAR DIFFUSER SHALL BE PROVIDED WITH PATTERN CONTROL DEVICES AND EQUALIZING GRIDS. ACTIVE OR INACTIVE RETURN SECTIONS SHALL NOT BE

MECHANICAL GENERAL NOTES (CONTINUED)

- FURNISHED WITH PATTERN CONTROL OR EQUALIZING GRIDS.
18. BORDER TYPES AND METHOD OF ATTACHMENT FOR ALL DIFFUSERS, GRILLES, AND REGISTERS SHALL BE COORDINATED WITH THE ARCHITECTURAL CEILING DETAILS AND SPECIFICATIONS.
19. REFER TO SPECIFICATIONS FOR ACOUSTIC LINING REQUIREMENTS NOT SHOWN ON THE DRAWINGS.
20. PROVIDE ALL REQUIRED PIPE TAPPING FOR WATER TREATMENT SYSTEMS.
21. ALL HVAC WATER PIPING RUNNING ABOVE ELECTRICAL SERVICES SHALL BE PROVIDED WITH A DRAIN PAN UNDERNEATH BY THE MECHANICAL CONTRACTOR. PIPING FROM DRAIN PAN SHALL BE PROVIDED BY MECHANICAL CONTRACTOR AND EXTEND TO NEAREST FLOOR DRAIN.
22. FOR WATER SYSTEMS: THE MECHANICAL CONTRACTOR SHALL INCLUDE IN BID PRICING SUPPLYING AND INSTALLING BALL TYPE SHUT-OFF VALVES AND SEPARATE BALANCING VALVE FOR ALL BRANCH PIPING REGARDLESS IF VALVES ARE NOT SHOWN IN CONTRACT DOCUMENTS. ALL SHUT-OFF VALVES SHALL BE FULL PORT AND PRESSURE RATED FOR SYSTEM PRESSURE. THE BALANCING VALVE SHALL BE SIMILAR TO B&G CIRCUIT SETTER PLUS CALIBRATED BALANCE VALVE, UNLESS OTHERWISE NOTED.
23. THE MECHANICAL CONTRACTOR SHALL INCLUDE IN BID PRICING SUPPLYING AND INSTALLING SECONDARY DRAIN PANS FOR ALL AIR CONDITIONING CEILING HUNG EQUIPMENT REGARDLESS IF DRAIN PANS ARE NOT SHOWN IN CONTRACT DOCUMENTS. REFER TO DETAIL FOR INSTALLATION OF DRAIN PANS. IF NO DETAIL IS SHOWN, CONTRACTOR MUST REQUEST DRAIN PAN DETAIL THRU RFI PROCESS DURING BIDDING.
24. THE MECHANICAL CONTRACTOR SHALL INCLUDE IN BID PRICING SUPPLYING AND INSTALLING CONDENSATE PIPING FOR ALL COOLING TYPE EQUIPMENT REGARDLESS IF CONDENSATE PIPING IS NOT SHOWN IN CONTRACT DOCUMENTS. ALL CONDENSATE PIPING SHALL BE INSULATED AND ROUTED TO NEAREST DRAIN OR JANITORS CLOSET. IF NO CONDENSATE PIPING IS SHOWN, CONTRACTOR MUST REQUEST CONDENSATE PIPING ROUTING THRU RFI PROCESS DURING BIDDING.
25. GENERAL NOTES, SYMBOLS, ABBREVIATIONS, AND DETAILS ARE APPLICABLE TO ALL HVAC/MECHANICAL DRAWINGS.
26. RELOCATE EXISTING WORK THAT INTERFERES WITH WORK OF THIS CONTRACT.
27. COORDINATE THIS WORK WITH THAT OF OTHER TRADES.
28. DIMENSIONS SHOWN ON PLAN ARE HORIZONTAL. DIMENSIONS SHOWN IN ELEVATION ARE VERTICAL, EXCEPT IN WAY OF STRUCTURAL STEEL, DIMENSIONS ARE MEASURED PERPENDICULAR TO FLANGE.
29. PRODUCT INSTALLATION SHALL ADHERE TO MANUFACTURERS' RECOMMENDATIONS.
30. PROVIDE ACCESS PANELS IN DUCTWORK IN ACCORDANCE WITH MANUFACTURERS' RECOMMENDATIONS FOR CONCEALED EQUIPMENT THAT REQUIRES PERIODIC SERVICE, INCLUDING AIR CONDITIONING UNITS, FANS, CONDENSATE PUMPS, FIRE DAMPERS, COMBINATION FIRE/SMOKE DAMPERS, AND DUCT MOUNTED SMOKE DETECTORS. COORDINATE WITH GENERAL CONTRACTOR FOR LOCATIONS AND SIZES OF ACCESS DOORS IN GENERAL CONSTRUCTION.
31. PROVIDE HANGERS, INSERTS, ANCHORS, SUPPLEMENTAL STEEL & SUPPORTS AS REQUIRED TO SUPPORT DUCTWORK, PIPING AND EQUIPMENT FROM STRUCTURE.
32. SCHEDULE WORK OF THIS SECTION TO AVOID INTERFERING WITH EXISTING OPERATIONS IN THE FACILITY.
33. COORDINATE ALL ROOF PENETRATIONS WITH THE WORK OF OTHER SECTIONS AND WITH FLASHING REQUIREMENTS. COORDINATE ALL ROOF PENETRATION LOCATIONS WITH THE OWNER/LANDLORD. NOTIFY THE OWNER/LANDLORD PRIOR TO STARTING WORK AND VERIFY COMPLIANCE WITH BOND AND WARRANTY OF THE ROOF.
34. RUN DUCTS AND PIPING CONCEALED, UNLESS OTHERWISE SPECIFIED, AND CLEAR OF CEILING INSERTS.
35. PROVIDE CLEARANCE IN FRONT OF ALL ELECTRIC CONTROL PANELS PER N.E.C. AND EQUIPMENT MANUFACTURERS' REQUIREMENTS.
36. ALL MOTOR STARTERS FOR HVAC EQUIPMENT SHALL BE FURNISHED BY THE MECHANICAL CONTRACTOR AND INSTALLED/WIRED BY THE ELECTRICAL CONTRACTOR, UNLESS OTHERWISE NOTED.
37. ALL DISCONNECT SWITCHES FOR HVAC EQUIPMENT SHALL BE FURNISHED, INSTALLED, AND WIRED BY THE ELECTRICAL CONTRACTOR, UNLESS INTEGRAL TO HVAC EQUIPMENT OR OTHERWISE NOTED.
38. USE FLAT TRANSVERSE SEAM FOR DUCTWORK WHERE SPACE AVAILABLE DICTATES.
39. BRANCH DUCTS TO INDIVIDUAL DIFFUSERS AND REGISTERS SHALL BE THE SAME SIZE AS THE DIFFUSER OR REGISTER NECK, UNLESS OTHERWISE NOTED.
40. ALL DUCTWORK AND PIPING SHALL BE INSTALLED TIGHT TO BOTTOM OF STRUCTURAL MEMBERS UNLESS OTHERWISE NOTED OR ABSOLUTELY REQUIRED BY FIELD CONDITIONS.
41. DO NOT INSTALL DUCTWORK OR PIPING DIRECTLY UNDER AND PARALLEL TO THE WEB OF STRUCTURAL MEMBERS. OFFSET IN ORDER TO ALLOW FUTURE DUCTWORK AND PIPING TO CROSS OVER IN BETWEEN STRUCTURAL MEMBERS.
42. BRANCH DUCTS TO INDIVIDUAL DIFFUSERS AND REGISTERS SHALL BE PROVIDED WITH VOLUME DAMPERS, WHETHER OR NOT THE VOLUME DAMPERS ARE SHOWN ON PLAN.
43. VOLUME DAMPERS LOCATED ABOVE INACCESSIBLE CEILINGS SHALL BE CABLE OPERATED TYPE, WITH CABLE OPERATORS LOCATED IN ACCESSIBLE LOCATIONS AND CLEARLY LABELED FOR DIFFUSER OR REGISTER SERVED.
44. UNLESS OTHERWISE NOTED, ALL EXPOSED DUCTWORK IN FINISHED SPACES SHALL BE SPIRAL ROUND OR FLAT OVAL TYPE, WITH SOLID OUTER WALL, PERFORATED INNER WALL, AND 1 INCH THICK INTERSTITIAL ACOUSTICAL LINING.
45. CONDENSATE DRAIN (CD) AND CONDENSATE PUMP DISCHARGE (PD) PIPING SHALL BE RIGID COPPER, TYPE L, MINIMUM 3/4" NOMINAL PIPE SIZE, BRAZED OR SOLDERED, WITH 1" INSULATION, UNLESS OTHERWISE NOTED ON DRAWINGS.

MECHANICAL GENERAL NOTES (CONTINUED)

46. NEW AND EXISTING PERMANENT HVAC AIR EQUIPMENT MAY BE USED BY CONTRACTORS DURING CONSTRUCTION FOR TEMPORARY HEATING, COOLING, AND VENTILATION, ONLY UNDER THE FOLLOWING CONDITIONS:
- 46.1. CONTRACTOR TO PROVIDE TEMPORARY FILTERS IN EACH UNIT DURING CONSTRUCTION, WHICH SHALL BE REPLACED WITH NEW CLEAN FILTERS AFTER GENERAL CONSTRUCTION IS COMPLETED.
- 46.2. CONTRACTOR TO PROVIDE FILTER FABRIC AT ALL RETURN AND EXHAUST REGISTERS, GRILLES, AND OPENINGS DURING CONSTRUCTION.
- 46.3. THE WARRANTY PERIOD FOR ALL EQUIPMENT SHALL NOT BEGIN UNTIL CONSTRUCTION IS COMPLETED. IF THE EQUIPMENT MANUFACTURER'S WARRANTY PERIOD BEGINS WHILE THE UNIT USED DURING CONSTRUCTION, THE CONTRACTOR SHALL BE RESPONSIBLE FOR ALL COSTS ASSOCIATED WITH EXTENDING THE WARRANTY TO PROVIDE THE FULL PERIOD OF COVERAGE TO THE OWNER.
- 46.4. IF NEW PERMANENT HVAC AIR EQUIPMENT INSTALLED UNDER THIS PROJECT WILL NOT BE OPERATED BY THE CONTRACTOR DURING CONSTRUCTION, ALL OPEN OR INCOMPLETE DUCTWORK SHALL BE GAPPED AIRTIGHT WITH WITH HEAVY POLYETHYLENE PLASTIC. AFTER THE INSTALLATION OF DUCTWORK, REGISTERS, GRILLES, AND DIFFUSERS, THE CONTRACTOR SHALL BLANK OFF ALL REGISTERS, GRILLES, AND DIFFUSERS WITH HEAVY POLYETHYLENE PLASTIC AND TAPE AIR TIGHT, IN AREAS THAT ARE UNDER CONSTRUCTION, UNTIL WORK IS COMPLETE IN THOSE AREAS.
- 46.5. IF THE ABOVE CONDITIONS ARE NOT MET, THE CONTRACTOR SHALL BE RESPONSIBLE FOR PROVIDING ANY NECESSARY TEMPORARY HEATING, COOLING, AND VENTILATION EQUIPMENT, DUCTWORK, CONTROLS, PIPING, AND POWER AT HIS OWN EXPENSE.
- 46.6. IF PERMANENT HVAC EQUIPMENT IS USED DURING CONSTRUCTION BUT NOT PROPERLY PROTECTED AS DESCRIBED ABOVE, THE CONTRACTOR SHALL BE RESPONSIBLE FOR CLEANING OUT DUST AND DEBRIS FROM DUCTWORK AND EQUIPMENT, AS WELL AS ANY NECESSARY REPAIR OR REPLACEMENT OF DAMAGED EQUIPMENT AT HIS OWN EXPENSE.
- 46.7. WHEN GENERAL CONSTRUCTION IS COMPLETE, VACUUM CLEAN ALL DIFFUSERS, REGISTERS, GRILLES, AND HVAC EQUIPMENT IN THE PROJECT AREA OR SERVING THE PROJECT AREA. REMOVE ANY CONSTRUCTION DEBRIS.
47. THIS CONTRACTOR SHALL BE RESPONSIBLE FOR DRAINING DOWN, FLUSHING CLEAN, AND RE-FILLING THE HVAC [HOT/CHILLED/CONDENSER] WATER SYSTEM FOR THE BUILDING, TO FACILITATE MODIFICATIONS TO PIPING AND EQUIPMENT. COORDINATE AND SCHEDULE THIS WORK WITH THE OWNER. ASSUME THIS WORK WILL BE PERFORMED OUTSIDE OF BUSINESS HOURS.

MECHANICAL DEMOLITION NOTES

1. DEMOLITION NOTES, SYMBOL LIST, AND DETAILS ARE APPLICABLE TO ALL HVAC/MECHANICAL DRAWINGS.
2. ALL PIPING IN WALLS AND FLOORS NOT TO BE REUSED WILL BE PLUGGED OR CAPPED, AND CUTTING AND PATCHING WILL BE PERFORMED TO RESTORE SURFACE TO ORIGINAL CONDITION BY THIS CONTRACTOR.
3. AFTER REMOVING PIPE THROUGH THE FLOOR SLABS, PACK OPENING WITH APPROVED FIRE-RATED PACKING.
4. THE CONTRACTOR SHALL INCLUDE IN HIS PRICE ALL COSTS ASSOCIATED WITH REMOVALS AND RELOCATIONS OF HVAC WORK AS DESCRIBED ON THE DRAWINGS AND IN THE SPECIFICATIONS WITH ALLOWANCES FOR EXPECTED OR UNFORESEEN DIFFICULTIES WHEN CONCEALED WORK HAS BEEN OPENED. NO CLAIMS FOR ADDITIONAL WORK ASSOCIATED WITH DEMOLITION WILL BE ACCEPTED, EXCEPT IN CERTAIN CASES CONSIDERED JUSTIFIABLE BY THE OWNER/ENGINEER.
5. THE CONTRACTOR SHALL PERFORM DEMOLITION AND REMOVAL WORK WITH MINIMUM INTERFERENCE WITH FUNCTIONING HVAC SYSTEMS. ALL AFFECTED SYSTEMS SHALL BE RECONNECTED AND RESTORED.
6. DEMOLITION AND REMOVAL WORK SHALL BE PERFORMED IN A NEAT AND WORKMANLIKE MANNER. THE CONTRACTOR SHALL PATCH, REPAIR, OR OTHERWISE RESTORE ANY DAMAGED INTERIOR OR EXTERIOR BUILDING SURFACE TO ITS ORIGINAL CONDITION.
7. THE CONTRACTOR SHALL REMOVE ALL DUCT AND PIPING SUPPORTS, ETC. FROM PARTITIONS THAT ARE TO BE REMOVED. WHERE THE REMOVAL OF THESE ITEMS DISRUPTS EXISTING PIPING THAT IS TO REMAIN, THE CONTRACTOR SHALL INSTALL AND PROVIDE BYPASS CONNECTIONS NECESSARY.
8. ALL PIPING WHICH BECOMES EXPOSED DURING THE ALTERATION WORK SHALL BE REAVED AND REROUTED CONCEALED BEHIND FINISHED SURFACES.
9. PORTIONS OF PIPING AND DUCTWORK TO BE REMOVED OR ABANDONED AS A RESULT OF DEMOLITION WORK, BUT WHICH ARE REQUIRED TO REMAIN ACTIVE, SHALL BE CUT AT CONVENIENT LOCATIONS, REROUTED, AND RECONNECTED.
10. THE CONTRACTOR SHALL NOTIFY THE OWNER AT THE APPROPRIATE TIME OF THE PROJECTED DEMOLITION AND PHASING SCHEDULE, SO THAT REMOVAL OR RELOCATION OF AFFECTED UTILITIES MAY BE CARRIED OUT IN COORDINATION WITH THE PROJECT REQUIREMENTS.
11. ALL EXISTING MATERIAL AND EQUIPMENT IN USABLE CONDITION, WHICH IS TO BE REMOVED UNDER THIS CONTRACT, SHALL REMAIN THE PROPERTY OF THE OWNER OR SHALL BE DISPOSED OF BY THE HVAC CONTRACTOR, AS DIRECTED BY THE OWNER.
12. ARRANGE TO WORK CONTINUOUSLY, INCLUDING OVER TIME, IF REQUIRED, TO ASSURE THAT SYSTEMS WILL BE SHUT DOWN ONLY DURING THE TIME ACTUALLY REQUIRED TO MAKE THE NECESSARY CONNECTIONS TO THE EXISTING SYSTEMS.
13. THE SHUTDOWN OF EXISTING BUILDING HVAC SERVICES SHALL BE COORDINATED WITH WITH THE OWNER. MAKE ARRANGEMENTS AT LEAST FIVE (5) BUSINESS DAYS PRIOR TO A SHUTDOWN.
14. CONTRACTOR SHALL COMPLY WITH ALL FEDERAL, STATE, AND LOCAL REQUIREMENTS.
15. WHERE THE DEMOLITION OF EXISTING PNEUMATIC CONTROL EQUIPMENT, THERMOSTATS, OR TUBING IS INDICATED IN THE PLANS, THE CONTRACTOR SHALL CAP THE ENDS OF ALL EXISTING TO REMAIN PNEUMATIC LINES AIRTIGHT UNLESS OTHERWISE NOTED. IF ADDITIONAL PNEUMATIC LINES OR DEVICES ARE DISCOVERED BY THE CONTRACTOR INSIDE WALLS OR ABOVE CEILINGS DURING DEMOLITION, THE CONTRACTOR SHALL INFORM THE DESIGN TEAM PRIOR TO REMOVAL OF THESE LINES OR DEVICES.



THIS DRAWING IS THE PROPERTY OF THE ENGINEER. IT HAS BEEN SPECIFICALLY PREPARED FOR THE OWNER FOR THIS PROJECT AT THIS SITE AND IS NOT TO BE USED FOR ANY OTHER PURPOSE, LOCATION OR OWNER WITHOUT WRITTEN CONSENT OF THE ENGINEER.



PORT CHESTER HOUSING AUTHORITY -  
BOILER REPLACEMENT  
45 TRAVERSE AVENUE, PORT CHESTER,  
NY 10573

Job Number:  
-

Job Start Date:  
6/13/22

Issue:	Date:
REVIEW	6/16/22
PERMIT	7/15/22
ISSUED FOR BID	9/1/22

Drawn By: Checked By:  
D.M.D. J.E.Q.

Sheet Title:  
GENERAL NOTES

Scale:  
NTS

Sheet Number:  
M-002