

ELECTRICAL SPECIFICATIONS

26 05 00 BASIC ELECTRICAL REQUIREMENTS

PERMITS AND CODES: OBTAIN AND PAY FOR ALL NECESSARY PERMITS AND REQUIRED INSPECTIONS. COMPLY WITH ALL NATIONAL, STATE AND MUNICIPAL LAWS, CODES AND ORDINANCES RELATING TO BUILDING AND PUBLIC SAFETY. PROVIDE ANY REQUIRED TEMPORARY POWER AND UTILITIES FOR ALL TRADES AND ALL CONSTRUCTION TRAILERS. PROVIDE TEMPORARY CONSTRUCTION LIGHTING AND POWER.

VISITING THE JOB SITE: VISIT THE SITE OF THE PROPOSED CONSTRUCTION IN ORDER TO FULLY UNDERSTAND THE FACILITIES, DIFFICULTIES AND RESTRICTIONS ATTENDING THE EXECUTION OF THE WORK. NO ADDITIONAL COMPENSATION WILL BE ALLOWED THIS CONTRACTOR FOR WORK OR ITEMS OMITTED FROM HIS ORIGINAL PROPOSAL.

DRAWINGS: DRAWINGS ARE DIAGRAMMATIC, CONFIRM DIMENSIONS & LOCATIONS IN THE FIELD. IF CONFLICTING DIMENSIONS ARE SHOWN, USE LARGER DIMENSIONS AND VERIFY WITH ARCHITECT. SEE ARCHITECTURAL PLANS AND ELEVATIONS FOR EXACT LOCATION OF FIXTURES AND WALL MOUNTED DEVICES.

MATERIAL: ALL MATERIALS SHALL BE NEW AND U.L. LISTED. MATERIAL INSTALLATION SHALL COMPLY WITH NEC REQUIREMENTS AND PERFORMANCE BY CRAFTSMAN SKILLED IN THIS PARTICULAR WORK.

EQUIPMENT PROTECTION: PROTECT EQUIPMENT AND WORK FROM DAMAGE DURING HANDLING AND INSTALLATION UNTIL COMPLETION OF CONSTRUCTION.

COOPERATION WITH OTHER TRADES: COOPERATION WITH TRADES OF ADJACENT, RELATED OR AFFECTED MATERIALS OR OPERATIONS, AND WITH TRADES PERFORMING CONSTRUCTION OF THIS WORK UNDER SEQUENTIAL CONTRACTS, IS CONSIDERED A PART OF THIS WORK IN ORDER TO EFFECT TIMELY AND ACCURATE PLACING OF WORK AND TO BRING TOGETHER, IN PROPER AND CORRECT SEQUENCE, THE WORK OF SUCH TRADES.

ACCESS PANEL: PROVIDE ACCESS PANELS OR DOORS FOR ALL DEVICES REQUIRING ADJUSTMENT, SIMILARLY FOR ALL JUNCTION BOXES, PULL BOXES ETC THAT ARE REQUIRED TO BE ACCESSIBLE PER CODE AND/OR THE LOCAL AUTHORITY HAVING JURISDICTION.

PLENUMS: PLENUMS ARE CROWDED AND NOT ALL OBSTACLES ARE INDICATED. ALLOW FOR CONDUIT OFFSETS AND PULL BOXES NOT INDICATED ON DRAWINGS.

PLASTER, GYPSUM BOARD OR OTHER NON-ACCESSIBLE CEILINGS: CONTRACTOR SHALL MINIMIZE CUTTING AND PATCHING BY INSTALLING CONDUIT PRIOR TO CEILING/WALL/PARTITION COVER-UP.

LOSS OR DAMAGE TO EXISTING FACILITIES: THE CONTRACTOR SHALL BE RESPONSIBLE FOR LOSS OR DAMAGE TO THE EXISTING FACILITIES CAUSED BY HIM AND HIS WORKMEN, AND SHALL BE RESPONSIBLE FOR REPAIRING OR REPLACING SUCH LOSS OR DAMAGE. THE CONTRACTOR SHALL SEND PROPER NOTICES, MAKE NECESSARY ARRANGEMENTS, AND PERFORM OTHER SERVICES REQUIRED FOR THE CARE, PROTECTION AND IN-SERVICE MAINTENANCE OF ALL ELECTRICAL SERVICES FOR THE NEW AND EXISTING FACILITIES.

WORK IN OCCUPIED AREAS: WORK IN, ABOVE, BELOW OR NEAR OCCUPIED AREAS SHALL BE AT OWNER'S CONVENIENCE AND MAY BE DURING EVENINGS OR WEEKENDS. SCHEDULE ALL REQUIRED POWER OUTAGES A MINIMUM OF 7 DAYS IN ADVANCE WITH FACILITY ENGINEER/OWNER. DO NOT TURN OFF ANY POWER SOURCES.

ELECTRICAL SERVICE OUTAGE: SERVICE TO THE EXISTING BUILDING SHALL BE MAINTAINED DURING NORMAL WORKING HOURS. ANY SERVICE OUTAGE REQUIRED TO COMPLETE THE WORK SHALL BE THE TIME AND FOR THE LENGTH OF TIME AS DIRECTED BY THE OWNER.

FIRE STOPS AND PENETRATION SEALS: ALL PENETRATIONS THROUGH FIRE RATED FLOORS AND WALLS SHALL BE SEALED WITH 3M FIRE RESISTANT FOAM SEALANT, TO PREVENT THE SPREAD OF SMOKE, FIRE, TOXIC GAS OR WATER THROUGH THE PENETRATION EITHER BEFORE, DURING OR AFTER A FIRE.

CLEAN UP: A) PROVIDE FOR ISOLATION OF WORK AREAS AND DAILY REMOVAL OF DEBRIS. B) CLEAN ALL EQUIPMENT AND FIXTURE LENSES. C) REPLACE ALL BURNED OUT LAMPS. D) TOUCH UP WITH PAINT WHERE REQUIRED.

SUBMITTAL DATA: SUBMITTALS ARE REQUIRED BUT NOT LIMITED TO THE FOLLOWING EQUIPMENT: LIGHTING FIXTURES, SWITCHGEAR, MCCS, DISTRIBUTION PANELBOARDS, BRANCH CIRCUIT PANELBOARDS, TRANSFORMERS, SWITCHES ETC.

SHOP DRAWINGS: SHOP DRAWINGS AS REQUIRED SHALL BE PROVIDED BY THE ELECTRICAL CONTRACTOR AT NO ADDITIONAL COST TO THE ARCHITECT. THESE SHOP DRAWINGS SHALL BE PREPARED TO INDICATE INSTALLATION OF MAJOR EQUIPMENT WHERE SPECIAL COORDINATION PROBLEMS EXIST.

COMPLETE SYSTEMS: ALL SYSTEMS SHALL BE COMPLETE AND WORKING AT COMPLETION OF CONSTRUCTION.

FINAL INSPECTION & OPERATING TESTS: ALL ELECTRICAL SYSTEMS MUST BE CHECKED FOR PROPER POLARITY AND SEQUENCE. ALL MOTORS MUST BE CHECKED FOR PROPER ROTATION AND ALL EQUIPMENT (INCLUDING HVAC, ELEVATOR AND SPECIAL EQUIPMENT) CHECKED FOR PROPER VOLTAGE AND PHASING REQUIREMENTS.

GUARANTEE: GUARANTEE ALL WORK AND MATERIALS FURNISHED UNDER THIS CONTRACT FOR A PERIOD OF ONE YEAR FROM THE DATE OF ACCEPTANCE BY THE OWNER AND ARCHITECT.

RECORD DRAWINGS: MAINTAIN A CONTINUOUS DAILY RECORD DURING THE COURSE OF CONSTRUCTION OF ALL CHANGES AND DEVIATIONS IN THE WORK FROM THE ACCOMPANYING DRAWINGS. SHOW EXACT DIMENSIONS FOR ALL UNDER-SLAB CONDUIT.

26 05 73 SHORT CIRCUIT CALCULATION, PROTECTIVE DEVICE COORDINATION AND ARC FLASH STUDIES: STUDIES SHALL ENCOMPASS ELECTRICAL DISTRIBUTION SYSTEM FROM NORMAL POWER SOURCE OR SOURCES TO AND INCLUDING BRANCH BREAKERS IN EACH PANELBOARD.

ARC FLASH HAZARD ANALYSIS CALCULATION SHALL NOT BE REQUIRED FOR EQUIPMENT RATED 240 VOLTS OR LESS AND SUPPLIED BY ONE TRANSFORMER RATED LESS THAN 125 KVA.

26 05 33 CONDUIT AND BOXES: CONDUIT SHALL BE RIGID GALVANIZED STEEL (RGS) OR ELECTRICAL METALLIC TUBING (EMT) AS MANUFACTURED BY ALLED, TRIANGLE OR WHEATLAND ABOVE GRADE; EMT OR RGS

PROVIDE TRANSITION FITTINGS FROM PVC SCH 40 OR 80 TO RGS FOR ALL ABOVE GRADE CONDUIT. ALL UNDERGROUND METALLIC CONDUIT SHALL HAVE 40-MIL THICK EXTERNAL PVC COATINGS FOR CORROSION PROTECTION.

INSTALL GROUND WIRES WHERE SHOWN ON THE DRAWINGS. COMPRESSION OR SET-SCREW TYPE FITTINGS MAY BE USED FOR EMT. MINIMUM CONDUIT SIZE 1/2 INCH TYPE "MC" METAL CLAD CABLE IS ACCEPTABLE IF APPROVED BY THE LOCAL AUTHORITY.

PROJECT RECORD: DOCUMENTS ACCURATELY RECORD ACTUAL ROUTING OF ALL UNDERSLAB AND UNDERGROUND CONDUITS; INCLUDE DIMENSIONS FROM KEY BUILDING POINTS AND DEPTH OF COVER.

OUTLET BOXES: SHALL BE GALVANIZED STEEL SUITABLE FOR LOCATION. CEILING OUTLET BOXES SHALL BE 4" OCTAGON WALL OUTLET BOXES SHALL BE PROPER DESIGN TO ACCOMMODATE THE DEVICES REQUIRED.

JUNCTION/PULL BOXES: (A) FOR EACH CONDUIT RUN: PROVIDE ONE JUNCTION/PULL BOX FOR EACH EQUIVALENT THREE QUARTER BENDS (70'). (B) UNDERGROUND FEEDERS: MINIMUM ONE PULL BOX FOR EACH 350 FEET OF CONDUIT RUN.

26 05 19 BUILDING WIRE AND CABLE WIRE: (TRIANGLE, AMERICAN INSULATED CABLE CO., OR CABLEX)

EMERGENCY AND NORMAL CIRCUITS MUST BE INSTALLED IN SEPARATE CONDUIT AND DEVICE BOXES PER N.E.C. ARTICLE 700.9 (B). REDWOOD SLEEPER AT 10' ON CENTER. CLEAR CONDUIT INTERIOR AFTER INSTALLATION.

FIELD INSULATION TESTING: INSULATION RESISTANCE OF ALL CONDUCTORS SHALL BE TESTED. EACH CONDUCTOR SHALL HAVE ITS INSULATION RESISTANCE TESTED AFTER THE INSTALLATION IS COMPLETED AND ALL SPLICES, TAPS AND CONNECTIONS ARE MADE EXCEPT FOR REMOVAL OF CONDUIT, PIPING AND CONNECTIONS TO TERMINALS.

26 27 26 WIRING DEVICES: WIRING DEVICES: FURNISH AND INSTALL WHERE INDICATED ON DRAWINGS. MATCH EXISTING OR BASE BUILDING DEVICES IF APPLICABLE. ALL DEVICES SHALL BE LEVITON "DECORA" TYPE (WHITE COLOR, CONFIRM WARCHTECT) OR APPROVED EQUAL UNLESS SPECIFIED OTHERWISE BY ARCHITECT.

TESTING AND CERTIFICATION: CONTRACTOR SHALL DELIVER A WRITTEN REPORT CERTIFYING THAT EVERY RECEPTACLE HAS BEEN TESTED AS FOLLOWS: (A) THE PHYSICAL INTEGRITY OF EACH RECEPTACLE SHALL BE CONFIRMED BY VISUAL INSPECTION. (B) THE CONTINUITY OF THE GROUNDING CIRCUIT IN EACH ELECTRICAL RECEPTACLE SHALL BE VERIFIED.

26 05 26 GROUNDING AND BONDING: GROUNDING: ALL CONDUIT WORK AND ELECTRICAL EQUIPMENT SHALL BE EFFECTIVELY AND PERMANENTLY GROUNDING IN ACCORDANCE WITH NEC REQUIREMENTS. PROVIDE GREEN EQUIPMENT GROUNDING CONDUCTOR WITH ALL POWER AND RECEPTACLE AND LIGHTING CIRCUITS.

26 05 53 ELECTRICAL IDENTIFICATION: IDENTIFICATION: LABEL ALL JUNCTION AND PULL BOXES WITH PANELS AND CIRCUIT NUMBERS. ALL JUNCTION AND PULL BOXES IN CEILING PLENUM SHALL BE PAINTED YELLOW FOR 480 VOLT HIGH VOLTAGE SYSTEM; BLUE FOR LOW VOLTAGE SYSTEM (240 VOLT AND/OR 208 VOLT).

COLOR CODE: CONDUCTORS SHALL BE COLOR CODED AS FOLLOWS (FOLLOW LOCAL AHJ OR EXISTING COLOR CODES IF APPLICABLE):

Table with 4 columns: Phase, Color, Voltage, and Notes. Rows include PHASE A (BROWN), PHASE B (ORANGE), PHASE C (YELLOW), NEUTRAL (GRAY OR WHITE), and GROUND (GREEN).

ALL PANELS SHALL BE IDENTIFIED USING NAMEPLATES WITH 4 ROWS OF TEXT (LETTER HEIGHT SHALL BE 1/4" MINIMUM). EXAMPLE: PANEL "XX", SECTION # 1 OF 2-SECT PNL, 225 AMPS BUS, 150A MCB, 208Y/120V, FED FROM DIST PANEL "XXX", 1ST FLOOR.

ALL EMERGENCY PANELS, JUNCTION BOXES WITH EMERGENCY CIRCUITS, ETC. SHALL BE PAINTED RED.

33 71 73 ELECTRICAL SERVICE: CONTRACTOR SHALL MAKE ARRANGEMENTS FOR TEMPORARY AND PERMANENT SERVICE. COMPLY WITH ALL SERVICE INSTALLATION STANDARDS OF THE SERVING UTILITY. ELECTRICAL SERVICE CHARACTERISTICS SHALL BE AS SHOWN ON THE ELECTRICAL ONE LINE DIAGRAM.

26 24 10 DISTRIBUTION SWITCHBOARDS: EQUIPMENT SHALL HAVE COPPER BUSES OR WINDINGS. PROVIDE SWITCHBOARD WHICH PERMITS ACCESS TO BUSES AND DEVICES FOR INSTALLATION AND FUTURE MAINTENANCE FROM THE FRONT, BACK AND SIDES.

GROUND-FAULT PROTECTION: PROVIDE GROUND FAULT PROTECTION ON CIRCUIT PROTECTIVE DEVICES WHERE INDICATED ON THE DRAWINGS. THE UNIT SHALL INCLUDE COORDINATED CURRENT SENSORS, SOLID STATE RELAY AND MONITOR PANEL OF THE SAME TYPE AND RATING.

TESTING: AFTER INSTALLATION AND BEFORE ACCEPTANCE BY THE OWNER, THE CONTRACTOR SHALL PROVIDE THE SERVICES OF AN INDEPENDENT TESTING ORGANIZATION SUCH AS GENERAL ELECTRIC INSTALLATION AND SERVICE ENGINEERING, TEST CO OR WESTINGHOUSE ENGINEERING SERVICES TO PERFORMANCE TEST ALL GROUND FAULT RELAYS IN ACCORDANCE WITH NEC PARAGRAPH 230.95.

ACCEPTABLE MANUFACTURERS ARE ABB, SQUARE D, EATON/CUTLER-HAMMER, AND SIEMENS. MATCH EXISTING WHERE REQUIRED BY OWNER.

26 24 16 PANELBOARDS: ALL PANELBOARDS SHALL HAVE COPPER BUSES. LOAD CENTER TYPE PANELBOARDS ARE NOT ACCEPTABLE AND SHALL NOT BE USED. PROVIDE BREAKERS WHICH ARE QUICK-MAKE AND QUICK-BREAK ON BOTH MANUAL AND AUTOMATIC OPERATION.

PANELBOARD DIRECTORIES: PROVIDE A STEEL DIRECTORY FRAME MOUNTED INSIDE THE DOOR WITH A HEAT-RESISTANT TRANSPARENT FACE AND A DIRECTORY CARD FOR IDENTIFYING THE LOADS SERVED. IDENTIFY EACH CIRCUIT WITH LOAD AND LOCATION (ROOM NAME AND ROOM NUMBERS) AND INDICATE WITH TYPED DIRECTORIES.

26 28 19 ENCLOSED SAFETY SWITCHES: ALL SAFETY SWITCHES SHALL BE HEAVY-DUTY TYPE WITH QUICK-MAKE, QUICK-BREAK CONTACTS AND SUITABLE FOR TERMINATING 75-DEGREE C WIRE.

26 22 00 DRY TYPE TRANSFORMERS: PROVIDE DRY TYPE QUIET TRANSFORMERS (PER ANSI-C89 AND UL 506). SELF-COOLED NEMA CLASS AA, COPPER WIRE WINDINGS. ALUMINUM WINDING TRANSFORMER IS ACCEPTABLE, PROVIDED THAT SUBSTITUTE ALUMINUM TRANSFORMER IS IN COMPLIANCE WITH NEC REQUIREMENTS.

SELECT THE APPROPRIATE TAP SETTINGS ON TRANSFORMER SO THAT THE ACTUAL SECONDARY VOLTAGE IS +/-2% OF A TAP SPAN AT FULL LOAD. RECORD THE TRANSFORMER SERIAL NUMBER, KVA RATINGS, SELECTED TAP SETTING AND SECONDARY VOLTAGE READINGS. SUBMIT COPIES OF THE RECORD TO THE ARCHITECT/ENGINEER.

PROVIDE A 220C INSULATION SYSTEM FOR A MAXIMUM 115-DEGREE C TEMPERATURE RISE OVER A 40-DEGREE C AMBIENT. SPECIAL TRANSFORMERS: 150-DEGREE C RISE FOR SHIELDED ISOLATION TYPE; 115-DEGREE C RISE FOR K-RATED TRANSFORMERS.

WARNING: It is a violation of the NYS Education Law Article 145 for any person to alter this document in any way, unless they are acting under the direction of a Professional Engineer

REVISIONS table with columns for NO., DATE, and DESCRIPTION.

ENGINEERS PLANNERS SCIENTISTS ARCHITECTS CONSTRUCTION MANAGERS

SA architects client centered • Smart solutions

600 North Hanley Street, Suite 150 York, PA 17404

ELECTRICAL SPECIFICATIONS POUGHKEEPSIE NY STORAGE DIAMOND POINT DEVELOPMENT

1986 SOUTH ROAD POUGHKEEPSIE, NEW YORK 12601

FILE NO: 22-082 DATE: 7/1/2022 SCALE: AS NOTED DRAWN BY: AMB DRAWING NO: E-003



FILE NO: 22-082 DATE: 7/1/2022 SCALE: AS NOTED

DRAWN BY: AMB DRAWING NO: E-003

ISSUED FOR PERMIT