

LIGHTING FIXTURE SCHEDULE									
TAG	MANUFACTURER	MODEL NUMBER	DESCRIPTION	MOUNTING	LAMP	WATTAGE	VOLTAGE	NOTES	
A	US LED	GTR2-22EH-35-80-UNV2-B-NF	2X2 LINEAR LIGHT FIXTURE	RECESSED	LED	19 W	277 V		
AE	US LED	GTR2-22EH-35-80-UNV2-B-NF-ILB-CP12A	2X2 LINEAR LIGHT FIXTURE WITH INTEGRAL EMERGENCY BATTERY PACK	RECESSED	LED	19 W	277 V		
B	US LED	PFJ1-1-4-1-35-D-50-D	1X4 LINEAR STRIP FIXTURE	SURFACE	LED	35 W	277 V		
BE	US LED	PFJ1-1-4-1-35-D-50-D-B	1X4 LINEAR STRIP FIXTURE WITH INTEGRAL EMERGENCY BATTERY BACK UP	SURFACE	LED	35 W	277 V		
C	ACCESS LIGHTING	20851LEDMS-WHACR	6.5" DIAMETER SURFACE MOUNTED LED FIXTURE WITH INTEGRAL MOTION SENSOR.	RECESSED	LED	9 W	277 V		
DE	DECO LIGHTING INC	LUCERA-25-50-UNV-MS1-EM	NOMINAL 4" LINEAR WALL MOUNTED STAIRWELL FIXTURE WITH INTEGRAL OCCUPANCY SENSOR AND EMERGENCY BATTERY.	WALL	LED	25 W	277 V		
F	US LED	LTR3-1-UNV-40-18-6R-C-WH	6" DIAMETER LED DOWNLIGHT	RECESSED	LED	13 W	277 V		
FE	US LED	LTR3-1-UNV-40-18-6R-C-WH-EH-25170-XXU	6" DIAMETER LED DOWNLIGHT WITH INTEGRAL EMERGENCY BATTERY.	RECESSED	LED	13 W	277 V		
LP-A	SELUX CORPORATION	QH2L-X-R4-5G350-30-XX-UNV-HS-DM-PC1	POLE MOUNTED LED SITE LUMINAIRE. UL LISTING FOR WET LOCATIONS.	15' OVERALL 12" POLE AND 3' CONCRETE BASE	LED	33 W	277 V		
LP-B	SELUX CORPORATION	QH2L-X-R55-5G350-30-XX-UNV-DM-PC1	POLE MOUNTED LED SITE LUMINAIRE. UL LISTING FOR WET LOCATIONS.	15' OVERALL	LED	33 W	277 V		
WP2	HUBBELL OUTDOOR	OSP1-24L15-3K7-2-PCU	LED FULL CUTOFF WALL PACK WITH TYPE 3 DISTRIBUTION AND INTEGRAL PHOTOCELL FOR ON/OFF CONTROL. FIXTURE FINISH PER ARCHITECT.	WALL	LED	14 W	277 V		
WP2E	HUBBELL OUTDOOR	OSP1-24L15-3K7-2-PCU	LED FULL CUTOFF WALL PACK WITH TYPE 3 DISTRIBUTION AND INTEGRAL PHOTOCELL FOR ON/OFF CONTROL AND COLD WEATHER EMERGENCY BATTERY. FIXTURE FINISH PER ARCHITECT.	WALL	LED	14 W	277 V		
WP3	HUBBELL OUTDOOR	OSP1-24L15-3K7-2-PCU	LED FULL CUTOFF WALL PACK WITH TYPE 4 DISTRIBUTION AND INTEGRAL PHOTOCELL FOR ON/OFF CONTROL. FIXTURE FINISH PER ARCHITECT.	WALL	LED	14 W	277 V		
WP3E	HUBBELL OUTDOOR	OSP1-24L15-3K7-2-PCU	LED FULL CUTOFF WALL PACK WITH TYPE 4 DISTRIBUTION AND INTEGRAL PHOTOCELL FOR ON/OFF CONTROL AND COLD WEATHER EMERGENCY BATTERY. FIXTURE FINISH PER ARCHITECT.	WALL	LED	14 W	277 V		
X	SURE-LITES	APXH7	INTERNALLY ILLUMINATED EXIT SIGN WITH WHITE THERMOPLASTIC HOUSING. INTEGRAL BATTERY AND LED LAMPS. COLOR OF LETTERING PER LOCAL AHJ.	CEILING	LED	3 W	277 V		

VERIFY FIXTURE SELECTION WITH ARCHITECT PRIOR TO PURCHASE. COORDINATE ALL COLORS AND FINISHES WITH ARCHITECT. PROVIDE APPROPRIATE DIMMING POWER PACKS AS NEEDED.

NO.	DATE	DESCRIPTION

ENGINEERS
PLANNERS
SCIENTISTS
CONSTRUCTION MANAGERS

KCI
TECHNOLOGIES

500 LOUISE DRIVE, SUITE 300
WILMINGTON, DE 19805
PHONE: 313.691.1340
WWW.KCI.COM

SAA architects
Client centered • Smart solutions

600 North Hanley Street, Suite 150
York, PA 17404
T - 717.843.3200 F - 717.690.0295
www.SAAarchitects.com

ELECTRICAL SCHEDULES

POUGHKEEPSIE NY STORAGE
DIAMOND POINT DEVELOPMENT

1899 SOUTH ROAD POUGHKEEPSIE, NEW YORK 12501
DUTCHESS COUNTY



FILE No.	22-082
DATE	7/1/2022
SCALE	AS NOTED
DRAWN BY	Author
DRAWING No.	E-602

WARNING: It is a violation of the NYS Education Law Article 145 for any person to alter this document in anyway, unless they are acting under the direction of a Professional Engineer

ISSUED FOR PERMIT