

1. THE EXISTING ONE LINE HAS BEEN DEVELOPED BASED ON EXISTING DRAWINGS AND READILY AVAILABLE OBSERVATIONS. NO CIRCUIT TRACES WERE USED TO VERIFY THE SYSTEM CONFIGURATION. WIRE ROUTES ARE SHOWN ARE THE MOST PROBABLE AND HAVE NOT BEEN FIELD VERIFIED. NOT ALL DISTRIBUTION EQUIPMENT IS SHOWN ON THIS DRAWING.
2. COORDINATE SHUT DOWN OF PANEL WITH THE OWNER. PERFORM ALL PREPARATORY WORK ALONG WITH ALL ASSOCIATED CONDUIT AND FEEDERS FOR A TIMELY CHANGE-OVER. THE CONTRACTOR SHALL CREATE AND SUBMIT A SEQUENCE OF WORK AND A SHUT DOWN SCHEDULE. THE SHUT DOWN SCHEDULE SHALL IDENTIFY THE LOADS AFFECTED BY THE SHUTDOWN AS WELL AS OPTIMUM TIME FOR CUTOVER, APPROXIMATE DOWNTIME AND ANY OTHER RELATED INFORMATION. THE ELECTRICAL CONTRACTOR SHALL SUBMIT A LOAD SCHEDULE FOR ALL TEMPORARY LOADS AND SUBMIT TO OWNER. FIELD VERIFY ALL LOADS PRIOR TO ANY WORK.

① EXISTING PANELBOARD AFFECTED BY NEW CONSTRUCTION.

