



104 E 25th Street, 8th Floor
New York, NY 10010
Telephone 212-353-8280
Fax 212-353-8306
www.oneatlas.com

November 2, 2021

Mr. Christopher Buteux
Supervising Clerk of the Works
Rockland County
50 Sanatorium Road, Building A
Pomona, New York 10970

Re: Report of Asbestos Survey Findings
Animal Shelter
65 Firemen's Memorial Drive, Pomona, NY 10970

Dear Mr. Buteux:

ATC Group Services, LLC (ATC), doing business as Atlas Technical (Atlas), completed an asbestos inspection in the aforementioned location. The inspection included visual observation and material sampling of suspect asbestos-containing materials (ACM) associated with the above referenced location. This inspection was performed by Mr. Pavel Mashenko on October 25, 2021. Mr. Mashenko is NYS DOL-licensed Asbestos Inspector (NYS DOL license number 95-04292). Based on the results of analyses, **asbestos was detected** in several of the building materials that were sampled in the animal shelter, including the main roof roofing material (2nd layer), tar/caulking on the main roof vent pipe, and 12"x12" off-white vinyl floor tiles in the lobby and corridor.

Based on the visual inspection and laboratory analysis of bulk samples collected from suspect materials within the areas inspected, proper asbestos abatement procedures must be utilized if the asbestos-containing materials (ACM) identified prior to demolition of the building.

Atlas appreciates this opportunity to be of service to you on this project. If you have any questions concerning this report or if we may be of further assistance to you, please contact us.

Sincerely,

Atlas Technical

A handwritten signature in black ink, appearing to read "Pavel Mashenko".

Pavel Mashenko
Senior Project Manager

A handwritten signature in black ink, appearing to read "John Springston".

John Springston, CIH, CSP, FAIHA
Industrial Hygiene Services Manager