


GENERAL NOTES


- REFERENCE PERFORMANCE CRITERIA NOTED ON 15000 - SHEET INDEX AND PROJECT INFORMATION. ENCLOSURE DETAILS SHOW THE FOLLOWING:
1. ROOF INSULATION MINIMUM R-30 C.I. 2.5" L.P. AND 9.5" P.P. ELEVATIONS ARE BASED ON AVERAGE R-30 OF POLYISOCYANURATE BOARD INSULATION WITH MINIMUM 1/4" PER FOOT ROOF SLOPE. PROVIDE 1/2" MINIMUM THICK COVER BOARD.
 2. RAINSCREEN WALL SYSTEM: MINIMUM R-10 + R-7.5 C.I. INSULATION GLASS-FIBER BOARD INSULATION FULL DEPTH OF STUD CAVITY (REFER TO STRUCTURAL DRAWINGS FOR STUD DEPTHS) + 2" CONTINUOUS EXTERIOR EXTRUDED-POLYSTYRENE RIGID BOARD INSULATION.
 3. FOUNDATION WALL PERIMETER CONDITIONS: PROVIDE MINIMUM R-10 EXTRUDED-POLYSTYRENE RIGID BOARD INSULATION AT FOUNDATION WALLS AT THE PERIMETER OF UNHEATED SLABS AND MINIMUM R-15 EXTRUDED-POLYSTYRENE RIGID BOARD INSULATION AT HEATED SLABS FOR 24" BELOW GRADE OR TO TOP OF SHELF/FOOTING WHICHEVER IS LESS.
 4. BELOW SLAB ON GRADE CONDITIONS: PROVIDE MINIMUM R-5 EXTRUDED-POLYSTYRENE RIGID BOARD INSULATION AT HEATED SLABS.
 5. ALL GYPSUM BOARD TO BE WITH MOISTURE AND MOLD RESISTANT CORE AND FACING SURFACES.
 6. PER 418-1.5 (a) IN NEW YORK STATE CHILD DAY CARE REGULATIONS, GLASS IN OUTSIDE WINDOWS LESS THAN 32" INCHES ABOVE THE FINISH FLOOR MUST BE OF SAFETY GRADE OR OTHERWISE PROTECTED BY USE OF BARRIERS TO AVOID ACCIDENTAL IMPACT.

SHEET NOTES


- 02 GALVANIZED METAL PIPE GUARDRAIL
- 03 LIGHT GAUGE METAL FRAMING; RE: STRUCTURAL
- 04 VINYL-COATED CHAIN LINK FENCING & GATE; RE: LANDSCAPING
- 05 1" X 8" CONCEALED GUTTER AND LEADERS; HEAT-TRACED THROUGH ENTIRE SYSTEM; REFER TO PLUMBING AND ELECTRICAL.




01 BUILDING SECTION - LONGITUDINAL SECTION AT NORTH WING
SCALE: 1/8" = 1'-0"




02 BUILDING SECTION - LONGITUDINAL SECTION AT EAST WING
SCALE: 1/8" = 1'-0"



04 BUILDING SECTION - TRANSVERSE SECTION AT NORTH WING
SCALE: 1/8" = 1'-0"



03 BUILDING SECTION - TRANSVERSE SECTION AT EAST WING
SCALE: 1/8" = 1'-0"



No.	Date	Description
0	05.20.2022	ISSUED FOR PERMIT
1	06.20.2022	100% CONSTRUCTION DOCUMENTS
2	07.01.2022	100% CONSTRUCTION DOCUMENTS-1

Plot Date: 07.01.2022
ALL DRAWINGS AND WRITTEN MATERIALS REPRESENTED ON THIS SHEET CONSTITUTE THE CONTRACT DOCUMENTS AND ARE THE SOLE PROPERTY OF REGENERON PHARMACEUTICALS. THIS SHEET MAY NOT BE REPRODUCED OR COPIED IN WHOLE OR IN PART, NOR MAY ANY OF THE DRAWINGS OR WRITTEN MATERIALS BE REPRODUCED OR COPIED IN WHOLE OR IN PART WITHOUT THE WRITTEN CONSENT OF REGENERON PHARMACEUTICALS. THIS SHEET MUST BE RETURNED UPON THE COMPLETION OF THE PROJECT WITHOUT THE EXPRESS WRITTEN CONSENT OF DESIGN PROFESSIONAL. REGENERON ASSUMES FULL RESPONSIBILITY FOR ANY AND ALL WORK INVOLVED IN SUCH REUSE.

Professional Seal and Signature

Vendor Name: GENSLER
Vendor Project No.: 006.3608.000
Discipline: ARCHITECTURE Drawn By: GENSLER
OVERALL BUILDING SECTIONS

Scale: As indicated Floor: 1ST FLOOR

A-300