



Hydraulic Calculations by HydraCALC

Hydratec Incorporated
64 Haverhill Road
Route 111
Windham, NH 03087
603-434-0502

Job Name : BLDG B ALT K25 SYS 16
Drawing : HIGH PILED STORAGE
Location : NY312 & PUGSLEY RD, BREWSTER, NY 10509
Remote Area : SYSTEM 16
Contract : 5031092
Data File : Lincoln Equities - BLDG B ALTERNATE SYS 16 K22 8.23.23.WXF



Hydraulic Design Information Sheet

Name - BLDG B ALT K22 SYS 16 Date - 8.23.23
Location - NY312 & PUGSLEY RD, BREWSTER, NY 10509
Building - HIGH PILED STORAGE System No. - SYSTEM 16
Contractor - SA COMUNALE Contract No. - 5031092
Calculated By - JUSTIN BEOUGHER Drawing No. - PG.19
Construction: () Combustible (X) Non-Combustible Ceiling Height - 45'-6
Occupancy - ESFR

S (X) NFPA 13 () Lt. Haz. Ord.Haz.Gp. () 1 () 2 () 3 () Ex.Haz.
Y () Figure Curve

S Other

T Specific Ruling

Made By

Date

M	Number of ESFR Sprinklers	- 12	System Type	Sprinkler/Nozzle
	End Head Pressure (PSI)	- 40	(X) Wet	Make RELIABLE
D	ESFR K-Factor	- 22.4	() Dry	Model P22
E	Elevation at Highest Outlet	- 43'-10 1/2	() Deluge	Size 1"
S	Hose Allowance - Inside	- 100	() Preaction	K-Factor 22.4
I	Rack Sprinkler Allowance	- NA	() Other	Temp.Rat.165
G	Hose Allowance - Outside	- 150		

N
Note

Calculation Flow Required - 1956.84 Press Required - 111.458
Summary C-Factor Used: 120 Overhead 150 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test -		Cap. -
T	Time of Test -	Rated Cap.- 2000	Elev.-
E	Static Press -	@ Press - 149	
R	Residual Press -	Elev. - 2	Well
	Flow -		Proof Flow
S	Elevation -		

U
P Location - PUMP
P WATER STORAGE TANK
L Source of Information -
Y

C	Commodity GROUP A	CARTONED UNEXP.	Class 1-4	Location
O	Storage Ht. 40 FT		Area	Aisle W.
M	Storage Method:	Solid Piled	%	Palletized % Rack
M	() Single Row	() Conven. Pallet	() Auto. Storage	() Encap.
S	R () Double Row	() Slave Pallet	() Solid Shelf	() Non
T	A () Mult. Row		() Open Shelf	

O C
R K Flue Spacing Clearance:Storage to Ceiling
A Longitudinal Transverse

G
E Horizontal Barriers Provided:


Water Supply Curve C

Hydratec Incorporated
BLDG B ALT K25 SYS 16

Page 2
Date 8.23.23

Pump Data:
P1 - Pump Churn Pressure : 160
P2 - Pump Rated Pressure : 149
P2 - Pump Rated Flow : 2000
P3 - Pump Pressure @ Max Flow : 135
P3 - Pump Max Flow : 3000

Demand:
D1 - Elevation : 18.840
D2 - System Flow : 1706.84
D2 - System Pressure : 111.458
Hose (Demand) : 250
D3 - System Demand : 1956.84
Safety Margin : 37.871



Fittings Used Summary

Hydratec Incorporated
BLDG B ALT K25 SYS 16

Page 3
Date 8.23.23

Fitting Legend																					
Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
F	NFPA 13 45° Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
L	NFPA 13 Long Turn Elbow	0.5	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90° Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90° Ell Firelock #001	0	0	0	0	0	3.5	4.3	5	0	6.8	8.5	10	13	4.5	5.1	0	0	0	0	0
X	90° Tee-Branch Firelock 002	0	0	0	0	0	8.5	10.8	13	0	16	21	25	33	9.3	11	0	0	0	0	0

Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA

Hydratec Incorporated
BLDG B ALT K25 SYS 16

Page 4
Date 8.23.23

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
PO	See Information on Pump Curve			149.329	1956.84	111.458

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
6	45.5		63.1		
R13	45.5		62.36		
1	45.5		62.99		
2	45.5		63.11		
3	45.5		63.22		
4	45.5		63.33		
R14	45.5		62.35		
5	45.5		62.99		
7	45.5		63.21		
8	45.5		63.33		
R15	45.5		62.32		
9	45.5		62.97		
10	45.5		63.08		
11	45.5		63.2		
12	45.5		63.31		
R16	45.5		62.25		
R17	45.5		55.42		
H1	45.5	22.4	40.53	142.6	
H2	45.5	22.4	40.0	141.67	
H3	45.5	22.4	40.0	141.67	
H4	45.5	22.4	40.5	142.55	
R18	45.5		55.44		
H5	45.5	22.4	40.55	142.65	
H6	45.5	22.4	40.03	141.72	
H7	45.5	22.4	40.03	141.72	
H8	45.5	22.4	40.53	142.6	
R19	45.5		55.63		
H9	45.5	22.4	40.69	142.89	
H10	45.5	22.4	40.16	141.96	
H11	45.5	22.4	40.17	141.96	
H12	45.5	22.4	40.66	142.84	
R20	45.5		63.04		
R21	45.5		63.6		
R22	45.5		64.07		
R23	45.5		64.46		
R24	45.5		64.8		
R25	45.5		65.06		
R26	45.5		65.26		
R27	45.5		65.41		

Flow Summary - NFPA

Hydratec Incorporated
BLDG B ALT K25 SYS 16

Page 5
Date 8.23.23

NODE ANALYSIS (cont.)

Node Tag	Elevation	Node Type	Pressure at Node	Discharge at Node	Notes
R28	45.5		65.52		
13	45.5		61.99		
14	45.5		61.98		
15	45.5		61.94		
16	45.5		61.86		
17	45.5		61.73		
18	45.5		61.73		
19	45.5		61.95		
20	45.5		62.67		
21	45.5		63.27		
22	45.5		63.75		
23	45.5		64.13		
24	45.5		64.44		
25	45.5		64.66		
26	45.5		64.81		
27	45.5		64.89		
28	45.5		64.92		
29	45.5		64.92		
30	45.5		64.93		
31	45.5		64.93		
32	45.5		64.95		
33	45.5		64.97		
34	45.5		65.06		
35	45.5		65.25		
36	45.5		65.59		
37	45.5		65.95		
38	45.5		66.35		
39	45.5		66.81		
40	45.5		67.31		
41	45.5		67.84		
42	45.5		68.43		
43	45.5		69.06		
44	45.5		69.75		
FMJ	45.5		71.0		
TR2	45.5		77.43		
BR2	2.0		98.96	100.0	
FLG	2.0		99.36		
UG7	-5.0		106.26		
UG8	-5.0		105.71		
UG9	-5.0		105.15	150.0	
UG10	-5.0		104.65		
UG11	-5.0		108.09		
NL	-5.0		108.57		
UG12	-5.0		109.72		
UG13	-5.0		109.42		
UG14	-5.0		108.89		
UG15	-5.0		107.76		
UG16	-5.0		106.95		
UG6	-5.0		113.17		

Flow Summary - NFPA

Hydratec Incorporated
BLDG B ALT K25 SYS 16

Page 6
Date 8.23.23

NODE ANALYSIS (cont.)

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
PUMP	2.0		110.45		
PO	2.0		111.46		

Final Calculations : Hazen-Williams

Hydratec Incorporated
BLDG B ALT K25 SYS 16

Page 7
Date 8.23.23

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
R13 to 1	45.500 45.500		60.34 60.34	2.5 2.635	0.0 0.0	56.333 0.0	120 0.0113	62.355 0.0			
1 to 2	45.500 45.500		0.0 60.34	2.5 2.635	0.0 0.0	10.000 0.0	120 0.0113	62.993 0.0	Vel =	3.55	
2 to 3	45.500 45.500		0.0 60.34	2.5 2.635	0.0 0.0	10.000 0.0	120 0.0113	63.106 0.0	Vel =	3.55	
3 to 4	45.500 45.500		0.0 60.34	2.5 2.635	0.0 0.0	10.000 0.0	120 0.0113	63.219 0.0	Vel =	3.55	
4 to R29	45.500 45.500		0.0 60.34	2.5 2.635	0.0 0.0	108.291 0.0	120 0.0113	63.332 0.0	Vel =	3.55	
R29			0.0 60.34					64.557	K Factor =	7.51	
R14 to 5	45.500 45.500		60.49 60.49	2.5 2.635	0.0 0.0	56.333 0.0	120 0.0114	62.347 0.0	Vel =	3.56	
5 to 6	45.500 45.500		0.0 60.49	2.5 2.635	0.0 0.0	10.000 0.0	120 0.0113	62.987 0.0	Vel =	3.56	
6 to 7	45.500 45.500		0.0 60.49	2.5 2.635	0.0 0.0	10.000 0.0	120 0.0114	63.100 0.0	Vel =	3.56	
7 to 8	45.500 45.500		0.0 60.49	2.5 2.635	0.0 0.0	10.000 0.0	120 0.0114	63.214 0.0	Vel =	3.56	
8 to R30	45.500 45.500		0.0 60.49	2.5 2.635	0.0 0.0	108.291 0.0	120 0.0114	63.328 0.0	Vel =	3.56	
R30			0.0 60.49					64.558	K Factor =	7.53	
R15 to 9	45.500 45.500		60.98 60.98	2.5 2.635	0.0 0.0	56.333 0.0	120 0.0115	62.315 0.0	Vel =	3.59	
9 to 10	45.500 45.500		0.0 60.98	2.5 2.635	0.0 0.0	10.000 0.0	120 0.0115	62.965 0.0	Vel =	3.59	
10 to 11	45.500 45.500		0.0 60.98	2.5 2.635	0.0 0.0	10.000 0.0	120 0.0116	63.080 0.0	Vel =	3.59	
11 to 12	45.500 45.500		0.0 60.98	2.5 2.635	0.0 0.0	10.000 0.0	120 0.0115	63.196 0.0	Vel =	3.59	
12 to R31	45.500 45.500		0.0 60.98	2.5 2.635	0.0 0.0	108.291 0.0	120 0.0115	63.311 0.0	Vel =	3.59	

Final Calculations : Hazen-Williams

Hydratec Incorporated
BLDG B ALT K25 SYS 16

Page 8
Date 8.23.23

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
R31			0.0 60.98						64.561		K Factor = 7.59	
R16 to R32	45.500 45.500		62.00 62.0	2.5 2.635		0.0 0.0 0.0	194.625 0.0 194.625	120 0.0119	62.248 0.0 2.315		Vel = 3.65	
R32			0.0 62.00						64.563		K Factor = 7.72	
R17 to H1	45.500 45.500		-281.29 -281.29	2.5 2.635		0.0 0.0 0.0	76.333 0.0 76.333	120 -0.1951	55.424 0.0 -14.896		Vel = 16.55	
H1 to H2	45.500 45.500	22.40	142.61 -138.68	2.5 2.635		0.0 0.0 0.0	10.000 0.0 10.000	120 -0.0528	40.528 0.0 -0.528		Vel = 8.16	
H2 to H3	45.500 45.500	22.40	141.67 2.99	2.5 2.635		0.0 0.0 0.0	10.000 0.0 10.000	120 0	40.000 0.0 0.0		Vel = 0.18	
H3 to H4	45.500 45.500	22.40	141.67 144.66	2.5 2.635		0.0 0.0 0.0	8.708 0.0 8.708	120 0.0571	40.000 0.0 0.497		Vel = 8.51	
H4 to R33	45.500 45.500	22.40	142.54 287.2	2.5 2.635		0.0 0.0 0.0	88.291 0.0 88.291	120 0.2028	40.497 0.0 17.907		Vel = 16.90	
R33			0.0 287.20						58.404		K Factor = 37.58	
R18 to H5	45.500 45.500		-281.12 -281.12	2.5 2.635		0.0 0.0 0.0	76.333 0.0 76.333	120 -0.1949	55.435 0.0 -14.880		Vel = 16.54	
H5 to H6	45.500 45.500	22.40	142.65 -138.47	2.5 2.635		0.0 0.0 0.0	10.000 0.0 10.000	120 -0.0526	40.555 0.0 -0.526		Vel = 8.15	
H6 to H7	45.500 45.500	22.40	141.72 3.25	2.5 2.635		0.0 0.0 0.0	10.000 0.0 10.000	120 0	40.029 0.0 0.0		Vel = 0.19	
H7 to H8	45.500 45.500	22.40	141.72 144.97	2.5 2.635		0.0 0.0 0.0	8.708 0.0 8.708	120 0.0573	40.029 0.0 0.499		Vel = 8.53	
H8 to R34	45.500 45.500	22.40	142.61 287.58	2.5 2.635		0.0 0.0 0.0	88.291 0.0 88.291	120 0.2033	40.528 0.0 17.950		Vel = 16.92	
R34			0.0 287.58						58.478		K Factor = 37.61	
R19 to H9	45.500 45.500		-281.73 -281.73	2.5 2.635		0.0 0.0 0.0	76.333 0.0 76.333	120 -0.1957	55.633 0.0 -14.940		Vel = 16.58	
H9 to H10	45.500 45.500	22.40	142.90 -138.83	2.5 2.635		0.0 0.0 0.0	10.000 0.0 10.000	120 -0.0528	40.693 0.0 -0.528		Vel = 8.17	

Final Calculations : Hazen-Williams

Hydratec Incorporated
BLDG B ALT K25 SYS 16

Page 9
Date 8.23.23

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
H10 to H11	45.500 45.500	22.40	141.96 3.13	2.5 2.635		0.0 0.0	10.000 0.0	120 0	40.165 0.0			
						0.0	10.000		0.0	Vel =	0.18	
H11 to H12	45.500 45.500	22.40	141.96 145.09	2.5 2.635		0.0 0.0	8.708 0.0	120	40.165 0.0			
						0.0	8.708	0.0573	0.499	Vel =	8.54	
H12 to R35	45.500 45.500	22.40	142.84 287.93	2.5 2.635		0.0 0.0	88.291 0.0	120	40.664 0.0			
						0.0	88.291	0.2038	17.992	Vel =	16.94	
R35			0.0 287.93						58.656	K Factor =	37.60	
R20 to R36	45.500 45.500		60.09 60.09	2.5 2.635		0.0 0.0	194.625 0.0	120	63.038 0.0			
						0.0	194.625	0.0112	2.185	Vel =	3.54	
R36			0.0 60.09						65.223	K Factor =	7.44	
R21 to R37	45.500 45.500		57.51 57.51	2.5 2.635		0.0 0.0	194.625 0.0	120	63.602 0.0			
						0.0	194.625	0.0103	2.014	Vel =	3.38	
R37			0.0 57.51						65.616	K Factor =	7.10	
R22 to R38	45.500 45.500		56.55 56.55	2.5 2.635		0.0 0.0	194.625 0.0	120	64.072 0.0			
						0.0	194.625	0.0100	1.953	Vel =	3.33	
R38			0.0 56.55						66.025	K Factor =	6.96	
R23 to R39	45.500 45.500		57.45 57.45	2.5 2.635		0.0 0.0	194.625 0.0	120	64.464 0.0			
						0.0	194.625	0.0103	2.011	Vel =	3.38	
R39			0.0 57.45						66.475	K Factor =	7.05	
R24 to R40	45.500 45.500		59.59 59.59	2.5 2.635		0.0 0.0	194.625 0.0	120	64.798 0.0			
						0.0	194.625	0.0111	2.151	Vel =	3.51	
R40			0.0 59.59						66.949	K Factor =	7.28	
R25 to R41	45.500 45.500		63.03 63.03	2.5 2.635		0.0 0.0	194.625 0.0	120	65.061 0.0			
						0.0	194.625	0.0123	2.387	Vel =	3.71	
R41			0.0 63.03						67.448	K Factor =	7.67	
R26 to R42	45.500 45.500		67.57 67.57	2.5 2.635		0.0 0.0	194.625 0.0	120	65.262 0.0			
						0.0	194.625	0.0139	2.714	Vel =	3.98	
R42			0.0 67.57						67.976	K Factor =	8.20	

Final Calculations : Hazen-Williams

Hydratec Incorporated
BLDG B ALT K25 SYS 16

Page 10
Date 8.23.23

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
R27 to R43	45.500 45.500		72.96 72.96	2.5 2.635	0.0 0.0	194.625 0.0	120 0.0161	65.412 0.0		Vel = 4.29	
R43			0.0 72.96					68.541		K Factor = 8.81	
R28 to R44	45.500 45.500		78.98 78.98	2.5 2.635	0.0 0.0	194.625 194.625	120 0.0186	65.524 0.0		Vel = 4.65	
R44			0.0 78.98					69.148		K Factor = 9.50	
13 to R13	45.500 45.500		60.34 60.34	2.5 2.635	X T 14.827 16.474 0.0	1.000 31.301 32.301	120 0.0113	61.990 0.0		Vel = 3.55	
R13			0.0 60.34					62.355		K Factor = 7.64	
14 to R14	45.500 45.500		60.49 60.49	2.5 2.635	X T 14.827 16.474 0.0	1.000 31.301 32.301	120 0.0114	61.980 0.0		Vel = 3.56	
R14			0.0 60.49					62.347		K Factor = 7.66	
15 to R15	45.500 45.500		60.98 60.98	2.5 2.635	X T 14.827 16.474 0.0	1.000 31.301 32.301	120 0.0115	61.943 0.0		Vel = 3.59	
R15			0.0 60.98					62.315		K Factor = 7.72	
16 to R16	45.500 45.500		62.00 62.0	2.5 2.635	X T 14.827 16.474 0.0	1.000 31.301 32.301	120 0.0119	61.864 0.0		Vel = 3.65	
R16			0.0 62.00					62.248		K Factor = 7.86	
17 to R17	45.500 45.500		-281.29 -281.29	2.5 2.635	X T 14.827 16.474 0.0	1.000 31.301 32.301	120 -0.1952	61.728 0.0		Vel = 16.55	
R17			0.0 -281.29					55.424		K Factor = -37.78	
18 to R18	45.500 45.500		-281.12 -281.12	2.5 2.635	X T 14.827 16.474 0.0	1.000 31.301 32.301	120 -0.1949	61.732 0.0		Vel = 16.54	
R18			0.0 -281.12					55.435		K Factor = -37.76	
19 to R19	45.500 45.500		-281.73 -281.73	2.5 2.635	X T 14.827 16.474 0.0	1.000 31.301 32.301	120 -0.1957	61.955 0.0		Vel = 16.58	
R19			0.0 -281.73					55.633		K Factor = -37.77	
20 to R20	45.500 45.500		60.09 60.09	2.5 2.635	X T 14.827 16.474 0.0	1.000 31.301 32.301	120 0.0112	62.675 0.0		Vel = 3.54	

Final Calculations : Hazen-Williams

Hydratec Incorporated
BLDG B ALT K25 SYS 16

Page 11
Date 8.23.23

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
R20			0.0 60.09						63.038		K Factor = 7.57	
21 to R21	45.500 45.500		57.51 57.51	2.5 2.635	X T	14.827 16.474 0.0	1.000 31.301 32.301	120 0.0104	63.267 0.0 0.335		Vel = 3.38	
R21			0.0 57.51						63.602		K Factor = 7.21	
22 to R22	45.500 45.500		56.55 56.55	2.5 2.635	X T	14.827 16.474 0.0	1.000 31.301 32.301	120 0.0100	63.748 0.0 0.324		Vel = 3.33	
R22			0.0 56.55						64.072		K Factor = 7.06	
23 to R23	45.500 45.500		57.45 57.45	2.5 2.635	X T	14.827 16.474 0.0	1.000 31.301 32.301	120 0.0103	64.130 0.0 0.334		Vel = 3.38	
R23			0.0 57.45						64.464		K Factor = 7.16	
24 to R24	45.500 45.500		59.59 59.59	2.5 2.635	X T	14.827 16.474 0.0	1.000 31.301 32.301	120 0.0111	64.441 0.0 0.357		Vel = 3.51	
R24			0.0 59.59						64.798		K Factor = 7.40	
25 to R25	45.500 45.500		63.03 63.03	2.5 2.635	X T	14.827 16.474 0.0	1.000 31.301 32.301	120 0.0123	64.665 0.0 0.396		Vel = 3.71	
R25			0.0 63.03						65.061		K Factor = 7.81	
26 to R26	45.500 45.500		67.57 67.57	2.5 2.635	X T	14.827 16.474 0.0	1.000 31.301 32.301	120 0.0140	64.811 0.0 0.451		Vel = 3.98	
R26			0.0 67.57						65.262		K Factor = 8.36	
27 to R27	45.500 45.500		72.96 72.96	2.5 2.635	X T	14.827 16.474 0.0	1.000 31.301 32.301	120 0.0161	64.892 0.0 0.520		Vel = 4.29	
R27			0.0 72.96						65.412		K Factor = 9.02	
28 to R28	45.500 45.500		78.98 78.98	2.5 2.635	X T	14.827 16.474 0.0	1.000 31.301 32.301	120 0.0186	64.923 0.0 0.601		Vel = 4.65	
R28			0.0 78.98						65.524		K Factor = 9.76	
29 to R29	45.500 45.500		-60.34 -60.34	2.5 2.635	X T	14.827 16.474 0.0	1.083 31.301 32.384	120 -0.0113	64.924 0.0 -0.367		Vel = 3.55	
			0.0									

Final Calculations : Hazen-Williams

Hydratec Incorporated
BLDG B ALT K25 SYS 16

Page 12
Date 8.23.23

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
R29			-60.34					64.557		K Factor = -7.51	
30 to R30	45.500 45.500		-60.49 -60.49	2.5 2.635	X T	14.827 16.474 0.0	120 120 -0.0114	64.926 0.0 -0.368		Vel = 3.56	
R30			0.0 -60.49					64.558		K Factor = -7.53	
31 to R31	45.500 45.500		-60.98 -60.98	2.5 2.635	X T	14.827 16.474 0.0	120 120 -0.0115	64.934 0.0 -0.373		Vel = 3.59	
R31			0.0 -60.98					64.561		K Factor = -7.59	
32 to R32	45.500 45.500		-62.00 -62.0	2.5 2.635	X T	14.827 16.474 0.0	120 120 -0.0119	64.948 0.0 -0.385		Vel = 3.65	
R32			0.0 -62.00					64.563		K Factor = -7.72	
33 to R33	45.500 45.500		-287.20 -287.2	2.5 2.635	X T	14.827 16.474 0.0	120 120 -0.2028	64.972 0.0 -6.568		Vel = 16.90	
R33			0.0 -287.20					58.404		K Factor = -37.58	
34 to R34	45.500 45.500		-287.58 -287.58	2.5 2.635	X T	14.827 16.474 0.0	120 120 -0.2033	65.061 0.0 -6.583		Vel = 16.92	
R34			0.0 -287.58					58.478		K Factor = -37.61	
35 to R35	45.500 45.500		-287.93 -287.93	2.5 2.635	X T	14.827 16.474 0.0	120 120 -0.2037	65.254 0.0 -6.598		Vel = 16.94	
R35			0.0 -287.93					58.656		K Factor = -37.60	
36 to R36	45.500 45.500		-60.09 -60.09	2.5 2.635	X T	14.827 16.474 0.0	120 120 -0.0112	65.586 0.0 -0.363		Vel = 3.54	
R36			0.0 -60.09					65.223		K Factor = -7.44	
37 to R37	45.500 45.500		-57.51 -57.51	2.5 2.635	X T	14.827 16.474 0.0	120 120 -0.0104	65.952 0.0 -0.336		Vel = 3.38	
R37			0.0 -57.51					65.616		K Factor = -7.10	
38 to R38	45.500 45.500		-56.55 -56.55	2.5 2.635	X T	14.827 16.474 0.0	120 120 -0.0100	66.350 0.0 -0.325		Vel = 3.33	
R38			0.0 -56.55					66.025		K Factor = -6.96	

Final Calculations : Hazen-Williams

Hydratec Incorporated
BLDG B ALT K25 SYS 16

Page 13
Date 8.23.23

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
39 to R39	45.500 45.500		-57.45 -57.45	2.5 2.635	X T 14.827 16.474 0.0	1.083 31.301 32.384	120 -0.0103	66.810 0.0 -0.335		Vel = 3.38	
R39			0.0 -57.45					66.475		K Factor = -7.05	
40 to R40	45.500 45.500		-59.59 -59.59	2.5 2.635	X T 14.827 16.474 0.0	1.083 31.301 32.384	120 -0.0111	67.307 0.0 -0.358		Vel = 3.51	
R40			0.0 -59.59					66.949		K Factor = -7.28	
41 to R41	45.500 45.500		-63.03 -63.03	2.5 2.635	X T 14.827 16.474 0.0	1.083 31.301 32.384	120 -0.0123	67.845 0.0 -0.397		Vel = 3.71	
R41			0.0 -63.03					67.448		K Factor = -7.67	
42 to R42	45.500 45.500		-67.57 -67.57	2.5 2.635	X T 14.827 16.474 0.0	1.083 31.301 32.384	120 -0.0140	68.428 0.0 -0.452		Vel = 3.98	
R42			0.0 -67.57					67.976		K Factor = -8.20	
43 to R43	45.500 45.500		-72.96 -72.96	2.5 2.635	X T 14.827 16.474 0.0	1.083 31.301 32.384	120 -0.0161	69.061 0.0 -0.520		Vel = 4.29	
R43			0.0 -72.96					68.541		K Factor = -8.81	
44 to R44	45.500 45.500		-78.98 -78.98	2.5 2.635	X T 14.827 16.474 0.0	1.083 31.301 32.384	120 -0.0186	69.750 0.0 -0.602		Vel = 4.65	
R44			0.0 -78.98					69.148		K Factor = -9.50	
13 to 14	45.500 45.500		-60.34 -60.34	4 4.26	0.0 0.0 0.0	9.417 0.0 9.417	120 -0.0011	61.990 0.0 -0.010		Vel = 1.36	
14 to 15	45.500 45.500		-60.49 -120.83	4 4.26	0.0 0.0 0.0	9.417 0.0 9.417	120 -0.0039	61.980 0.0 -0.037		Vel = 2.72	
15 to 16	45.500 45.500		-60.98 -181.81	4 4.26	0.0 0.0 0.0	9.417 0.0 9.417	120 -0.0084	61.943 0.0 -0.079		Vel = 4.09	
16 to 17	45.500 45.500		-62.00 -243.81	4 4.26	0.0 0.0 0.0	9.417 0.0 9.417	120 -0.0144	61.864 0.0 -0.136		Vel = 5.49	
17 to 18	45.500 45.500		281.28 37.47	4 4.26	0.0 0.0 0.0	9.417 0.0 9.417	120 0.0004	61.728 0.0 0.004		Vel = 0.84	
18 to 19	45.500 45.500		281.12 318.59	4 4.26	0.0 0.0 0.0	9.417 0.0 9.417	120 0.0237	61.732 0.0 0.223		Vel = 7.17	

Final Calculations : Hazen-Williams

Hydratec Incorporated
BLDG B ALT K25 SYS 16

Page 14
Date 8.23.23

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
19 to 20	45.500 45.500		281.73 600.32	4 4.26	0.0 0.0 0.0	9.417 0.0 9.417	120 0.0765	61.955 0.0 0.720		Vel = 13.51	
20 to 21	45.500 45.500		-60.10 540.22	4 4.26	0.0 0.0 0.0	9.417 0.0 9.417	120 0.0629	62.675 0.0 0.592		Vel = 12.16	
21 to 22	45.500 45.500		-57.51 482.71	4 4.26	0.0 0.0 0.0	9.417 0.0 9.417	120 0.0511	63.267 0.0 0.481		Vel = 10.87	
22 to 23	45.500 45.500		-56.55 426.16	4 4.26	0.0 0.0 0.0	9.417 0.0 9.417	120 0.0406	63.748 0.0 0.382		Vel = 9.59	
23 to 24	45.500 45.500		-57.45 368.71	4 4.26	0.0 0.0 0.0	10.000 0.0 10.000	120 0.0311	64.130 0.0 0.311		Vel = 8.30	
24 to 25	45.500 45.500		-59.59 309.12	4 4.26	0.0 0.0 0.0	10.000 0.0 10.000	120 0.0224	64.441 0.0 0.224		Vel = 6.96	
25 to 26	45.500 45.500		-63.03 246.09	4 4.26	0.0 0.0 0.0	10.000 0.0 10.000	120 0.0146	64.665 0.0 0.146		Vel = 5.54	
26 to 27	45.500 45.500		-67.57 178.52	4 4.26	0.0 0.0 0.0	10.000 0.0 10.000	120 0.0081	64.811 0.0 0.081		Vel = 4.02	
27 to 28	45.500 45.500		-72.97 105.55	4 4.26	0.0 0.0 0.0	10.000 0.0 10.000	120 0.0031	64.892 0.0 0.031		Vel = 2.38	
28			0.0 105.55					64.923		K Factor = 13.10	
28 to 29	45.500 45.500		26.57 26.57	6 6.357	0.0 0.0 0.0	9.417 0.0 9.417	120 0.0001	64.923 0.0 0.001		Vel = 0.27	
29 to 30	45.500 45.500		60.34 86.91	6 6.357	0.0 0.0 0.0	9.417 0.0 9.417	120 0.0002	64.924 0.0 0.002		Vel = 0.88	
30 to 31	45.500 45.500		60.49 147.4	6 6.357	0.0 0.0 0.0	9.417 0.0 9.417	120 0.0008	64.926 0.0 0.008		Vel = 1.49	
31 to 32	45.500 45.500		60.98 208.38	6 6.357	0.0 0.0 0.0	9.417 0.0 9.417	120 0.0015	64.934 0.0 0.014		Vel = 2.11	
32 to 33	45.500 45.500		62.00 270.38	6 6.357	0.0 0.0 0.0	9.417 0.0 9.417	120 0.0025	64.948 0.0 0.024		Vel = 2.73	
33 to 34	45.500 45.500		287.21 557.59	6 6.357	0.0 0.0 0.0	9.417 0.0 9.417	120 0.0095	64.972 0.0 0.089		Vel = 5.64	

Final Calculations : Hazen-Williams

Hydratec Incorporated
BLDG B ALT K25 SYS 16

Page 15
Date 8.23.23

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
34 to 35	45.500 45.500		287.57 845.16	6 6.357	0.0 0.0 0.0	9.417 0.0 9.417	120 0.0205	65.061 0.0 0.193		Vel = 8.54	
35 to 36	45.500 45.500		287.94 1133.1	6 6.357	0.0 0.0 0.0	9.417 0.0 9.417	120 0.0353	65.254 0.0 0.332		Vel = 11.45	
36 to 37	45.500 45.500		60.09 1193.19	6 6.357	0.0 0.0 0.0	9.417 0.0 9.417	120 0.0389	65.586 0.0 0.366		Vel = 12.06	
37 to 38	45.500 45.500		57.51 1250.7	6 6.357	0.0 0.0 0.0	9.417 0.0 9.417	120 0.0423	65.952 0.0 0.398		Vel = 12.64	
38 to 39	45.500 45.500		56.55 1307.25	6 6.357	0.0 0.0 0.0	10.000 0.0 10.000	120 0.0460	66.350 0.0 0.460		Vel = 13.21	
39 to 40	45.500 45.500		57.46 1364.71	6 6.357	0.0 0.0 0.0	10.000 0.0 10.000	120 0.0497	66.810 0.0 0.497		Vel = 13.80	
40 to 41	45.500 45.500		59.58 1424.29	6 6.357	0.0 0.0 0.0	10.000 0.0 10.000	120 0.0538	67.307 0.0 0.538		Vel = 14.40	
41 to 42	45.500 45.500		63.04 1487.33	6 6.357	0.0 0.0 0.0	10.000 0.0 10.000	120 0.0583	67.845 0.0 0.583		Vel = 15.03	
42 to 43	45.500 45.500		67.57 1554.9	6 6.357	0.0 0.0 0.0	10.000 0.0 10.000	120 0.0633	68.428 0.0 0.633		Vel = 15.72	
43 to 44	45.500 45.500		72.96 1627.86	6 6.357	0.0 0.0 0.0	10.000 0.0 10.000	120 0.0689	69.061 0.0 0.689		Vel = 16.46	
44 to FMJ	45.500 45.500		78.98 1706.84	6 6.357	V 12.573 0.0 0.0	4.000 12.573 16.573	120 0.0752	69.750 0.0 1.247		Vel = 17.25	
FMJ			0.0 1706.84					70.997		K Factor = 202.57	
FMJ to TR2	45.500 45.500		1706.84 1706.84	6 6.357	2V 25.147 0.0 0.0	60.375 25.147 85.522	120 0.0752	70.997 0.0 6.434		Vel = 17.25	
TR2 to BR2	45.500 2		0.0 1706.84	8 8.249	T 41.108 0.0 0.0	38.875 41.108 79.983	120 0.0211	77.431 19.840 1.691		** Fixed Loss = 1 Vel = 10.25	
BR2 to FLG	2 2	H100	100.00 1806.84	8 7.98	L 19.632 0.0 0.0	2.000 19.632 21.632	150 0.0183	98.962 0.0 0.396		Vel = 11.59	
FLG to UG10	2 -5		0.0 1806.84	8 7.98	L 19.632 52.855 0.0	51.125 72.487 123.612	150 0.0183	99.358 3.032 2.259		Vel = 11.59	

Final Calculations : Hazen-Williams

Hydratec Incorporated
BLDG B ALT K25 SYS 16

Page 16
Date 8.23.23

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
UG10			0.0 1806.84						104.649		K Factor = 176.62	
UG7 to UG8	-5 -5		-403.27 -403.27	8 7.98	G	6.041 0.0	483.333 6.040	150	106.265 0.0			
UG8 to UG9	-5 -5		0.0 -403.27	8 7.98	G	6.041 0.0	486.000 492.040	150	105.707 -0.561		Vel = 2.59	
UG9 to UG10	-5 -5	H150	150.00 -253.27	8 7.98	6F 2G	81.548 12.081	937.542 93.630	150	105.146 0.0			
UG10 to UG11	-5 -5		1806.85 1553.58	8 7.98	G	6.041 0.0	242.917 248.957	150	104.649 3.441		Vel = 1.62	
UG11 to NL	-5 -5		0.0 1553.58	12 11.65	G	8.05 0.0	213.250 8.049	150	108.090 0.0		Vel = 9.97	
NL to UG12	-5 -5		0.0 1553.58	12 11.65	2F	34.882 0.0	489.875 34.883	150	108.574 0.0		Vel = 4.68	
UG12 to UG13	-5 -5		-1956.85 -403.27	8 7.98	F G	13.591 6.041	245.208 19.632	150	109.723 0.0			
UG13 to UG14	-5 -5		0.0 -403.27	8 7.98	G	6.041 0.0	457.500 463.540	150	109.421 -0.528		Vel = 2.59	
UG14 to UG15	-5 -5		0.0 -403.27	8 7.98	2F G	27.183 6.041	960.000 33.222	150	108.893 0.0			
UG15 to UG16	-5 -5		0.0 -403.27	8 7.98	4F G	54.365 6.041	648.583 60.405	150	107.760 0.0		Vel = 2.59	
UG16 to UG7	-5 -5		0.0 -403.27	8 7.98	G	6.041 0.0	596.667 602.707	150	106.952 -0.687		Vel = 2.59	
UG7			0.0 -403.27						106.265		K Factor = -39.12	
UG12 to UG6	-5 -5		1956.84 1956.84	12 11.65	6F 3G	104.647 24.149	817.042 209.294	150	109.723 0.0			
UG6 to PUMP	-5 2		0.0 1956.84	12 11.65	2L	48.299 0.0	45.500 48.298	150	113.167 -3.032		Vel = 5.89	
PUMP to PO	2 2		0.0 1956.84	10 10.42	2V S B	10.89 66.551 22.99	15.000 100.431 115.431	120	110.450 0.0		Vel = 5.89	
								0.0087	1.008		Vel = 7.36	

Final Calculations : Hazen-Williams

Hydratec Incorporated
BLDG B ALT K25 SYS 16

Page 17
Date 8.23.23

Node1	Elev1	K	Qa	Nom	Fitting or		Pipe Ftngs	CFact	Pt Pe	*****	Notes	*****
to												
Node2	Elev2	Fact	Qt	Act	Equiv	Len	Total	Pf/Ft	Pf			
			0.0									
PO			1956.84					111.458	K Factor = 185.35			