



REINFORCEMENT SCHEDULE	
R1	#5 BARS @ 10" O.C. VERT.
	#4 BARS @ 8" O.C. HORIZ.
R2	#5 BARS @ 8" O.C. VERT.
	#4 BARS @ 12" O.C. HORIZ.
R3	#5 BARS @ 12" O.C. VERT.
	#4 BARS @ 10" O.C. HORIZ.
R4	#4 BARS @ 12" O.C. VERT.
	#4 BARS @ 2" O.C. HORIZ.
R5	#5 BARS @ 10" O.C. VERT.
	#4 BARS @ 12" O.C. HORIZ.
R6	#5 BARS @ 10" O.C. VERT.
	#4 BARS @ 10" O.C. HORIZ.
R7	#5 BARS @ 12" O.C. VERT.
	#4 BARS @ 10" O.C. HORIZ.

SOUTH ELEVATION (8 1/2" PANEL TYP. U.N.O.)

SCALE: 1/8" = 1'-0"  
(LOOKING FROM INSIDE OF BUILDING ALONG COLUMN LINE C)  
NOTES:

- NOTES:
1. VERIFY ALL PANEL AND OPENING DIMENSIONS W/GENERAL CONTRACTOR & ARCHITECT PRIOR TO CASTING PANELS W/DOORS AND WINDOWS.
  2. PROVIDE 1-H5 E.F. AROUND PERIMETER OF PANEL U.N.O.
  3. CONTINUE REINFORCING THROUGH KNOCK-OUT OPENINGS.
  4. BLOCKING AT TOP OF WALL TO REMAIN AFTER CONSTRUCTION OF PANELS.
  5. HORIZONTAL STEEL CONTINUES THROUGH PANEL LEGS AT ALL OPENINGS.