

**84 CHALET ROAD
KIAMESHA LAKE, NY 12751**

© 2019 JCJ Architecture

CONSULTANTS:



1 PROVIDE ONE (1) 4" CONDUIT FROM PAD MOUNTED TRANSFORMER (BY OTHERS). VERIFY EXACT LOCATION IN FIELD. STUB CONDUIT UP AT PANEL BOARD.

NOT FOR CONSTRUCTION

ISSUE	11/08/2019
JOB	H18064.00 PHASE 14
DRAWN	DSL
SCALE	1/4" = 1'-0"

REVISIONS:

E-110