

**84 CHALET ROAD
KIAMESHA LAKE, NY 12751**

© 2019 JCJ Architecture

CONSULTANTS:



LUMINAIRE SCHEDULE											
TYPE	DESCRIPTION	MFGR. & CATALOG No.	LAMP	DRIVER VOLTAGE	UNIT WATTS	COLOR TEMP [K]	MOUNTING	DIMMING	LOCATION	REMARKS	
D01	4-1/2" SQUARE DOWNLIGHT. INTEGRAL DIFFUSE LENS. ALUMINUM SQUARE DIE-CAST BAFFLE TRIM. WHITE FINISH	LITHONIA: 6JBK-3Q-30K-90CRI-MW OR APPROVED EQUAL.	90 CRI 770 LUMEN LED MODULE	120V	11W	3000K	RECESSED	NO	LOCKER ROOMS	--	
EM01	EMERGENCY BATTERY PACK FIXTURE. INTEGRAL NI-CAD BATTERY. MIN 90 MINUTE.	LITHONIA: EU2L OR APPROVED EQUAL.	LED	120-277V	1W	--	WALL SURFACE	--	ALL	PROVIDE ADDITIONAL REMOTE HEADS WHERE SHOWN.	
EX01	THERMOPLASTIC LED EXIT SIGN. INTEGRAL 90 MINUTE MINIMUM BATTERY.	LITHONIA: EATON, OR APPROVED EQUAL.	RED LED	120-277V	5W	--	AS SHOWN	--	ALL		
F01	1"x4" LINEAR LOW BAY FIXTURE. ENAMEL FINISH. DAMP LOCATION LISTED.	LITHONIA: MS SERIES MSL-8000LM-SBL-MVOLT-XX-40K-80CRI OR APPROVED EQUAL.	80 CRI, 8000 LUMEN LED MODULE	277V	75W	4000K	SURFACE OR PENDANT	NO	EQUIPMENT STORAGE	REFER TO ARCHITECTURAL RCP FOR MOUNTING HEIGHT.	
F02	2"x4" FLAT LED PANEL.	LITHONIA: CPX LED SERIES CPX-2X2-3200-35K-M4 OR APPROVED EQUAL.	80 CRI, 3200 LUMEN LED MODULE	120-277V	30W	3500K	RECESSED	NO	OFFICES	PROVIDE SURFACE MOUNT ADAPTER WHERE NECESSARY.	
S01	20" SITE LIGHTING FIXTURE. INTEGRAL PHOTOCELL. TYPE V DISTRIBUTION	LITHONIA: D-SERIES OR APPROVED EQUAL.	11000 LUMEN MODULE	120-277V	102W	4000K	POLE	NO	SITE EXTERIOR	--	
S02	EXTERIOR WALL MOUNTED LED SITE FIXTURE. INTEGRAL PHOTOCELL. TYPE IV DISTRIBUTION	LITHONIA: D-SERIES OR APPROVED EQUAL.	10000 LUMEN MODULE	120-277V	71W	4000K	EXTERIOR WALL	NO	EXTERIOR	--	
W01	EXTERIOR WALL MOUNTED LED WALL PACK. REFRACTIVE GLASS LENS. INTEGRAL PHOTOCELL. INTEGRAL EMERGENCY BATTERY FIXTURE.	LITHONIA: WST LED SERIES OR APPROVED EQUAL.	6000 LUMEN MODULE	120-277V	51W	4000K	EXTERIOR WALL	NO	EXTERIOR	--	

GENERAL NOTES:

- A. ALL DEVICES PROVIDED BY THE DIVISION 16 CONTRACTOR.
- B. ITEM NUMBER INDICATES EQUIPMENT NUMBER
- C. ALL DEVICES SHALL BE SURFACE MOUNTED UNLESS OTHERWISE NOTED.
- D. PROVIDE OVERLOADS, SIZE AS REQUIRED, BY THE DIVISION 15 CONTRACTOR.
- E. "AU" INDICATES CONTROL DEVICES IS LOCATED AT THE UNIT.
- F. "NF" INDICATES NON-FUSED.
- G. "IU" INDICATES INTEGRAL WITH UNIT.

NOT FOR CONSTRUCTION

ISSUE	11/08/2019
JOB	H18064.00 PHASE 14
DRAWN	DSL
SCALE	1/8" = 1'-0"

REVISIONS:

A vertical column of 10 upward-pointing triangles, each containing a horizontal line, serving as a guide for revisions.

E-113