	PIPE SCHEDULE	
	PIPE SIZE	# OF HEADS
	1"	1
	1-1/4"	2-3
	1-1/2"	4-5
	2"	6-10
THE CIZEC INDICATED ABOVE		

THE SIZES INDICATED ABOVE ARE BASED ON PRELIMINARY HYDRAULIC CALCULATIONS. THE FIRE PROTECTION CONTRACTOR SHALL PERFORM FINAL CALCULATIONS ON THE COORDINATED SYSTEM DESIGN TO VERIFY SIZES PRIOR TO COMMENCING WORK.

FIRE PROTECTION SYMBOL LIST		
SYMBOL	DESCRIPTION	
FC	FLUSHING CONNECTION	
	NEW PIPING	
— FP ——	FIRE PROTECTION SERVICE (FP)	
<u> </u>	SPRINKLER MAIN/BRANCH PIPING (S)	
—D—	SPRINKLER DRAIN PIPING (D)	
	ELBOW DOWN	
	ELBOW UP	
	BOTTOM/TEE CONNECTION	
<u> </u>	TOP TEE CONNECTION	
——	PIPE CONTINUATION	
	FLUSHING CONNECTION	
•	PENDENT SPRINKLER	
(•)	CONCEALED PENDENT SPRINKLER	
0	UPRIGHT SPRINKLER	
<u> </u>	DRAIN VALVE	
<u> </u>	CHECK VALVE	
<u> </u>	PRESSURE REDUCING VALVE	
<u></u>	RELIEF VALVE	
	BACKFLOW PREVENTER (BFP)	
Ø X	SHUT-OFF VALVE WITH TAMPER SWITCH (TS)	
厚	FLOW SWITCH (FS)	
	ALARM CHECK VALVE WITH TRIM (ACV)	
\bowtie	FIRE DEPARTMENT VALVE (FDV)	
_	WATER MOTOR GONG	
****	FIRE DEPARTMENT CONNECTION (FDC)	
+	INSPECTOR'S TEST CONNECTION (ITC)	
₩ ₩	FIRE HYDRANT (FH)	
X	DRAWING KEYNOTE	

RW Monster Golf Clubhouse Building


84 CHALET ROAD KIAMESHA LAKE, NY 12751

JCJARCHITECTURE

120 HUYSHOPE AVENUE SUITE 400 HARTFORD, CT 06106 860.247.9226

© 2019 JCJ Architecture

CONSULTANTS:



ISSUE __11/08/2019 JOB __H18064.00 PHASE 14__ DRAWN EAS SCALE NOT TO SCALE

DETAILS, SCHEDULES AND SYMBOL LIST - FIRE PROTECTION

FP-001