| PIPE SCHEDULE | | |
|---------------------------|------------|--|
| PIPE SIZE | # OF HEADS | |
| 1" | 1 | |
| 1-1/4" | 2-3 | |
| 1-1/2" | 4-5 | |
| 2" | 6-10 | |
| THE SIZES INDICATED ABOVE | | |

THE SIZES INDICATED ABOVE ARE BASED ON PRELIMINARY HYDRAULIC CALCULATIONS. THE FIRE PROTECTION CONTRACTOR SHALL PERFORM FINAL CALCULATIONS ON THE COORDINATED SYSTEM DESIGN TO VERIFY SIZES PRIOR TO COMMENCING WORK.

| FIRE PROTECTION SYMBOL LIST | | |
|-----------------------------|--|--|
| SYMBOL | DESCRIPTION | |
| FC | FLUSHING CONNECTION | |
| | NEW PIPING | |
| —— FP —— | FIRE PROTECTION SERVICE (FP) | |
| s | SPRINKLER MAIN/BRANCH PIPING (S) | |
| D | SPRINKLER DRAIN PIPING (D) | |
| | ELBOW DOWN | |
| | BOTTOM/TEE CONNECTION | |
| <u> </u> | TOP TEE CONNECTION | |
| | PIPE CONTINUATION | |
| | FLUSHING CONNECTION | |
| • | PENDENT SPRINKLER | |
| (•) | CONCEALED PENDENT SPRINKLER | |
| 0 | UPRIGHT SPRINKLER | |
| | DRAIN VALVE | |
| - V- | CHECK VALVE | |
| ₹ I→ | RELIEF VALVE | |
| | BACKFLOW PREVENTER (BFP) | |
| ⊗ | SHUT-OFF VALVE WITH TAMPER SWITCH (TS) | |
| F§ | FLOW SWITCH (FS) | |
| | ALARM CHECK VALVE WITH TRIM (ACV) | |
| - | WATER MOTOR GONG | |
| *** | FIRE DEPARTMENT CONNECTION (FDC) | |
| | INSPECTOR'S TEST CONNECTION (ITC) | |
| (X) | DRAWING KEYNOTE | |
| | | |

RW Monster Golf Maintenance Building


84 CHALET ROAD KIAMESHA LAKE, NY 12751

JCJARCHITECTURE

120 HUYSHOPE AVENUE SUITE 400 HARTFORD, CT 06106 860.247.9226

© 2019 JCJ Architecture

CONSULTANTS:



ISSUE __11/08/2019 **JOB** __H18064.00 PHASE 14__ SCALE NOT TO SCALE

DETAILS, SCHEDULES AND SYMBOL LISTS - FIRE PROTECTION

FP-002