

1 CART STORAGE BUILDING - FIRST FLOOR PLAN - HVAC
1/8" = 1'-0"

UNIT HEATER SCHEDULE - GAS(LP)

UNIT NO.	LOCATION	TYPE	AIR SIDE			GAS			EFFICIENCY		FAN MOTOR				MOUNTING	THROW	MANUFACTURER & MODEL No.	REMARKS
			AIR FLOW (CFM)	ENT. AIR TEMP. (DEG. F)	LVG. AIR TEMP. (DEG. F)	INPUT CAPACITY (BTUH)	OUTPUT CAPACITY (BTUH)	MIN. GAS PRESS BEFORE REGULATOR (In. WC)	MIN (%)	TEST PROCEDURE	RPM	HP	VOLTS	PHASE	HEIGHT (Ft.-In.)	(Ft.)		
UH-1	CART STORAGE	HORIZONTAL	990	70.0	120.0	60,000	49,200	-	82.0	ANSI Z83.8	-	-	-	-	9.0	36.0	MODINE MODEL HD60	-
UH-2	CART STORAGE	HORIZONTAL	990	70.0	120.0	60,000	49,200	-	82.0	ANSI Z83.8	-	-	-	-	9.0	36.0	MODINE MODEL HD60	-
UH-3	CART STORAGE	HORIZONTAL	990	70.0	120.0	60,000	49,200	-	82.0	ANSI Z83.8	-	-	-	-	9.0	36.0	MODINE MODEL HD60	-
UH-4	CART STORAGE	HORIZONTAL	990	70.0	120.0	60,000	49,200	-	82.0	ANSI Z83.8	-	-	-	-	9.0	36.0	MODINE MODEL HD60	-

WALL HEATER SCHEDULE - ELECTRIC

UNIT NO.	LOCATION	TYPE	AIR FLOW (CFM)	CAPACITY (MBH)	ELEC CHARACTERISTICS			MANUFACTURER & MODEL No.	REMARKS
					CAPACITY (KW)	VOLTS	PHASE		
EWH-1	ICE ROOM	WALL MOUNTED	65	5.12	1.50	240	1	Q-MARK MODEL CWH1207DSAF	-

REMARKS:
1. PROVIDE SURFACE MOUNTING FRAME KIT.

RW Monster Golf Cart Storage Building

84 CHALET ROAD
KIAMESHA LAKE, NY 12751

JCJARCHITECTURE
120 HUYSHOPE AVENUE
SUITE 400
HARTFORD, CT 06106
860.247.9226

© 2019 JCJ Architecture

CONSULTANTS:

NOT FOR CONSTRUCTION

P.I.C. L.D.
P.M. P.A.

ISSUE 11/08/2019
JOB H18064.00 PHASE 14
DRAWN LEL
SCALE 1/8" = 1'-0"

REVISIONS:

FLOOR PLAN & SCHEDULES - HVAC

M-110