

**84 CHALET ROAD
KIAMESHA LAKE, NY 12751**

© 2019 JCJ Architecture

CONSULTANTS:



PACKAGED ENERGY RECOVERY VENTILATION UNIT SCHEDULE - STATIC PLATE CORE HEAT EXCHANGER																										
UNIT NO.	LOCATION	SERVICE	MODE	SUPPLY FAN				EXHAUST FAN				ELECTRICAL CHARACTERISTICS				TOTAL EFF. (%)	PERFORMANCE CONDITIONS (DEG. F)								MANUFACTURER & MODEL No.	REMARKS
				AIR FLOW (CFM)	E.S.P. (In. W.C)	T.S.P. (In. W.C)	HP	AIR FLOW (CFM)	E.S.P. (In. W.C)	T.S.P. (In. W.C)	HP	VOLTS	PHASE	MCA	MOP		O.A.		R.A.		S.A.		E.A.			
																	DB	WB	DB	WB	D	WB	DB	WB		
ERV-M1	EQUIPMENT STORAGE XA11	OFFICE AREA	SUMMER	500	0.75	0.78	0.50	500	0.75	0.78	0.50	208	1	8.5	15.0	-	86.5	74.8	75.0	62.4	78.4	68.5	83.0	69.6	GREENHECK MODEL MINICORE-10-VG-FM	-
			WINTER														2.7	1.0	70.0	54.2	48.1	38.9	23.5	62.9		

ISSUE	11/08/2019
JOB	H18064.00 PHASE 14
DRAWN	LEL
SCALE	1/8" = 1'-0"

FIRST FLOOR PLAN AND SCHEDULES - HVAC