



- 1 CONNECT TO LIGHTING CIRCUIT SERVING THIS ROOM AHEAD OF ANY LOCAL SWITCHING.
- 2 CONNECT EXIT SIGN TO EMERGENCY LIGHTING CIRCUIT SERVING THIS BUILDING AHEAD OF ANY LOCAL SWITCHING.

**84 CHALET ROAD
KIAMESHA LAKE, NY 12751**

120 HUYSHOPE AVENUE
SUITE 400
HARTFORD, CT 06106
860.247.9226

MEP & FP ENGINEER
M/E ENGINEERING
60 LAKEFRONT BOULEVARD, SUITE 320
BUFFALO, NY 14202
716.845.5092

AKRF ENGINEERING
34 SOUTH BROADWAY, SUITE
WHITE PLAINS, NY 10601
914-949-7336

LUMINARE SCHEDULE

- A. ALL DEVICES PROVIDED BY THE DIVISION 16 CONTRACTOR.
- B. ITEM NUMBER INDICATES EQUIPMENT NUMBER
- C. ALL DEVICES SHALL BE SURFACE MOUNTED UNLESS OTHERWISE NOTED.
- D. PROVIDE OVERLOADS, SIZE AS REQUIRED, BY THE DIVISION 15 CONTRACTOR.
- E. "AU" INDICATES CONTROL DEVICES IS LOCATED AT THE UNIT.
- F. "NF" INDICATES NON-FUSED.
- G. "IU" INDICATES INTEGRAL WITH UNIT.

PERMIT SET
09/30/2021



.JOB H18064.14

SCALE 1/8" = 1'-0"

REVISIONS:

A vertical column of 10 upward-pointing triangles, each containing a number from 1 to 10, used for tracking revisions.

E-113