



PAVARINI

Request For Information

9/18/2023

To: Ed Arcari

RE: Halle Building Gymnasium Alterations

- RFI # 1 Please provide the trade labor status for this project,
Open shop, Prevailing wage or Union.
OPEN SHOP
- RFI #2 Are there any MBE/WBE requirements? **NO**
- RFI # 3 Is there's an existing BMS system we are tying into? **NO BMS, NOT ATC. STAND ALONG THERMOSTATS**
If yes please provide contact information.
If no please provide an ATC spec and sequence of operations
- RFI # 4 To what extent do they want duct liner on the rectangular duct work.
ROOFTOP EQUIPMENT 10' SUPPLY AND RETURN
INTERIOR UNITS 5' SUPPLY AND RETURN
- RFI # 5 What kind of round ductwork do they want where it is
exposed? Spiral Seam? **ROUND NO INSULATION AND NO LINER.**
JUST LINED INTO BUILDING FROM SOUND TRAP
- RFI # 6 The specifications talk about concealed duct work
insulation, what about exposed duct insulation?
NO INSULATION ON EXPOSED DUCTWORK IN GYM