



- NOTES:**
- REFER TO DRAWING G1 FOR SYMBOLS AND ABBREVIATIONS.
  - REFER TO DRAWING E5 FOR SWITCHBOARD AND PANELBOARD SCHEDULES.
  - CIRCUIT NUMBERS CORRESPOND TO RESPECTIVE CIRCUIT BREAKER IN PANELS AS INDICATED BELOW:  
  
MDP#1/3 - DENOTES CIRCUITS 1 AND 3 IN NEW 208/120V, 3 $\phi$  SWITCHBOARD 'MDP'  
  
UP#1 - DENOTES CIRCUIT 1 IN NEW 208/120V, 3 $\phi$  UTILITY PANELBOARD 'UP'
  - SURGE ARRESTOR SHALL BE MODEL 200LS AS MANUFACTURED BY MCG SURGE PROTECTION, OR APPROVED EQUAL.
  - FAN/DUCT HEATER CONTROLS:  
a. GENERAL CONTRACTOR SHALL BE RESPONSIBLE FOR CONTROL CONDUIT AND WIRING TO THERMOSTAT(S) AND DUCT HEATER. REFER TO GC DRAWINGS.

3/16"=1'-0" 6 4 2 0 5'

NO.	DATE	REVISION	INT.

UNAUTHORIZED ALTERATION OR ADDITION TO THIS DOCUMENT IS A VIOLATION OF SECTION 7209 OF THE NEW YORK STATE EDUCATION LAW.			
PROJECT ENGINEER:		DRAWN BY:	
AE		TW/JQ	
DESIGNED BY:		CHECKED BY:	
MN		MN	



TOWN OF BLOOMING GROVE	
ORANGE COUNTY	NEW YORK
LASSER PARK SENIOR CENTER	

CONTRACT 2
BASEMENT
POWER PLAN
ELECTRICAL

PROJECT NO.
5708
DATE:
AUGUST 2023
SCALE:
3/16" = 1'-0"

E3