

UNIT VENTILATORS

EQUIPMENT NO. UV-X	NOMINAL TONNAGE	ASSOCIATED CONDENSER	PERFORMANCE/ CONSTRUCTION REQUIREMENTS									
			SUPPLY FAN			OUTSIDE AIR FLOW (CFM)	COOLING COIL				FILTERS	
			AIR FLOW / FAN SPEED (CFM)	MOTOR POWER (HP)	MOTOR TYPE		TOTAL CAPACITY (MBH)	SENSIBLE CAPACITY (MBH)	REFRIGERANT TYPE	AIR DATA		TYPE
										EAT DB/WB (°F)	LAT DB/WB (°F)	
1-5, 2-3, 2-4, 4-2, 4-4, 4-7, 5-3, 6-4, 6-5, 6-6, 7-1	2.0	SEE PLANS	750	0.333	ECM - VARIABLE	SEE VENT INDEX	22.9	17.2	R-410A	80 / 67	58.8 / 57.5	1" THROWAWAY
1-1, 1-2, 1-3, 1-4, 2-5, 3-2, 3-5, 4-3, 5-5, 6-1, 6-2	2.5	SEE PLANS	1000	0.333	ECM - VARIABLE	SEE VENT INDEX	33.2	24.9	R-410A	80 / 67	56.6 / 56.0	1" THROWAWAY
3-1, 3-3, 3-4, 4-5, 4-6, 5-1, 5-2, 5-4, 5-6, 7-2, 7-3, 7-4, 7-5	3	SEE PLANS	1250	0.333	ECM - VARIABLE	SEE VENT INDEX	43.4	32.6	R-410A	80 / 67	55.2 / 55.2	1" THROWAWAY
1-6, 2-1, 2-2, 4-1, 6-3	4	SEE PLANS	1500	0.333	ECM - VARIABLE	SEE VENT INDEX	53.7	40.3	R-410A	80 / 67	54.3 / 54.3	1" THROWAWAY