

DEPARTMENT OF GENERAL SERVICES, PURCHASING DIVISION

Dr. Robert L. Yeager Health Center
50 Sanatorium Rd, Building A
Pomona, New York 10970
Phone: (845) 364-3820 Fax: (845) 364-3809
Email: purchasing@co.rockland.ny.us

Paul Brennan, FNIGP, NIGP-CPP, CPPO
Director of Purchasing

ADDENDUM # 6

RFB-RC-2024-049

**Management Services and Capital Improvements at the Advanced
Wastewater Treatment Plant in Hillburn, NY**

The information in this addendum supersedes any contradictory information set forth in the contract documents. Acknowledge receipt of this addendum in the space provided on the signature page of the bid proposal. Failure to do so, may subject the bidder to disqualification. This addendum forms a part of the contract documents.

Item No. 1:

Replace the ICI Price Proposal Form for ICI No. 6 with Attachment A of this Addendum.

Item No. 2:

QUESTIONS

1. Addendum No. 4 amended ICI No. 6 to include the replacement of 81 CU FT of Carbon Media. However, upon contacting the manufacturer to obtain a quote, it was discovered that the plant has 843 CU FT of Carbon Media. Is the intent to only replace 81 CU FT of Carbon Media or 843 CU FT of Carbon Media? Clarification is needed.

Response: The intent is to replace all of Carbon Media. The furnished volume of carbon media in the ICI price proposal form has been updated to reflect the total amount (843 Cu Ft). (See attached)

SIGNED:

Paul J. Brennan

PAUL J. BRENNAN, FNIGP, NIGP-CPP, CPPO
DIRECTOR OF PURCHASING

ATTACHMENT A

ICI PRICE PROPOSAL FORM

FIXED DESIGN-BUILD PRICE FOR EACH INDIVIDUAL ICI IN EACH SUBGROUP

ICI No. 6

Odor Control System Carbon & Air Piping

SUMMARY OF FIXED DESIGN-BUILD PRICE

COST

Construction Work

Furnish Carbon (Volume: 843 cu ft) \$ _____

Install Carbon \$ _____

Furnish and Install Air Distribution Piping \$ _____

Total \$ _____