



Addendum

Wallkill Central School District
Wallkill, New York

SED NO. 62-18-01-06-0-005-018

Reconstruction to
Plattekill Elementary School

Tt Project No. 17597-22002 – Phase 2B

BID Addendum No. 2
to
Drawings and Project Manual

October 23, 2024

To: ALL BIDDERS

This ADDENDUM forms a part of the BIDDING AND CONTRACT DOCUMENTS and modifies the following documents:
Original DRAWINGS dated December 18, 2023.
PROJECT MANUAL dated December 18, 2023 and BID ADDENDUM NO. 1 dated October 21, 2024.

Acknowledge receipt of the ADDENDUM in the space provided on the FORM OF PROPOSAL

This ADDENDUM consists of (1) page and the following:

ATTACHMENTS

PRE-BID REQUEST FOR INFORMATION QUESTIONS/ANSWERS

PROJECT MANUAL MODIFICATIONS - PLUMBING

ITEM 2-C-1: Refer to SECTION 33 11 13 – POTABLE WATER SUPPLY WELLS

1. Paragraph 2.6, ADD the following:

“8. Test Kits:

- a. Provide 1 LaMotte SMART 2 Colorimeter with low-range phosphate test. LaMotte Company, Chestertown, Maryland 800-344-3100.
- b. Provide 1 Pulsafeeder Part No. 30260 chlorine residual kit testing pH and Chlorine residual from 0- 10 ppm and deliver to owner and obtain written receipt. Send copy of receipt to Architect.
- c. Provide 1 set of spare parts for parts subject to normal where to owner and obtain written receipt.”

END OF ADDENDUM



INSTRUCTIONS TO BIDDERS
ATTACHMENT #1:
PRE-BID REQUEST FOR INTERPRETATION FORM

SUBMIT FORM BY EMAIL TO INE.Walkill@tetrattech.com

Project No.: 17597-22002B

Date: 10/22/2024

Project Name: Reconstruction to Plattekill Elementary School

Bidder Contact Person: Eric DeRise
Bidder Company Name: S&O Construction Services
Bidder Phone: 845-635-2916
Bidder Email Address: ederise@soconserv.com

Question Pertains to:

Drawing Number:
Plan Area:
Room Number:
Drawing Detail Number:
Specification Section: 223200

Question: (Please be specific)

Thanks for providing spec 223200 in Addendum #1. However, the supplier is requesting more information to provide the best price:

- (1) Can you please provide a spec on the chemical feed pumps and pulse meters that activate the pumps?
- (2) Can you provide a spec on the test kits?

Review by Architect/Engineers: _____ **Responded By:** GPD **Date:** 10/22/24

Please refer to Section 33 11 13 - Potable Water Supply Wells and BID Addendum No. 2.

Submit requests not less than 5 working days prior to the specified Bid Opening date and time. In the event that this question requires clarification or modification of the Bidding Documents, such written information can only be provided by formal Addendum, distributed to all plan holders.