







28K SP1
SCALE: NONE




28K SP5
SCALE: NONE




30K SP3
SCALE: NONE



28K SP2
SCALE: NONE




28K SP6
SCALE: NONE




30K SP4
SCALE: NONE


NOTES:
1. JOIST MANUFACTURER TO ACCOUNT FOR AN ADDITIONAL ADD LOAD (150 LBS FOR 6" MAIN) AT EACH LOCATION ESFR MAIN RUNS PERPENDICULAR TO JOIST (COORDINATE LOCATION WITH ESFR DRAWINGS).



28K SP3
SCALE: NONE




30K SP1
SCALE: NONE




30K SP5
SCALE: NONE


NOTES:
1. JOIST MANUFACTURER TO ACCOUNT FOR AN ADDITIONAL ADD LOAD (150 LBS FOR 6" MAIN) AT EACH LOCATION ESFR MAIN RUNS PERPENDICULAR TO JOIST (COORDINATE LOCATION WITH ESFR DRAWINGS).




28K SP4
SCALE: NONE



30K SP2
SCALE: NONE



30K SP6
SCALE: NONE



SUBMITTALS		
NO.	DATE	DESCRIPTION
12-04-23		COORDINATION SET
12-08-23		75% PROGRESS SET
01-26-24		90% PROGRESS SET
02-09-24		PERMIT SET