


**General Notes**

A. REFER TO AM050 FOR GENERAL NOTES.

**Keyed Notes**

- ① INSTALL CONDENSING UNIT ON EXISTING SUPPORTS SYSTEM.
- ② RS/RL UP TO RCU. VERIFY LINE SIZE WITH UNIT MANUFACTURER. 1" CD UP FROM BELOW. SEE DETAIL 11/AM500 FOR ADDITIONAL INFORMATION.



S.E.D. Control No. 62-18-01-06-0-007-019

Rev. No.	Date	Description

complex world | CLEAR SOLUTIONS

Tetra Tech Engineers, Architects & Landscape Architects, P.C.

**WALKKILL**  
CENTRAL SCHOOL DISTRICT

**BID SET**

**TETRA TECH**  
ARCHITECTS & ENGINEERS

Walkkill Central School District  
Walkkill, New York

Reconstruction to:  
Walkkill Senior High School

Roof Plans - Partial Area D

Drawn By: JPF1/pgm	Date: 06/30/2023	Drawing Number:
Project No.:	AM105	
17597-22002		