


- Keyed Notes:**
- 1 PROVIDE (3)W30, (1)W6G IN 2" C. TO MDP. PROVIDE 200A, 208V, 3P BREAKER
 - 2 PROVIDE (3)W12, (1)W12G IN 1/2" C. TO PANEL GP. PROVIDE 20A, 208V, 3P BREAKER
 - 3 PROVIDE (2)W12, (1)W12G IN 1/2" C. TO PANEL GP. PROVIDE 20A, 120V, 1P BREAKER
 - 4 PROVIDE FAN SHUTDOWN AND DUCT SMOKE DETECTOR. CONNECT TO EXISTING FIRE ALARM CIRCUITS. PROVIDE REQUIRED TESTING AND PROGRAMMING.
 - 5 PROVIDE FAN SHUTDOWN AND CONNECT TO EXISTING FIRE ALARM CIRCUIT. PROVIDE REQUIRED TESTING AND PROGRAMMING.
 - 6 RECONNECT REINSTALLED EQUIPMENT TO CIRCUIT PREVIOUSLY SAFEGUARDED FOR REUSE.

- General Notes:**
- A. REFER TO DRAWING AE050 FOR GENERAL NOTES
 - B. REFER TO AE600 PANEL BOARD SCHEDULES FOR ADDITIONAL INFORMATION



S.E.D. Control No. 62-18-01-06-0-007-019

Rev. No.	Date	Description



complex world | CLEAR SOLUTIONS

Tetra Tech Engineers, Architects & Landscape Architects, P.C.

BID SET



Walkkill Central School District
Walkkill, New York

Reconstruction to:
Walkkill Senior High School

Roof Power Plan - Area B

Drawn By: GLK/ded	Date: 06/30/2023	Drawing Number:
Project No.:	AE165	
17597-22002		

1 Partial Roof Plan - Area B
1/8" = 1'-0"