



General Notes

A. REFER TO BM051 FOR GENERAL NOTES.

Keyed Notes

1

INSTALL FTR TIGHT (<1") TO CEILING. DIRECT OPEN ENDED DUCT TO DISCHARGE DIRECTLY INTO FTR ENCLOSURE. BALANCE TO 50 CFM.

2

3/4" HWS/R DOWN TO SERVE FTR.

3

INSTALL FTR HIGH ON WALL UPSIDE DOWN AND TIGHT TO CEILING. ~2" FROM CEILING. COORDINATE WITH LOCKERS.
RUN DUCT BETWEEN JOISTS.

A

B

Key Plan

N.T.S.

S.E.D. Control No. 62-18-01-06-0-002-015

Rev. No.	Date	Description

WALKKILL

CENTRAL SCHOOL DISTRICT

complex world

CLEAR SOLUTIONS

Tetra Tech Engineers, Architects & Landscape Architects, P.C.

BID SET

TETRA TECH

ARCHITECTS & ENGINEERS

Walkkill Central School District
Walkkill, New York

Reconstruction to:
John G. Borden Middle School

Partial First Floor Plan

Drawn By: JPF/jgm
Date: 06/30/2023
Project No.: 17597-22002

Drawing Number:
BM130