



Key Plan
N.T.S.

S.E.D. Control No. 62-18-01-06-0-002-015

Rev. No.	Date	Description

Plumbing Fixture Schedule									
DWG LABEL	ROUGH-IN CONNECTION SIZE (INCHES)				BARRIER FREE	AGE GROUP	RIM HEIGHT	DESCRIPTION	NOTES
	SAN	VENT	CW	HW					
WC "C"	4	2	1	-	NO	ADULT	15"	VITREOUS CHINA, WALL MOUNTED WITH SUPPORT, TOP SPUD, BATTERY OPERATED SENSOR FLUSH VALVE AND SEAT.	1, 2, 3
WC "D"	4	2	1	-	YES	ADULT	17"	ACCESSIBLE, VITREOUS CHINA, WALL MOUNTED WITH SUPPORT, TOP SPUD, BATTERY OPERATED SENSOR FLUSH VALVE AND SEAT.	1, 2, 3
UR "A"	2	1 1/2	3/4	-	NO	ADULT	24"	VITREOUS CHINA, WALL MOUNTED WITH SUPPORT, TOP SPUD AND BATTERY OPERATED SENSOR FLUSH VALVE.	1, 2, 3
UR "B"	2	1 1/2	3/4	-	YES	ADULT	17"	ACCESSIBLE, VITREOUS CHINA, WALL MOUNTED WITH SUPPORT, TOP SPUD AND BATTERY OPERATED SENSOR FLUSH VALVE.	1, 2, 3
LAV "A"	1 1/2	1 1/2	1/2	1/2	NO	ADULT	31"	VITREOUS CHINA, WALL MOUNTED WITH SUPPORT, MANUAL, TWO-HANDLE COMMERCIAL FAUCET, SUPPLIES, TAILPIECE AND TRAP.	1, 2, 3
LAV "B"	1 1/2	1 1/2	1/2	1/2	YES	ADULT	34"	ACCESSIBLE, VITREOUS CHINA, WALL MOUNTED WITH SUPPORT, ACCESSIBLE, MANUAL, TWO-HANDLE COMMERCIAL FAUCET, SUPPLIES, OFFSET TAILPIECE AND VANDAL RESISTANT TRAP.	1, 2, 3
SHR "C"	-	-	1/2	1/2	YES	ADULT	-	ACCESSIBLE, FACTORY-FABRICATED, SURFACE MOUNTED SHOWER CABINET WITH VALVE ON RIGHT/ SEAT ON LEFT, SEVERE SERVICE HEAD, DIVERTER VALVE, HAND-HELD SHOWER SPRAY, RECESSED SOAP DISH, VERTICAL PIPING SHROUD AND VANDAL RESISTANT SCREWS.	1, 2, 3
EWV "A"	1 1/2	1 1/2	1/2	-	YES	ADULT	-	WALL MOUNTED, ACCESSIBLE, DUAL HEIGHT, PRESSURE WATER COOLER WITH FILTERED BOTTLE FILLING STATION.	1, 2, 3
INT WH	-	-	3/4	-	-	-	-	CONCEALED OUTLET, SELF DRAINING MODERATE CLIMATE WALL HYDRANT.	1, 2
FD "A"	4	2	-	-	-	-	-	MEDIUM DUTY, CAST-IRON FLOOR DRAIN WITH 7" DIAMETER NICKEL BRONZE STRAINER, DEEP-SEAL P-TRAP AND TRAP SEAL DEVICE.	

NOTES:
1. SIZES INDICATED ARE MINIMUM. LARGER SIZES SPECIFICALLY INDICATED ON DRAWINGS SUPERCEDE MINIMUM SIZES INDICATED IN THIS SCHEDULE.
2. PROVIDE TERMINATION STYLE AND SIZE FOR FIXTURE CONNECTIONS AS INDICATED BY FIXTURE MANUFACTURER.
3. REFER TO TOILET ROOM PLANS ON ARCHITECTURE DRAWINGS FOR FIXTURE CENTERLINE DIMENSIONS.

WALKKILL CENTRAL SCHOOL DISTRICT

complex world CLEAR SOLUTIONS

Tetra Tech Engineers, Architects & Landscape Architects, P.C.

BID SET

TETRA TECH ARCHITECTS & ENGINEERS

Walkkill Central School District
Walkkill, New York

Reconstruction to:
John G. Borden Middle School

Details and Schedule

Drawn By: BCL	Date: 06/30/2023	Drawing Number:
Project No.:	17597-22002	
		BP500