

1 WET WELL SECTION

H-005 SCALE: 1/4" = 1'-0"

0' 2' 4'

2 DRY WELL SECTION

H-005 SCALE: 1/4" = 1'-0"

0' 2' 4' 8'

		9	,	1		V.								
	SEALS SEALS OF STATE OF STATE OF APOFE	NEW YOUTH	LEGAL EN ARCADIS (OF NEW YORK, INC		WARNING - IT IS A VIOLATION OF NEW YORK EDUCATION LAW, SECTION 7209.2, FOR ANY PERSON, UNLESS HE IS ACTING UNDER THE DIRECTION OF A LICENSED PROFESSIONAL ENGINEER OR LAND SURVEYOR, TO ALTER THIS DOCUMENT IN ANY WAY. IF ALTERED, THE ALTERING PERSON SHALL COMPLY WITH THE REQUIREMENTS OF NEW YORK LAW, SECTION 7209.2.								
ſ														
ŀ	-					9.5 0								
ł					-									
ł	REVISION NUMBER	DATE	MADE BY	APP'D BY			REVISION	1 10 0 0000						
I				RECC	RD DRAV	VING CERTIFI	ICATION							
I		Larger May 8	HANGES O CHANG	economic III d	D									
Ì	- 22	, CO	ONTRACT	OR			PROJECT COORDINATOR							
١	NAME SIGNATURE			DATE	-	SIGNATURE	NAMESIGNATURE							
						, NEW ND TRANSI	YORK PORTATION	DATE CONTRACT NUMBER 22-526	SHEET NUMBER H-007					
	=		DIVISIO	ON OF I	ENGINEE	CRING		SHEET NO. 72						
					NITARY S		UMPING STATION WER DISTRICT DATE: APRIL 2023 DPW FILE NO.							
		4			2	and the same of		205-03-H-	REV. NO. 113-0					

IN CHARGE OF S. CHHEA
CHECKED BY V. VITALE
MADE BY J. BICHLER

						ELEC	CTRI	C HE	ATER S	CHE	DULE	•							
MARK NO.	LOCATION	SERVICE	MBH	COIL D	ATA V/PH	RPM	TOR D	V/PH	TOTAL AMPS	CFM	EAT (°F)	LAT (°F)	THROW (FT)	DISCHARGE ORIENTATION	MTG. HEIGHT (FT AFF)	WEIGHT (LBS)	MFR	MODEL	NOTES
WVR-EUH-1 THRU 2	DRY WELL	DRY WELL	17.1	5.0	208/3	1,050	1/15	208/1	13.9	405	55	94	12	HORIZONTAL	8	50	CHROMALOX	HD3D	1
WVR-EUH-3 THRU 4	DRY WELL	DRY WELL	17.1	5.0	208/3	1,050	1/15	208/1	13.9	405	55	94	12	HORIZONTAL	7	50	CHROMALOX	HD3D	1
WVR-EUH-5	ELECTRICAL ROOM	ELECTRICAL ROOM	17.1	5.0	208/3	1,050	1/15	208/1	13.9	405	55	94	12	HORIZONTAL	7	50	CHROMALOX	HD3D	1
NOTES:																			
1. DISCONNECT PROVIDED UN	DER ELECTRICAL WORK.																		

						FAN SCI	HEDULE								
		SERVICE	TYPE	DRME	AIRFLOW (CFM)	ESP	SPEED (RPM)	MOTOR DATA				WEIGHT	-		
MARK NO.	LOCATION					(IN. W.G.)		HP	ВНР	RPM	V/PH	(LBS)	MFR	MODEL	NOTES
WVR-SF-1	DRY WELL	DRY WELL	AXIAL INLINE	DIRECT	850	0.50	1750	1/3	0.12	1750	115/1	185	HARTZELL	A39	1,5
WVR-SF-2	OUTSIDE	WET WELL	VANE AXIAL INLINE	DIRECT	1,210	0.50	1160	1/3	0.19	1160	115/1	159	HARTZELL	A29V	1,2,3,4
NOTES: 1. DISCONNECT PR 2. FRP CONSTRUC		R ELECTRICAL		3. WEATH	ER HOOD.	CLASS I DIVIS		5. ALUMIN		ISTRUCTI	ON W/ EF	POXY COATIN	G.		

			· · · · · · · · · · · · · · · · · · ·	GRAVITY VE	NTILAT	OR SCHE	EDULE					Harris and the second s	· · · · · · · · · · · · · · · · · · ·
MARK NO.	LOCATION	SERVICE	TYPE	FUNCTION	AIR FLOW (CFM)	THROAT OPENING (IN)	THROAT AREA (SF)	TIERS (NUMBER)	SP (IN W.C.)	WEIGHT (LB)	MFR	MODEL	NOTES
WVR-SH-1	OUTDOORS	DRY WELL	DOME	INTAKE AIR	850	16.5	5.44	1	0.05	24	LOREN COOK	PR	1
WVR-RH-1	OUTDOORS	DRY WELL	DOME	RELIEF AIR	850	16.5	5.44	1	0.1	24	LOREN COOK	PR	1
NOTES: 1. ALL ALUMINUM C	ONSTRUCTION.												

SEALS OF NEW TODAY TO A TIZE AS BEEN TO THE SEAL OF	LEGAL ENTITY: ARCADIS OF NEW YORK, INC. COPYRIGHT: 2021 ARCADIS PROJECT		7209.2, FOR AN A LICENSED PF DOCUMENT IN COMPLY WITH	S A VIOLATION OF NEW YO. IY PERSON, UNLESS HE IS / ROFESSIONAL ENGINEER O ANY WAY. IF ALTERED, THE THE REQUIREMENTS OF NI	ACTING UNDER THE DIRECT R LAND SURVEYOR, TO A E ALTERING PERSON SHAI	CTION OF LTER THIS LL
	, incondition readed.	100. 001000				
				,		·

1 1)Δ1⊢ 1	MADE APP'D BY			REVISION		
	RECOR	RD DRAWIN	G CERTIFIC	CATION		
AS BUILT - CHA	NGES AS NOTEE)				
NAME	TRACTOR		NAME	PROJECT C	OORDINATOR	2
SIGNATURE	DATE		SIGNATURE TITLE		DATE	
WESTCHES		•		YORK Ortation	CONTRACT NUMBER 22-526	SHEET NUMBER H-008
DEPARTMENT OF	TODITO HOL					
	OIVISION OF EN		NG		SHEET NO. 73	of 103


IN CHARGE OF S. CHHEA CHECKED BY V. VITALE MADE BY J. BICHLER

NOTES

1. VOLUME DAMPERS SHOWN OR SPECIFIED ON THE DRAWINGS ARE IN ADDITION TO DAMPERS SPECIFIED WITH REGISTERS. REGISTER DAMPERS ARE NOT SHOWN ON THE DWGS.

GRILL STUB DUCT DETAIL

NOT TO SCALE




NOTES:


MAINTAIN MANUFACTURER'S MINIMUM CLEARANCE REQUIREMENTS.

UNIT HEATER

ELECTRIC UNIT HEATER MOUNTING DETAIL




VERTICAL DUCT
SUPPORTS FROM WALL DETAIL
NOT TO SCALE




ELECTRICAL WIRING SHALL NOT BE ROUTED THROUGH DUCTWORK.

EXHAUST FAN ON CONCRETE CURB DETAIL
NOT TO SCALE



MESH SCREEN DETAIL

NOT TO SCALE



205-03-H-115-0

DETAILS

N CHARGE OF S. CHHEA

CHECKED BY V. VITALE

MADE BY J. BICHLER

NOT TO SCALE

//AUS-30039047-WCDEF - Pumping Station Rehabilitation/H-3D-WPS.rvt Scale: 12" = 1'-0" D