

DRAFT CONSTRUCTION DOCUMENT - NOT FOR PERMIT OR CONSTRUCTION

Date: September 17, 2024

Revisions

UNAUTHORIZED ALTERATION OR ADDITION TO A PLAN BEARING A
LICENSED PROFESSIONAL ENGINEER'S SEAL IS A VIOLATION OF
SECTION 7209, SUB-DIVISION 2 OF THE N.Y. STATE EDUCATION LAW
FELLENZER ENGINEERING, LLP
CERTIFICATE OF AUTHORIZATION #: 0017795

FELLENZER 
ENGINEERING LLP
www.fello.com

22 Mulberry St., Suite 2A,
Middletown, NY 10940
t 845-343-1481 fx 845-343-4986

DESIGNED BY:	DRAWN BY:	APPROVED BY:	FE PROJECT #:
--------------	-----------	--------------	---------------

1/8" 1/4" 1/2" 0 1" 2"

REFERENCE SCALE

H4.12

JOB NO 6784502	MODEL NUMBER	SC-110010MA	DRAWN BY	SHEWATS FIRE	DESCRIPTION OF OPERATION: 20V 3 Phase w/ control for 1 Exhaust Fan, Exhaust on in Fire, Lights out in Fire, Relay Dr-Off with Supply Fan, Panel Dr-Off/Thermally/Manually Controlled, Room Temperature sensor, project scope for Risk Mitigation
	JOB NAME	Peekskill Firehouse Kitchen L.	DATE	5/8/2024	

INTERLOCK NETWORK

CONTROL PANEL TO BLACK O/C

TO RED O/C

MASTER FS O/C

PANEL O/C

MASTER CODE

TO LINK TERMINALS TO ALL CODE PANELS THAT MUST ACTIVATE TOGETHER SEE MASTER & SLAVE DIP SWITCHES PER FIRE SYSTEM MANUAL

[illegible][illegible]