

- BUILDING ELEVATIONS:
BASEMENT = -12'-0"
FIRST FLOOR = 0'-0"
SECOND FLOOR = 12'-0"
ROOF = 23'-9 1/4"
- CONDENSATE PITCHED AT
1/8" PER FOOT
HWS/R CONNECTIONS TO
UNIT VENTILATORS IS 1"
- 1 UTILITY COMPARTMENT
2 CONDENSATE PIPED TO
EXTERIOR. DRAIN DOWN TO
GRADE.
3 DROP TO PIPE ENCLOSURE
& ROUTE TO UNIT
4 EXPANSION COMPENSATORS

TRADE	DESCRIPTION	DATE	REV
MECHANICAL	MECHANICAL PIPING AND EQUIPMENT	01/01/2023	01
ELECTRICAL	ELECTRICAL		
PLUMBING	PLUMBING		
MECHANICAL	MECHANICAL		

TRADE	COMPANY	DATE	AUTHORIZED SIGNATURE
MECHANICAL			
ELECTRICAL			
PLUMBING			
MECHANICAL			

COORDINATION NOTE

ELITECAD DESIGNS SHALL NOT BE RESPONSIBLE FOR ANY MATERIALS CONSTRUCTION ERRORS OR OMISSIONS THAT MAY RESULT FROM ASSUMPTIONS MADE BY THE CLIENT BASED ON THE INFORMATION PROVIDED ON THESE DRAWINGS. REQUIREMENTS ARE MADE BY A MEMBER OF THE FIELD AND THE ASSUMPTIONS MADE AT THE MEMBER'S LOCATION.

ELITECAD DESIGNS DISCLAIMER

INFORMATION APPEARING ON THIS SHEET HAS BEEN PREPARED FROM THE BEST INFORMATION AVAILABLE. ELITECAD DESIGNS ASSUMES NO LIABILITY TO THE USER FOR ANY CONSTRUCTION AND/OR MATERIALS DEFICIENCIES. THE USER SHALL BE RESPONSIBLE FOR THE ACTUAL CONSTRUCTION AND/OR MATERIALS. ELITECAD DESIGNS ASSUMES NO LIABILITY FOR ANY CONSTRUCTION AND/OR MATERIALS DEFICIENCIES. THE USER SHALL BE RESPONSIBLE FOR THE ACTUAL CONSTRUCTION AND/OR MATERIALS.

ARCHITECT / ENGINEER NOTES:

FOR APPROVAL

VERIFY THAT LINE ABOVE IS 1" LONG. PRINT MAY HAVE BEEN REDUCED.

REV	DATE	DESCRIPTION
0	12/14/2023	SUBMITTED FOR APPROVAL

