

DRAWING NOTES AND SYMBOLS

BUILDING ELEVATIONS:
BASEMENT = -12'-0"
FIRST FLOOR = 0'-0"
SECOND FLOOR = 12'-0"
ROOF = 23'-9 1/4"

CONDENSATE PITCHED AT
1/8" PER FOOT
HWS/R CONNECTIONS TO
UNIT VENTILATORS IS 1"

① UTILITY COMPARTMENT
② CONDENSATE PIPED DN TO
FIRST FLOOR
③ DROP TO PIPE ENCLOSURE
& ROUTE TO UNIT
④ EXPANSION COMPENSATORS

REFERENCE DRAWINGS			
TRADE	DESCRIPTION	DATE	REV
MECHANICAL	MECHANICAL ROOMS	12/15/2023	0
PLUMBING	PLUMBING	12/15/2023	0
ELECTRICAL	ELECTRICAL	12/15/2023	0
STRUCTURAL	STRUCTURAL	12/15/2023	0
MECHANICAL	MECHANICAL	12/15/2023	0

RECORD OF TRADE COORDINATION			
TRADE	COMPANY	DATE	AUTHORIZED SIGNATURE
MECHANICAL			
PLUMBING			
ELECTRICAL			
MECHANICAL			
PLUMBING			

COORDINATION NOTE

ELITECAD DESIGNS SHALL NOT BE RESPONSIBLE FOR ANY MATERIAL CONSTRUCTION ERRORS OR OMISSIONS THAT MAY RESULT FROM ASSUMPTIONS BY THE CLIENT BASED ON THE INFORMATION PROVIDED IN THESE DRAWINGS. REQUIREMENTS ARE MADE BY A VENDOR IN THE FIELD AND THE ASSUMPTION DATA AT THE VENDOR'S LOCATION.

ELITECAD DESIGNS DISCLAIMER

INFORMATION APPEARING ON THIS SHEET HAS BEEN OBTAINED FROM THE BEST INFORMATION AVAILABLE. ELITECAD DESIGNS ATTENDS TO THE BEST OF ITS ABILITY TO PROVIDE ACCURATE INFORMATION. ELITECAD DESIGNS DOES NOT WARRANT THE ACCURACY OF THE INFORMATION PROVIDED. ELITECAD DESIGNS SHALL NOT BE RESPONSIBLE FOR ANY MATERIAL CONSTRUCTION ERRORS OR OMISSIONS THAT MAY RESULT FROM ASSUMPTIONS BY THE CLIENT BASED ON THE INFORMATION PROVIDED IN THESE DRAWINGS. REQUIREMENTS ARE MADE BY A VENDOR IN THE FIELD AND THE ASSUMPTION DATA AT THE VENDOR'S LOCATION.

ARCHITECT / ENGINEER NOTES:

FOR APPROVAL

VERIFY THAT LINE ABOVE IS 1" LONG. PRINT MAY HAVE BEEN REDUCED.

REV	DATE	DESCRIPTION
0	12/15/2023	SUBMITTED FOR APPROVAL

