

SUBMITTAL COVERSHEET **Nanuet UFSD –Phase 3 Projects**

Architect:
KSQ Architects
215 W 40th Street, 15th Floor
New York, NY 10018

Owner:
Nanuet Union Free School District
101 Church Street
Nanuet, NY 10954

Construction Manager:
Jacobs
One Penn Plaza, 54th floor
New York, NY 10019

Contractor: Joe Lombardo Plumbing & Heating of Rockland Inc

Contract: Ron Lombardo

Address: 321 Spook Rock Road Suite 109A
Suffern, New York 10901

Telephone: 845-357-6537

Fax: 845-357-8529

School Name: Nanuet Union Free School District Phase 3 Bond Projects @ Barr Middle School & Nanuet High School

Type of Submittal:

Re-submittal: ☐ No ☐ Yes

☐ Shop Drawings ☐ Product Data ☐ Schedule ☐ Sample ☐ _____
☐ Test Report ☐ Certificate ☐ Color Sample ☐ Warranty ☐ _____

Submittal Description:

Product Name: STEAM & CONDENSATE SPECIALTIES - REVISION #1

Manufacturer: WALLACE EANNACE

Subcontractor/Supplier: D&B ENGINEERING

References:

Spec. Section No.: 232214

Drawing No(s): _____

Paragraph: _____

Rm. or Detail No(s): _____

Architect's/ Engineer's Review Stamp

Contractor Review Statement:

These documents have been checked for accuracy and coordinated with job conditions and Contract requirements by this office and have been found to comply with the provisions of the Contract Documents.

Ronald J. Lombardo

10.6.23

Name:

Date:

Company Name:

Joe Lombardo Plumbing & Heating of Rockland Inc.

Remarks:

1. Provide full load data or electrical operating load data for condensate pump as submitted system is 3-horsepower vs scheduled 2-horsepower.
2. Provide steam trap submittal data for steam main drip pocket assembly as outlined on keyed note 11 drawing HS-M108.

Remarks:

1. Enclosed is the revised submittal with data for the condensate pump 2. we actually need the engineer to provide more data per the rfi i wrote for the steam traps size and type and the prv station not shown we see the main drip pocket details on the dwgs which will be submitted on our shop dwg after we receive the answer to the rfi.