



GENERAL NOTES:

1. REMOVE DRAWINGS INDICATE DEVICE LOCATIONS, EQUIPMENT CONNECTIONS, AND PANEL LOCATIONS AS OBSERVED IN THE FIELD. EXISTING PANEL INFORMATION IS BASED ON FIELD OBSERVATION AND AS BUILT DRAWINGS. VERIFY ALL INFORMATION PRIOR TO REMOVAL. CONFIRM ALL LOCATIONS WITH FIELD OBSERVATIONS, MEASUREMENTS, AND INVESTIGATION. REMOVE ELECTRICAL ITEMS SHOWN ON PLANS UNLESS NOTED OTHERWISE.
2. PROVIDE LIFTS, LADDERS, AND OTHER EQUIPMENT REQUIRED TO GAIN ACCESS FOR ALL ELEVATED WORK. OWNER'S LIFTS AND LADDERS SHALL NOT BE USED.
3. COORDINATE REMOVALS WITH THE ARCHITECTURAL PLANS.
4. COORDINATE ELECTRICAL REMOVALS WITH OTHER TRADES.
5. SEE BM-E001 FOR GENERAL PROJECT NOTES.

KEYED NOTES:

- 1 REMOVE EXISTING CAM/LIGHTING. PRESERVE CIRCUITS FROM PANEL LV2 AND CONTROLS FROM THE BUILDING.
- 2 RECONNECT TO EXISTING LIGHTING CIRCUITS FROM PANEL LV2 AND CONTROLS. COORDINATE WITH ARCHITECTURAL AND STRUCTURAL PLANS.
- 3 SAFELY REMOVE AND TEMPORARILY STORE CAMERAS, BLUE LIGHT, CABLES, AND ACCESSORIES FOR REUSE DURING CAM/LIGHT REPLACEMENT. OBTAIN THE SERVICES OF THE OWNER'S SECURITY VENDOR FOR PROGRAMMING, ADDITIONS, AND/OR RELOCATIONS OF EXISTING SECURITY DEVICES.
- 4 SAFELY REMOVE AND TEMPORARILY STORE CAMERAS, BLUE LIGHT, CABLES, AND ACCESSORIES FOR REUSE DURING CAM/LIGHT REPLACEMENT. OBTAIN THE SERVICES OF THE OWNER'S SECURITY VENDOR FOR PROGRAMMING, ADDITIONS, AND/OR RELOCATIONS OF EXISTING SECURITY DEVICES.

ARCHITECT

ksqdesign

NEW YORK OKLAHOMA

**KSQ Design**  
215 W 40th Street 15th Floor  
New York, NY 10018  
646.435.0660 office  
[www.ksq.design](http://www.ksq.design)

Owner

**Nanuet Union Free School District**  
101 Church Street  
Nanuet, NY 10954  
845.627.9880  
[www.nanuetsd.org](http://www.nanuetsd.org)

Structural Engineer

**Clapper Structural Engineering**  
160 Partition Street  
Saugerties, NY 12477  
845.943.9601  
[www.clapperstructural.com](http://www.clapperstructural.com)

MEP Engineer

**Sage Engineering Associates, LLP**  
9 Columbia Circle  
Albany NY 12203  
518.453.6091  
[www.sageellp.com](http://www.sageellp.com)

Environmental

**Quest Environmental Solutions**  
1376 Route 9  
Wappingers Falls, NY 12590  
845.298.6251  
[www.qualityenv.com](http://www.qualityenv.com)

### Construction Manager

**Jacobs**  
One Penn Plaza  
24<sup>th</sup> Floor, Suite 2400  
New York, NY 10119  
646.908.6550  
[www.jacobs.com](http://www.jacobs.com)



NUFSD BOND  
PHASE 5  
PROJECT -  
BARR MS

LIGHTING FIXTURE SCHEDULE								
NOTE:								
TYPE	DESCRIPTION	MANUFACTURER	LAMP				VOLTS	FIXTURE REMARKS
			TYPE	WATTS	LUMENS	COLOR		
L1	6' AQUAS SERIES EXTERIOR LINEAR CANOPY LED	FORUM LIGHTING #AQD-32-65-40-WOL-S-6-UNI/WH	LED	39.6 W	3900 lm	4000 K	120/277	
ELU3	COLD WEATHER EM LIGHTING UNIT, SELF DIAGNOSTIC	RAB LIGHTING #EMOUT-3MSK	LED	6.0 W	349 lm	3200 K	120/277	

☐ SED#50-01-08-03-0-002-020 (HIGHVIEW ES)  
☐ SED#50-01-08-03-7-007-002 (Maintenance)  
☐ SED#50-01-08-03-7-012-004 (OEC)  
☐ SED#50-01-08-03-0-001-026 (MILLER ES)  
☒ SED#50-01-08-03-0-004-022 (BARR MS)

Highview Elementary School  
24 Highview Ave  
Nanuet, NY 10954

OEC Building  
135 Convent Road  
Nanuet, NY 10954

Maintenance Building  
103 Church St.  
Nanuet, NY 10954

Miller Elementary School  
50 Blauvelt Rd Unit1  
Nanuet, NY 10954

A MacArthur Barr Middle School  
143 Church St  
Nanuet, NY 10954

KEY PLAN

REVISIONS		
No.	Description	Date
1	SED ADD #1	11/06/24

ISSUED: BID SET

DATE: 06/21/2024

SCALE: AS NOTED

**SHEET NAME:**  
FIRST FLOOR  
ELECTRICAL PLANS

SHEET NUMBER:

BM-E101

## SSUE FOR BID SET