




WALL TYPE F
ONE LAYER 5/8" TYPE "X" GYPSUM WALLBOARD ON ONE SIDE OF WOOD STUDS




WOOD FLOOR TYPE - FT1
3" = 1'-0" 2




WALL TYPE M
CONCRETE MASONRY UNIT CORE WALL UNIT, WITH OR WITHOUT INTERIOR FURR OUT, ONE OR BOTH SIDES
UL # = XXXX
2 HR FIRE RATING
STC (DESIGNED) = 65




WALL TYPE F
ONE LAYER 5/8" TYPE "X" GYPSUM WALLBOARD ON ONE SIDE OF METAL STUDS




WALL TYPE P
ONE LAYER 5/8" TYPE "X" GYPSUM WALLBOARD ON BOTH SIDES OF METAL STUDS




WALL TYPE S
ONE LAYER 5/8" TYPE "X" GYPSUM WALLBOARD ON ONE SIDE OF CH STUD
ONE LAYER 1" SHAFT WALL
FIRE RATED BATT INSULATION IN CAVITY
UL # = U415 SYSTEM A
1 HR FIRE RATING
STC (DESIGNED) = 39



WALL TYPE A.2
TWO LAYERS 5/8" TYPE "X" GYPSUM WALLBOARD ON BOTH SIDES OF METAL STUDS
FIRE RATED BATT INSULATION IN CAVITY
UL # = U407
1/2 - 1 HR FIRE RATING
STC (DESIGNED) = 62



WALL TYPE A.1
ONE LAYER 5/8" TYPE "X" GYPSUM WALLBOARD ON BOTH SIDES OF METAL STUDS
FIRE RATED BATT INSULATION IN CAVITY
UL # = U407
7/8 - 1 HR FIRE RATING
STC (DESIGNED) = 52



WALL TYPE A
ONE LAYER 5/8" TYPE "X" GYPSUM WALLBOARD ON BOTH SIDES OF METAL STUDS
BATT INSULATION IN CAVITY
UL # = U419
STC (DESIGNED) = 52

WALL TYPE LEGEND
1 1/2" = 1'-0" A1